



Office of the
Executive Engineer,
Central Mechanical Division,
Urban Development & MA Department,
Government of West Bengal,
Nirman Bhavan,
Kolkata - 91.

Corrigendum no.1

Tender Reference Number : UD/e-NIQ/CMD/17/2017-18 OF EXECUTIVE ENGINEER , Central Mechanical Division

Tender Id : 2018_UDD_165954_1

Following additional considerations are to be made during selecting or fabricating of PSS :-

1) Transformer Compartment protection shall be IP 34 instead of IP 23 as mentioned in the BOQ.

2) Complete RMU should have internal Arc tested for 21KA/ 1 sec in both main tank & Cable chamber.

3) IAC A&B should be read instead of A&B in the scope of work sl. No. vii.

4) Maximum Transformer losses allowable are as described below:-

No load Loss= 1.1KW

Full load loss= 3.4 KW

Impedance= 4.5%

Executive Engineer,
Central Mechanical Division

Memo No. 844

Dated:10.04.2018

Copy forwarded for information & necessary action to:

- 1) The Special Engineer, Salt Lake Reclamation & Development Circle, U.D.Department
- 2) The S.D.O. Salt Lake Electrical Sub-Division.
- 3) Estimating section
- 4) Divisional Accounts Officer
- 5) Notice Board
- ✓ 6) Computer cell, Nagaryan.

Executive Engineer,
Central Mechanical Division
10/4/18.