

OFFICE OF THE ASANSOL MUNICIPAL CORPORATION ASANSOL :: BURDWAN



TEL-FAX : (0341)2302491

e-mail ID – asansolmunicipalcorporation@gmail.com

Memo No. :- 89/PW/ENG/2017

Dated: 11/05/2017

NOTICE INVITING e-BID

BID NO :- . Q-09/WS/ENG/AMRUT/17.

The Secretary, Asansol Municipal Corporation, on and for behalf of the Board of Councillors of Asansol Municipal Corporation invites sealed competitive Bid on Turnkey Basis (Two part System) from reliable and resourceful Companies / Firms / Contractors having experience and acumen in construction work as noted below the eligibility and depicted hereunder for participating in the e-Bid.

1) Name of the Work:-

Surveying, investigation, Planning, Designing, Construction & commissioning of 6.0 meter diameter Collector well, 1 (one) No. 750 mm dia. infiltration gallery (required length designed by Bidder minimum 250.00 meter long) with 40 Nos. 300 mm dia. 10 mm thick spiral mild welded M.S. Strainer (required length designed by bidder minimum 18.00 meter long) pushing, foot way bridge, with clear water pumping station having capacity to supply 24.97 MLD with 16 hours operation (Approx.- 1560.625 m³/ hour), LT substation with PDB panel and soft starter at collector well and Supplying & laying of 2 X 450 mm dia. (approx length 2X 400.00 meter) 12 mm thick spiral welded mild steel M.S. Pipe line from Collector well to (1000 mm dia mild welded 16 mm thick, 3.00 meter length) manifold line dia at the starting point of foot way bridge (river bank of high lift pump house). From the manifold line laying of 800 / 700 / 600 mm dia. D.I pipe line (approx length 300 meter) (D.I. Pipe will be supply from A.M.C office) with necessary valves and accessories, to GLR 1 with necessary civil, electrical (according to Indian Electricity rules), mechanical & all other allied works related for Kulti water Project as

per SWID hydraulic survey report (with necessary approval from respective Authority) including lightening with yard and internal illumination complete in all respect on turnkey basis and after satisfactory completion and commissioning, 3 (three) months trial run, necessary training of maintenance staff & thereafter (subsequently) 5 (five) years operation and maintenance with security and guarding arrangement under AMRUT.

2) Location of Work:-

Dag No 278, Khatian No. 306 & 359 and Mouza –Chinakuri, P.S: Kulti, Dist.: Paschim Bardhaman.

3) Eligibility to participate in the Bid:-

Having experience and technical acumen in Executing, Construction & Completion of collector well, Infiltration gallery, strainer pushing, collector well foot way bridge structure with joist frame, pumping station of 10 MLD or above capacity within last five financial year, L.T. Sub-station for PDB panel and soft starter including Civil & Electro-mechanical works and supplying, Laying of 12 mm thick Spiral mild welded M.S. rising main pipe for a length not less than 0.300 meter in a single / separate contract during last five financial years in any Govt. / Board / Semi Govt. / Corporation /Statutory Authority / Govt. undertaking etc. organization.

AND

Having sufficient qualified technical personnel (to be employed under the firm for at least 3 consecutive years) with sound knowledge and experience in execution of similar nature of works.

AND

Having annual turnover of at least Rs.10.00 crore or above in any one year of last five Financial years.

AND

Having valid electrical license for L. T. line, VAT / ST, TAN, PAN Card, E.S.I Registration Certificate and Electrical supervisory license etc.

4) Documents to be produced in support of Credential for Bid:-

A successful performance and completion certificate supplemented with work order along with payment certificate issued by the competent authority shall have to be furnished in support of credibility in terms with eligibility criteria depicted in this Notice **(Ref: Sl. No. 3 : Eligibility to participate in the Bid)**. Besides this, following documents shall have to be furnished:

- a) Particulars of ownership / partnership or Board of Directors pertaining to the Organization / Company / Firm.
- b) Copies of valid PAN Card, & E.S.I Registration Certificate, Electrical Supervisory license Certificate (LT).
- c) Bank solvency Certificate not less than 5.00 crores in the financial year 2016-2017.
- d) Valid documents in support of annual Turnover.
- e) List of machines & equipment necessary for fields.
- f) List of Technical Personnel employed under the organization in details with names, qualification, experience and address with contact number.
- g) Corresponding address, fax & telephone nos. Contract mobile no. & Email no. of the Organization.

All documents in original to be produced in due course of time as & when asked by the Tender Inviting Authority

5) Earnest Money:-

- a) **2% of the Quoted Bid price in two parts, vice. Rs. 5,00,000.00 (Rupees Five Lakhs only) as an initial Earnest Money Deposit shall accompany with Bid Proposal in favour of the “Asansol Municipal Corporation, Payable at Asansol.”**

b) Initial earnest money is to be deposited either online by net Banking through using ICICI Bank Payment Gateway or offline through RTGS / NEFT. Please refer Memo No 3975-F(Y) dated 28.07.2016 of the Finance Department, Govt. of West Bengal

c) Earnest Money Deposit i.e. 2% of bid amount beyond Rs.5,00,000.00 (if any) shall have to be deposited after acceptance of Bid Proposal.

6) Date and time schedule:-

Sl. No.	Particulars	Date & Time
1	Date of uploading of NleB. and Bid Documents (online) (Publishing Date)	12/05/2017
2	Date of Pre Bid Meeting with the intending bidders In the office of the Superintending Engineer, West Circle, at Asansol Municipal Corporation, G.C. Mitra Road, Asansol, Paschim Bardhaman.	22/05/2017 3.00 p.m.
3	Documents download start date (Online)	12/052017 3.00 p.m.
4	Documents download end date (Online)	05/06/2017 3.00 p.m.
5	Bid submission start date (On line)	12/05/2017 3.00 p.m.
6	Bid Submission closing (On line)	05/06/2017 3.00 p.m.
7	Bid opening date for Technical Proposals (Online)	07/06/2017 2.00 p.m.
8	Date of uploading list for Technically Qualified Bidder (online)	To be notified later
9	Date of uploading the final list of Technically Qualified Bidder (online) after disposal of appeals, if any.	To be notified later
10	Date for opening of Financial Proposal (Online)	To be notified later
11	Also if necessary for further negotiation through off line for final rate.	To be notified later

7) Cost price of Bid Document:- "Nil"

8) Time of completion:-

Time of completion of the Contract is 12 (twelve) months from the date of issue of Work Order.

9) Site inspection & general information:-

Intending Bidders are required to inspect the site of the Project with particular reference to location and infrastructure facilities. They are to make a careful study with regard to availability of materials and their sources and all relevant factors as might affect their rates and prices. They are also acquainted with relevant IS specifications, CPHEEO manuals, Clauses & Sub Clauses of the Bid documents and to have fully acquainted with all details of work front, communications, underground utility services, seasonal weather and its variation, labour, water supply, existing & proposed site levels, position and diversion of transportation and barricading , if required, electricity and any other general information including topological condition & existing level and level pertaining to and needed for the work to be completed in time properly.

10) Bid documents:-

A full set of Bid documents consists of 2 Parts. These are;

a) Part I containing all documents in relation to the name of the firm applied credentials possessed by them, all documents as depicted in Sl. No. 4 along with this NleB and its all corrigenda's.

AND

Section A: Description of the Project.

Section B: Conditions & requirements for Bidding.

Section C: General conditions of the contract.

Section D: Special provisions.

Section E: General specifications of Workmanship & materials for Civil Works.

Section F: General technical specification.

Section G: Surveying, investigation, detailed drawing, design, technical specification for civil works for 6.0 meter diameter Collector well, foot way bridge with suitable joist frame, 1 Nos. 750 mm dia. 250 meter long infiltration gallery with 40 Nos. 300 mm dia. 10 mm thick spiral mild welded M.S. Strainer pushing, clear water pumping station having capacity to supply 24.97 MLD with 16 hours operation (Approx.- 1560.625 m³/ hour), LT substation with PDB panel and soft starter at collector well and Supplying & laying of 2 X 450 mm dia. (approx length 2X 400.00 meter) 12 mm thick spiral welded mild steel M.S. Pipe line from Collector well to (1000 mm dia mild welded 16 mm thick, 3.00 meter length) manifold line at the starting point of foot way bridge (river bank of high lift pump house). From the manifold line laying of 800 / 700 / 600 mm dia. D.I pipe line (approx length 300 meter) (D.I. Pipe will be supply from A.M.C office) including all necessary valves and accessories from Collector well to GLR 1 with necessary civil, electrical (according to Indian Electricity rules), mechanical & all other allied works related for Kulti water Project as per SWID hydraulic survey report (with necessary approval from respective Authority) including jetty & Substation lightening with yard and internal illumination complete in all respect on turnkey basis.

Section H: General Technical Specification for R.C.C Pile foundation.

Section I: Technical Specification of Pumps.

Section j: Mechanical works

Section K: Motor Control Panel

Section L: Electrical Motor Works

Section M: Specification of Substation Building

Section N: Laying Of Rising Main

Section O: Annexure

- i. Soil Investigation Report.
- ii. List of documents to be furnished

- iii. Tentative Layout of Substation Building
- iv. List of tools / Electrical equipment.
- v. List of vendors
- vi. List of deviation
- vii. Hydraulic survey report(SWID report)
- viii. Tentative lay out plan of Intake Jetty
- ix. Site Plan

b) **Part II** containing following documents;
Bid Price / Price Schedule (BOQ).

11) Validity of Bid:-

A Bid submitted shall remain valid for a period of 120 calendar days from the date set for opening of Bids. Any extension of this validity period if required will be subject to concurrence of the Bidders.

12) Withdrawal of Bid:-

A Bid once submitted shall not be withdrawn within the validity period. If any Bidder/Bidders withdraw his / their Bid(s) within the validity period then Earnest Money as deposited by him / them will be forfeited.

13) Acceptance of Bid:-

The Secretary, Asansol Municipal Corporation will accept the Bid on recommendation of the Competent Authority. He does not bind himself to accept otherwise the lowest Bid and reserves to himself/herself the right to reject any or all of the Bids received without assigning any reason thereof.

14) Intimation:-

The successful Bidder will be notified in writing of the acceptance of his Bid. The Bidder then becomes the “Contractor” and he shall forthwith take steps to execute Formal Contract Agreement in appropriate Asansol Municipal Corporation Form with the Secretary, Asansol Municipal Corporation and fulfil all his obligations as required by the Contract.

After the Bid is provisionally accepted, the Bidder shall submit detail Design, Drawing and working specifications phase wise based on existing site condition & proposed levels at site. If it is found technically correct and acceptable with proper examination by the Superintending Engineer, Western Circle, M.E. Directorate, provisional approval of the submitted drawings will be accorded phase wise for execution.

Eventually, all the parts, Design, Drawings etc. of the successful Bidder shall be taken as a part of the agreement.

15) Escalation of Cost:-

There will be no escalation in cost for materials or labour and the contract price mentioned in the contract stands valid till completion of the operation and maintenance of the contract.

16) Name & address of Engineer-In-Charge (EIC) of the Work

Executive Engineer, Asansol Division, Municipal Engineering Directorate

17) Execution of Work:-

The Contractor is liable to execute the whole work as per direction and instruction of the Executive Engineer, Asansol Division of Municipal Engineering Directorate who is the Engineer in Charge of the work after due approval of “The Superintending Engineer, Western Circle, M. E. Dte.”

18) Payment:-

Payment will be made to the successful Bidder by the Secretary, Asansol Municipal Corporation periodically only on receipt of written recommendation from the Executive Engineer, Asansol Division of Municipal Engineering Directorate. Payment for all Electro-mechanical works will be recommended by the Technical Advisor, (E/M) MED.

19) Influence:-

Any attempt to exercise undue influence in the matter of acceptance of Bid is strictly prohibited and any Bidder who resorts to this will render his Bid liable to rejection.

	<u>FOLLOWING CLAUSES ARE TO BE ADHERING TO BY THE CONCERNED BIDDER DURING THE PROCESS OF BIDDING.</u>
19.	In case office faces sudden closure owing to reason beyond the scope and control of the Secretary, any of last date / dates as schedule in Sl. No 7 may be extended up-to / to next and following working day without issuing further and separate notice should the Secretary feel it to be necessary and exigent.
20.	Persons having authenticated and having registered Power of Attorney may be considered lawfully becoming to be acting on and for behalf of the Bidder.
21.	Sufficient care has been taken to avoid variance in between the contents of the listed documents in the Bid documents. However, if there is any variance between the contents of different documents, the provision of documents appearing earlier in the list shall prevail over the same provided in the contents coming later.
22.	Imposition of any duty / tax / rule etc. owing to change / application in legislations / enactment shall be considered as a part of the contract and to be adhering to by the Bidder / contractor strictly.
23.	Bid Acceptance Authority is the Secretary, Asansol Municipal Corporation.

24.	In case of any dispute arising from any clauses of similar nature between bid documents and Municipal tender form, the decision of Superintending Engineer, Western Circle, M.E. Directorate, will be final and binding.
25.	All usual deductions for taxes i.e. ST, IT, and Labour welfare Cess etc. as applicable will be made from the bills from time to time which is inclusive in cl.57 of section C.
26.	No conditional / incomplete Bid shall be entertained.
27.	In the event of e-Filing intending bidder may download the tender document from the website http://wbtenders.gov.in directly by the help of Digital Signature Certificate free of cost. Technical Bid & Financial Bid both will be submitted concurrently duly digitally signed in the Website http://wbtenders.gov.in . Tender document may be downloaded from website & submission of Technical Bid/Financial Bid as per Tender Schedule.
28.	The requisite cost of Earnest Money, as specified in this NleB shall be paid to ICICI bank by online internet bank transfer or NEFT or RTGS in favour of Asansol Municipal Corporation (as per GO No. 3975-F(Y) dt. 28.07.2016 of Finance Department, Govt. of West Bengal). Every such Transfer shall be done on or after the date of publish of NleB. Any Bid without such Transfer of EM (Except exemption as per G.O.) shall be treated as informal and shall be automatically cancelled. Online transfer of Earnest Money receipt (Scanned copy) shall be uploaded as Statutory document.
29.	The Bidder, at the Bidder's own responsibility and risk is encouraged to visit and examine the site of works and its Surroundings and obtain all information that may be necessary for preparing the Bid and entering into a contract for the work as mentioned in the Notice inviting Tender, the cost of visiting the site shall be at the Bidder's own expense. Traffic management and execution shall be the responsibility of the Agency at his / her / their risk and cost.

30.	The intending Bidders shall clearly understand that whatever may be the outcome of the present invitation of Bids, no cost of Bidding shall be reimbursable by the ULB. The Secretary, Asansol Municipal Corporation reserves the right to reject any application for purchasing Bid documents and to accept or reject any or all the offered bid / bids without assigning any reason whatsoever and is not liable for any cost that might have incurred by any Bidder at any stage of Bidding.
31.	Prospective applicants are advised to note carefully the minimum qualification criteria as mentioned in 'Instructions to Bidders' before bidding.
32.	During scrutiny, if it is come to the notice to tender inviting authority that the credential or any other papers found incorrect / manufactured / fabricated, that Bidder will not be allowed to participate in the tender and that application will be out rightly rejected without any prejudice.
33.	Before issuance of the work order, the tender inviting authority may verify the credential & other documents with the original of the lowest bidder if found necessary. After verification, if it is found that such documents submitted by the lowest bidder is either manufacture or false, in that case, L.O.A. / work order will not be issued in favour of the bidder under any circumstances.
34.	If any discrepancy arises between two similar clauses on different notifications, the clause as stated in later notification will supersede former one in following sequence: i) Asansol Municipal Corporation tender form ii) NleB iii) Special terms & Condition iv) Technical bid v) Financial bid
35.	Contractor shall have to comply with the provisions of (a) the contract labour (Regulation Abolition) Act. 1970 (b) Apprentice Act. 1961 and (c) minimum wages Act. 1948 of the notification thereof or any other laws relating thereto and the rules made and order issued there under from time to time.

36.	Where an individual person holds a digital certificate in his own name duly issued to him against the company or the firm of which he happens to be a director or partner, such individual person shall, while uploading any tender for and on behalf of such company or firm, invariably upload a copy of registered power of attorney showing clear authorization in his favour, by the rest of the directors of such company or the partners of such firm, to upload such tender. The power of attorney shall have to be registered in accordance with the provisions of the Registration Act, 1908.
37.	Any legal matter will be settled within the jurisdiction of Hon'ble District Judges Court at Asansol, Dist:- Paschim Bardhaman, West Bengal.
38.	Bidder would be at liberty to point out any ambiguities, contradictions, omissions etc. seeking clarifications thereof or interpretation of any of the conditions of the Bid documents before the Bid Inviting Authority in writing 48 hours prior to Pre Bid Meeting, beyond such period no representation in that behalf will be entertained by the Bid Inviting Authority.
39.	The successful Bidder will remain liable for following with West Bengal Contract Labour (Regulation & Abolition) Act 1970 and necessary certificates from appropriate authority to be submitted within 07 (seven) days from the date of issue of work order, otherwise the work order may be cancelled.
40.	Additional Security Deposit @ 8% (eight percent) will be deducted from each and every running bill. The entire amount of such 10% (ten percent) of Security Deposit (Initial 2% EM + additional 8%) excluding for operation and maintenance will be refunded without any interest only after 3 months from successful running of the whole work in all respect as per clause 57 of section C after full satisfaction of E.I.C.
41	The successful bidder has to provide detailed estimate along with rate analysis (if any) for all civil and electro mechanical works including planning, designing and drawings as per the clause 57 of Section C with all necessary break up elaborately for comparison of rate with departmental estimate if asked by the concerned authority before acceptance of bid which will be treated as part of the bid document.

42.	Clause 57 of Section C has been prepared on the basis of major items of the work so that contractor may get payment after completion of major items in a phase wise way . If any item the contractor feels as major item but not reflected in the clause will be pointed out during pre-bid meeting. All other items (if any) not shown in the payment schedule or in bid document but required for successful completion and commissioning of the project will be in the scope of Bidder.
-----	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Secretary
Asansol Municipal Corporation

INSTRUCTION TO BIDDERS/BIDDERS

SECTION – A

1. General guidance for e-tendering

Instructions / Guidelines for Bidders for electronic submission of the tenders have been annexed for assisting them to participate in e-tendering.

2. Registration of Bidder

Any Bidder willing to take part in the process of e-tendering will have to be enrolled and registered with the Government e-procurement system, through logging on to <http://wbtenders.gov.in>. The Bidder is to click on the link for e-tendering site as given on the web portal.

3. Digital Signature certificate (DSC)

Each Bidder is required to obtain a class-II or Class-III Digital Signature Certificate (DSC) for submission of tenders, from the service provider of the National Information's Centre (NIC) or any other bonafide service provider on payment of requisite amount. Details are available at the Web Site stated in Clause 2 of Guideline to Bidder. DSC is given as a USB e-Token.

4. The contractor can search and download NIB and Tender Documents electronically from computer once he logs on to the website mentioned in Clause 2 using the Digital Signature Certificate. This is the only mode of collection of Tender Documents.

5. Submission of Tenders.

General process of submission, Tenders are to be submitted through online to the website stated in Cl. 2 in two folders at a time for each work, one in Technical Proposal and the other is Financial Proposal before the prescribed date and time using the Digital Signature Certificate (DSC) the documents are to be uploaded virus scanned copy duly Digitally Signed. The documents will get encrypted (transformed into non readable formats).

A. Technical proposal

The Technical proposal should contain scanned copies of the following further two covers (folders).

A-1. Statutory Cover Containing

1. Prequalification Document

- i. Prequalification Application (Sec-B, Form – I)
- ii. Scanned Copy online Transaction of earnest money (EMD) as prescribed in the NleB against each of the serial of work in favour of “The Secretary, Asansol Municipal Corporation,” payable at Asansol.

2. NleB with Bid Documents (downloads and upload the same Digitally Signed)

3. Technical Document (*To be filled, scanned & digitally signed*)

- i. Financial Statement (Section – B, Form – II).
- ii. Affidavits((Ref:- format for general affidavit shown in “Y” Part “B”.)
- iii. Bank Solvency Certificate.
- iv. Form III & IV Of Section B.

A-2. Non statutory Cover Containing / My Documents

- i. Professional Tax (PT) deposit receipt challan (up to date), PAN Card, IT, IT Return for the Current Assessment year, VAT Registration Certificate (up to date).
- ii. Registration Certificate under Company Act. (if any).
- iii. Registered Deed of partnership Firm/ Article of Association and Memorandum
- iv. Power of Attorney (For Partnership Firm/ Private Limited Company, if any)
- v. Tax Audit Report along with Balance Sheet and Profit and Loss A/c for the last five years(year just preceding the current Financial Year will be considered as year – I)
- vi. Clearance Certificate for the Current Year issued by the Assistant Registrar of Co-Op (S) (ARCS) bye laws are to be submitted by the Registered labour Co-Op(S) Engineers’ Co.-Opt.(S).

vii. List of machineries possessed by own/arranged through lease deed along with authenticated documents of lease / sub-lease / hire basis etc.

viii. List of laboratory Instrument.

ix. List of technical staff along with structure and organization (Section – B, Form – III).

x. Credential: Scanned copy of Original Credential Certificate as stated in NleB

Note: - Failure of submission of any of the above mentioned documents (as stated in A1 and A2) will render the Bid liable to be summarily rejected for both statutory and non statutory cover.

INTENDING BIDDERS SHOULD UPLOAD NON-STATUTORY DOCUMENTS AS PER FOLLOWING FOLDERS IN MY DOCUMENT:

E-Bidding system of Government of West Bengal			
Bidder Document Sub Category Master			
Sl. No.	Category Name	Sub Category Name	Sub Category Description
A	CERTIFICATES	A1. CERTIFICATES	1. West Bengal VAT Registration / ST Registration / P.F / PAN 2. Valid Electrical License 3. E.S.I Registration Certificate.
B	COMPANY DETAILS	B1. COMPANY DETAILS	1. Proprietorship Firm (Trade License). 2. Registered Deed of partnership Firm 3. Registration Certificate under Company Act. (if any). Ltd. Company (Incorporation Certificate , Trade License) 4. Power of Attorney (For Partnership Firm / Private Limited Company, if any) 5. Society (Society Registration copy, Trade License)

C	CREDENTIAL	C1. CREDENTIAL1	Similar nature Work & Completion Certificates along with work order and payment certificate issued by competent authority (as per SI No. 3 of NleB)
D	EQUIPMENT	D1. LABORTARY	1. List of Machineries and equipment necessary for field as well as laboratory test of all materials as per NleB
		D2.CIVIL MACHINERIES	
		D2. ELECTRICAL MACHINERIES	
		D2. MECHNANICAL MACHINERIES	
		D2. MISCELLENEOUS MACHINERIES	
E	FINANCIAL INFO	E1. P/L & BALANCE SHEET 2011- 2012	P/L & BALANCE SHEET (as per NleB)
		E2. PAYMENT CERTIFICATE 1	Payment Certificate in support of valid Credential only to be submitted
		E3 PAYMENT CERTIFICATE 2	
F	MANPOWER	F1. TECHNICAL PERSONNEL	1. List of sufficiently qualified technical person (as per SI No 3 of NleB)
		F2. TECHNICAL PERSONNEL ON CONTRACT	1. List of technical personnel employed under the organisation (or on contact basis) in details with name, qualification, experience and, address with contact number.
G	DECLARATION	DECLARATION 1	1. Bank Solvency Certificate (As per NleB)
		DECLARATION 2	2. Valid Document in support of annual turnover as per NleB.
		DECLARATION 3	3. Corrigendum and additional document (if any).

Note:- Failure of submission of any of the above mentioned documents (as stated in A1 & A2) will render the Bid liable to summarily rejected for both statutory & non statutory cover. All Corrigendum & Addendum Notices, if any, have to be digitally signed & uploaded by the contractor in the Declaration Folder of My Documents.

B. Bid Evaluation

- i. Opening and evaluation of Bid :- If any Bidder is exempted from payment of EMD, copy of relevant Government order needs to be furnished (applicable in case of Registered Labour Co-Operative Society).

- ii. Opening of Technical proposal: - Technical proposals will be opened by the Bid Inviting Authority electronically from the website using his/ her Digital Signature Certificate.

- iii. Cover (folder) of statutory documents (vide Cl. No. 5.A-1) should be opened first and if found in order, cover (Folder) for non-statutory documents (vide Cl. No.– 5.A-2) will be opened. If there is any deficiency in the statutory documents the Bid will summarily be rejected.

- iv. Decrypted (transformed in to readable formats) documents of the non-statutory cover will be downloaded and handed over to the Bid Evolution Committee. Scrutiny of technical proposal and recommendation thereafter and processing of comparative statement for acceptance etc. will be made by the Municipal Engineering Directorate, under the department of Municipal Affairs, Govt. of West Bengal. Comparative Statement may be forwarded to appropriate authority depending on the value of the work as applicable as per existing norms and guidelines under UIDSSMT programme.

- v. Uploading of summary list of technically qualified bidders.

- vi. Pursuant to scrutiny and decision of the screening committee the summary list of eligible Bidder and for which their proposal will be considered and uploaded in the web portals.

- vii. While evaluation, the committee may summon the bidders and seek clarification / information or additional documents or original hard copy of any of the documents already submitted and if these are not produced within the stipulated time frame, their proposals will be liable for rejection.

C. Financial proposal

As per SI. 9 Part II (a) , Bid Price / Price Schedule. To be uploaded digitally signed by the Bidder.

6. Financial capacity of a Bidder will be judged on the basis of working capital and available bid capacity as mentioned in the N.I.T. to be derived from the information furnished in **FORM-I and II** (Section-B) i.e., Application (for Pre-qualification) and Financial Statement. If an applicant feels that his / their Working Capital beyond own resource may be insufficient, he/they may include with the application a letter of guarantee issued by a first class Bank to supplement the applicant. **This letter of guarantee should be addressed to the Tender Inviting / Accepting Authority and should guarantee duly specifying the name of the project that in case of contract is awarded to the Bidder, the Bidder will be provided with a revolving line of credit.** Such revolving line of credit should be maintained until the works are taken over by the Authority.

The audited Balance sheet for the last five years, net worth bid capacity etc. are to be submitted which must demonstrate the soundness of Bidder's financial position, showing long term profitability including an estimated financial projection of the next two years.

7. Penalty for suppression / distortion of facts

Submission of false document by Bidder is strictly prohibited and in case of such act by the Bidder the same may be referred to the appropriate authority for prosecution as per relevant IT Act with forfeiture of earnest money forthwith.

8. REJECTION OF BID

The Employer (tender accepting authority) reserves the right to accept or reject any Bid and to cancel the Bidding processes and reject all Bids at any time prior to the award of Contract without thereby incurring any liability to the affected

Bidder or Bidders or any obligation to inform the affected Bidder or Bidders of the ground for Employer's (tender accepting authority) action.

The Bidder who's Bid has been accepted will be notified by the Tender Inviting and Accepting Authority through acceptance letter/ Letter of acceptance. The Letter of acceptance will constitute the formation of the Contract.

The Agreement in Printed Tender Form will incorporate all necessary documents e.g. N.I.B., all addenda-corrigendum, special terms and condition (Section –C), different filled-up forms (Section –B), Price Schedule and the same will be executed between the Tender Accepting Authority and the successful Bidder.

Secretary
Asansol Municipal Corporation

SECTION – B
FORM –I
PRE-QUALIFICATION APPLICATION

To

Secretary

Asansol Municipal Corporation

Ref: - Tender for _____

_____ (Name of work)

_____ **N.I. B. No.:**

Dear Sir,

Having examined the Statutory, Non statutory and NIT documents, I /we hereby submit all the necessary information and relevant documents for evaluation. The application is made by me / we on behalf of _____ in the capacity _____ duly authorized to submit the order.

The necessary evidence admissible by law in respect of authority assigned to us on behalf of the group of firms for Application and for completion of the contract documents is attached herewith. We are interested in bidding for the work(s) given in Enclosure to this letter. We understand that:

- (a) Tender Inviting and Accepting Authority/Engineer-in-Charge can amend the scope and value of the contract bid under this project.
- (b) Tender Inviting and Accepting Authority/Engineer-in-Charge reserves the right to reject any application without assigning any reason.

Enclose: - e-Filling:-

- 1. Statutory Documents
- 2. Non Statutory Documents

Date: -

Signature of applicant

Including title and capacity in which application is made.

SECTION – B
FORM - II
FINANCIAL STATEMENT

B.1 Name of Applicant:

B.2 Summary of assets and liabilities on the basis of the audited financial statement of the last five financial years.

(Attach copies of the audited financial statement of the last five financial years)

	1st Year (Rs. In lakh)	2nd Year (Rs. In lakh)	3rd Year (Rs. In lakh)	4th Year (Rs. In lakh)	5th Year (Rs. In lakh)
a) Current Assets : (It should not include investment in any other firm)					
b) Current liabilities : (It should include bank over draft)					
c) Working capital : (a) – (b)					
d) Net worth : (Proprietors Capital or Partners Capital or Paid up Capital + Reserve and surplus)					
e) Bank loan/ Guarantee : (As per clause G.2. with all sub clauses)					

B.3 Annual value of construction works undertaken :

Work in hand i.e. Work order issued	As on 31.03.2017	As on 31.03.2016	As on 31.03.2015	As on 31.03.2014	As on 31.3.2013	As on 31.03.2012

Signed by an authorized officer of the firm

Title of the officer

Name of the Firm with Seal

Date _____

AFFIDAVIT "Y"

DECLARATION OF THE BIDDER

(Affidavit to be affirmed on a Non Judicial Stamp Paper of Appropriate Value And Duly Notarized)

I,, son of, aged about years by occupation do hereby solemnly affirm and confirm as follow:

1. That, I am the of have duly authorized by and competent to affirm this affidavit on behalf of the said Bidder.

2. That, I have inspected the site of work covered under NIB (NIB No_____) circulated through Office memo bearing No -----dated ----- and have made myself fully acquainted with the site conditions existing level/proposed level and local conditions in and around the site of work. I have also carefully and meticulously gone through the Bid documents. Bid of the above named Bidder is offered and submitted upon due consideration of all factors and if the same is accepted, I on and for behalf of the aforesaid Bidder, being lawfully and duly authorized, promise to abide by all the covenants, conditions and stipulations of the Contractual documents and to carry out, complete the works to the satisfaction of the Bid accepting Authority of the Work and abide by all instructions as may given by the Engineer in Charge of the work time to time. I also hereby undertake to abide by the provisions of Law including

the provisions of Contract Labour (Regulation & Abolition) Act, Apprentice Act 1961, West Bengal Sales Tax Act, VAT Act, Income Tax Act as would be applicable to the Contractor upon entering into formal Contract / agreement with the Bid Inviting/Accepting authority.

3. That I declare that, no relevant information as required to be furnished by the Bidder has been suppressed in the Bid documents.

4. That the statement above made by me is true to my knowledge.

Deponent

Solemnly affirmed by the said

.....

Before me.

.....

(1st class Judicial Magistrate / Notary Public)

SECTION - B

FORM- III

STRUCTURE AND ORGANISATION

A.1 Name of applicant:

A.2 Office Address:

Telephone No. and Cell Phone No. :

Fax No. :

E mail id:

A.3 Attach an organization chart showing the structure of the company with names of Key personnel and technical staff with Bio-data. :

Note: Application covers Proprietary Firm, Partnership, Limited Company or Corporation,

Signature of applicant including title

and capacity in which application is made.

SECTION -B

FORM – IV

DEPLOYMENT OF MACHINERIES (IN FAVOUR OF OWNER / LESSEE):-

(Original document of own possession arranged through lease deed to be annexed)

(If engaged before Certificate from E.I.C. to be annexed in respect of anticipated dated of release of Machineries.)

Name of Machine / Instrument	Make	Type	Capacity	Motor / Engine No.	Machine No.	Possession Status		Date of release If Engaged
						Idle	Engaged	

For each item of equipment the application should attach copies of

- (i) Document showing proof of full payment, (ii) Receipt of Delivery,
- (iii) Road Challan from Factory to delivery spot, is to be furnished.

Signature of applicant including title

and capacity in which application is made.

Successful agency shall have to make an agreement (in two copies) with the Asansol Municipal Corporation, in the prescribed pro-forma by depositing @ Rs. 1000/- (Rupees one thousand only.) for cost of each tender form in cash stating that the agency is agreeable to supply the Pipe materials as and when require (as per the rates quoted and terms and conditions laid down in the quotation papers) to the Municipality with in the Municipal/Adjoining areas (as the case may be).

Secretary,

Asansol Municipal Corporation

Memo No.:- ____/PW/ENG/2017

Dated:_____

Copy Forwarded for information and for favour of wide circulation to:

1. The Mayor, Asansol Municipal Corporation,
2. The District Magistrate, Paschim Bardhaman.
3. The Commissioner, Asansol Municipal Corporation,
4. The Director SUDA, SUDA BHAWAN, HC Block, Sector-III, Saltlake, Kol-106.
5. The Chief Engineer, M.E.Dte., Bikash Bhawan, Saltlake, Kol-106.
6. The Superintendent Engineer, (Western Circle), M.E.Dte., Paschim Bardhaman.
7. The Chief Engineer, Asansol Municipal Corporation.
8. The Superintendent Engineer, Asansol Municipal Corporation.
9. The Revenue officer, Asansol Municipal Corporation.
10. The Executive Engineer, M.E.Dte. Asansol Division.
11. The Finance officer, Asansol Municipal Corporation.
12. The O.S. for wide circulation in a day by National & local News Paper in Bengali, English and Hindi News Paper.
13. The Office Notice Board, Asansol Municipal Corporation for wide circulation.
14. The Guard File.

Secretary,
Asansol Municipal Corporation

SECTION – A

DESCRIPTION OF THE PROJECT

1.0 GENERAL

The work involves Surveying, Investigation, Planning, Designing, Construction & commissioning of Collector well (6.00 meter dia.), 2 Nos. 750 mm dia. 250 meter long

infiltration gallery with 40 Nos. 300 mm dia. 10 mm thick spiral mild welded M.S. Strainer pushing, 3.00 meter width foot way bridge filter water pumping station having capacity to supply 24.97 MLD with 16 hours operation (Approx.- 1560.625 m³/ hour), collector well LT substation (panel and starter) and supplying, laying of 2 X 400 meter length 450 mm dia 12 mm thick spiral welded mild steel M.S. Pipe line (TATA /SAIL make) on both sides of bridge from IGLR1 to 3.00 meter length 1000 mm dia 16 mm thick MS manifold line (at the starting point of footway bridge) and Laying 800 / 700 / 600 mm dia D.I. pipe line from MS manifold line to GLR1 at Chinakuri Pump House approx 300 meter length (DI pipe will be supplied from AMC office) as per design will be constructed by agency for Kulti water project with necessary civil, electrical (according to Indian Electricity rules) & mechanical works & all other allied works related to the project in all respect complete for drawl of water from river Damodar as per SWID hydraulic survey report (with necessary approval from respective authority) including collector well internal illumination, yard lighting and after satisfactory completion and commissioning, 3 (three) months trial run, necessary training of maintenance staff & thereafter (subsequently) 5 (five) years operation and maintenance with security and guarding arrangement except rising main for Kulti water supply project under AMRUT.

2.0 LOCATION

The site of proposed collector well Jetty cum foot way bridge structure with filter water pumping station will be Mouza:- Chinakuri, Plot No. :-278, Dist: Paschim Bardhaman, WB.

3.0 SCOPE OF WORK

The Bid is a design-cum-execution Bid on turnkey basis. The Bidder is advised to go through the documents meticulously. In case of any doubt about any data the Bidder may seek clarification before the Bid Inviting Authority by uploading 48 hour prior of the Pre bid meeting and clarification of the same will be discussed in pre bid meeting and will be uploaded later on.

The Bid comprises of following major works. The works includes surveying, Planning, design, drawing and construction of civil works including supply, carriage of all materials with foundation for the various units of Collector well. The scope also includes Trial Run and testing commissioning the Plant for three months, after successful Commissioning, operating and maintaining the same for a period of 60 (sixty) months after the completion of specified period of Successful Trial Run, under the overall supervision of the Employer / his representative and from the date of commissioning accept rising main.

Sl. No.	Name of the work	Approx quantity
01.	<p>COLLECTOR WELL:- Construction of 6.00 meter diameter RCC central radial collector well with 1 No. 12 mm thick spiral mild welded MS strainer pipe (TATA / SAIL make) of 750 mm dia. (required length designed by bidder minimum 250 meter long) infiltration gallery and 40 Nos. 300 mm dia. 10 mm thick spiral mild welded MS strainer (required length designed by bidder minimum 18 meter long) pushing on virgin soil bed / rock to collect water from the infiltration gallery including surveying, Planning, design, drawing and construction of Civil, Electrical and Mechanical works including supply, carriage of all materials with foundation for the various units of Collector well and provision of following accessories.</p>	01 No.
1.01	<p>Investigation of bed deposit along three sections at 200 meter apart at proposed location at river bed of Damodar, hydraulic parameters (radius of influence and hydraulic conductivity) of sub surface profile, design of infiltration gallery considering least saturated depth of water of 5 meter in river deposit on continuous pumping from gallery to CWR, scour depth etc. Detail design along with drawing of Infiltration gallery, sub surface seepage cut off wall (dyke), pumping system to harvest 5 MGD + 10 % loss of sub surface water by 16 hours pump running per day by each infiltration gallery from river of Damodar at Chinakuri ghat of Kulti,</p>	02 Nos.
1.02	<p>Construction of temporary 5.00 meter wide approach road with supply and hand packing stone boulder (two layers of boulder 300 mm thickness) rolling the same including spreading and consolidating brick bats 200 mm thick, morrum 75 mm thck, placing necessary hume pipe for under pass flowing water of river to facilitate movement of construction equipment / materials from river bank to gallery site path way for transporting materials from river bank up to construction site.</p>	1 item

1.03	Suitable round type platform 1.00 meter width inside the collector well including stair from each platform to other and fixed at top & bottom of collector well.	3 Layer
1.04	Suitable round type platform 1.00 meter width including stair outside the collector well from platform to the river bed including suitable support at top, middle & bottom of well,	1 Layer
1.05	750 mm dia. inlet hole with paddle collar (1 Nos. working and 1 Nos. stand by for future Infiltration gallery) Including supplying and fixing of sluice valve 750 mm dia ISI marked as per IS: 14846 with test certificate of Kriloskar / Upadhaya / Kalpana make with necessary extended spindle, Plummer block, head stock with gear arrangement, spacer with anchor bolt etc. to operate from inspection gallery just after pump platform.	2 Nos.
1.06	40 Nos. 300 mm dia slotted 10 mm thick spiral welded mild steels (TATA / SAIL make) in two / three rows one is at RL 13.50 meter, another one at RL-15.00 meter and other is at 16.50 meter which is at 6.25 meter, 7.25 & 8.00 meter below the river bed of R.L. 22.825 meter. The spiral welded mild steels pipes of 300 mm inner dia. of 10 mm thick M.S. Pipe. On every meter length of pipes with slotted holes of 960 Nos. slotted holes of size 75 mm X 2.5 mm, is made in 20 rows @ 48 Nos. holes in each row. 40 Nos. 300 mm dia. of required length Strainer will be pushing Including supplying and fixing of Butter fly valve 300 mm dia ISI marked as per IS: 14846 with test certificate of Kriloskar / Upadhaya / Kalpana make with necessary extended spindle, Plummer block, head stock with gear arrangement, spacer with anchor bolt etc. to operate from inspection gallery just after pump platform. A bullet head of cast steel 300 mm dia. is initially to be welded to a 2.50 meter length pipes on its one end and to be placed one by one up to 30 meter long (required length as per designed by the bidder minimum 18.00 meter long).	30 Nos.
02.	INFILTRATION GALLERY :- Construction of 1 Nos. 750 mm dia. and suitable length (required length as per designed by	01 No.

	the bidder minimum 250.00 meter long) Infiltration gallery including surveying, investigation Planning, design, drawing and construction of Civil, Electrical and Mechanical works including supply, carriage of all materials with foundation for the various units of Collector well and provision of following accessories.	
2.01	Execution of an infiltration gallery with supply, fitting, fixing of 750 mm dia. TATA / SAIL make 10 mm thick M.S. (M.S. pipe as per 15:3589 and slot as per 1S:8110) with necessary flange joint and nut, bolt, gasket and two coats of epoxy paint for M.S. Pipe on outer surface. On every meter length of pipes with slotted holes size 75 mm X 2.5 mm in each row.	01 set.
2.02	The gallery pipe top SI should be at least 6 meter below existing river bed level as per enclosed drawing and should be placed after over pumping for development of formation. Open excavation of sand including sand stone, rock; debris etc. as is necessary up to a depth of at least 7.1 m from bed level with excavator, sand pump, grab etc. and grading the bottom of trench to lay the strainer pipe at a slope of 1: 500 (around) towards well under the supervision of divers. Placing the pebble from top of water level along the gallery at under and above strainer as per drawing and direction of E.I.C. under supervision of divers. The slots of the strainer should be cleaned after painting and joining of flange joints should be done by divers. The depth of gallery as mentioned in the drawing is a binding criteria for which necessary investigation has to be done. Localized rock, debris etc under water have to be cleared to complete the gallery as per drawing and direction of E.LC to achieve required yield 5.50 MGD with sand & turbid free water from the gallery to well during the month of end. To achieve the said yield, necessary increase of gallery depth, may be considered during execution without any additional cost.	Required length as per design minimum 250.00 Meter
2.03	Stone boulder sausage work on top of gallery after carrying it up to gallery site as per drawing of boulder size more than	1 item

	200 mm. with 4 mm thick G.I. wire net of 150 x 150 mm opening along with studs.	
2.04	<p>Providing pea gravel as per IS: 8419 1977 for gallery bottom and outer periphery as per IS and free from foreign materials especially iron bearing materials of size to support the sand above gallery. Gravel size should be so as to eliminate sand in gallery water (sieve analysis report and supporting document from authentic book / literature is to be produced).</p> <p>Filtering medium near pipe line - 38 mm broken stone.</p> <p>2nd layer- 38 to 19 mm broken stone.</p> <p>3rd layer - 12 to 6 mm broken stone.</p> <p>4th layer - Course sand passing through a sieve of 3.35 mm size and retained on a sieve 1.70 mm size.</p> <p>5th layer: - Fine sand retained on 70 micron sieve and passing through 1.70 mm sieve.</p>	1 item
2.05	Backfilling of sand on top of gallery from excavated bed material as shown in drawing.	1 item
2.06	Providing coffer dam for diverting the water course if necessary to construct the gallery.	1 item
2.07	Construction of temporary 5 m wide approach road with supply and hand packing stone boulder (two layers boulder of 300 mm thickness) rolling the same including spreading consolidating brick brats 200 mm thick, moorum 75 mm thick, placing necessary hume pipe for under pass flowing water of river to facilitate movement of construction equipment / materials from bank to gallery site if required.	1 item
03.	COLLECTOR WELL FOOTWAY BRIDGE :- Construction of suitable foot way bridge including surveying, planning, design, drawing and construction of civil, electrical and mechanical works with joist and angle frame including supply, carriage of all materials with foundation for the various units of from river bank to collector well providing and installing the following items and calculating the following loads. (Approx length 400.00 meter).	1 item
3.01	Suitable double column 30.00 meter centre to centre with tie-	1 item

	brassier 3.00 meter centre to centre difference for support of foot way bridge.	
3.02	Supplying, Laying and fabricating of 12 mm thick 450 mm dia spiral welded mild steel M.S. Pipe line (TATA / SAIL make) on both sides of foot way bridge including all necessary different types of valves and accessories all complete.	1 item
3.03	Top line for transportation of materials from river bank to collector well. (Approx length 400.00 meter).	1 item
3.04	2 Nos. each side of 400 sq mm 3 / 3.5 core aluminium armoured cable on both side of pipe line by suitable U clamp on the vertical / side frame.	4 Nos. cable
04.	Collector well internal illumination, yard lighting including necessary conceal wiring.	1 item
05.	Vertical Turbine pump – motor discharge 755.00 cum per hour at the head of approx 40.00 meter (actual head will be calculate by the bidder) 2 Nos. working and 2 Nos. Stand by.	4 Nos.
06.	L.T. PDP panel at Collector well end with 2 Nos. Air Circuit Breaker of required rating for receiving the power from L.T. PDB panel at high lift pump house including 4 Nos. soft starters having all the safety of pump-motor for manual operating and remote operating.	1 Set
07.	Digital flow and discharge meter for calculate the discharge in sec, minute, hour, day, month and total discharge of water of Siemens L.& T and other approved make as per direction of E.I.C.	1 Set
0.8	Construction of 1 st floor of building for decorative type officers room cum guest house, upon the preconstruction of ground floor of substation building (constructed by the bidder of GLR 1) by Vitrified tiles flooring, Flush type door, aluminium slider window, wall finished by Plaster of Paris and distemper colouring, Steel railing on cantilever Veranda, toilet finished by decorative type Parry ware make WC comet, wall mixture tap and including conceal electrical wiring with LED tube lights, lamp and required quantity of ceiling fan and exhaust fan in toilet all complete. (covered area and lay out	1 item

plan are shown in the enclosed drawing)	
-----------------------------------------	--

A) 1560.625 M³/HR. CAPACITY COLLECTOR WELL FILTER WATER PUMPING STATION: (22.5 MLD CONSIDERING 16 HRS. RUNNING OF PUMPING A DAY)

i) The Bid includes Survey, investigation, Planning, Design, Supply, Erection, Fabrication, Operation & maintenance of Collector well filter water Pumping Station, Supplying, Laying and fabricating of spiral welded mild steel M.S. Pipe line (TATA / SAIL make) on both sides of foot way bridge 450 mm dia. from Collector well to MS manifold pipe line at the starting point of foot way bridge and Laying of 800 / 700 / 600 mm dia D.I. pipe line from MS manifold pipe line to GLR1 at Chinakuri Pump House (approx length 300 meter) including all necessary different types of valves and accessories all complete up to ground level reservoir of high lift pump house.

ii) The total work includes design, supply, fitting, fixing, commissioning trial run (for three months) and thereafter operation and maintenance of (5) five years for the pumping machinery, motors etc. and allied equipment's including proper engagement of operating personnel. The essential prerequisite of the operation and maintenance work is to maintain uninterrupted water supply from the pumping station to ground level reservoir.

iii) The Bidder has to submit in due course the specific size and capacity of all machineries & equipment offered along with data related to static & dynamic loads in different operating conditions. The size of all the equipment's should be so selected to match with the civil works.

iv) The vibration & noise should be within the acceptable limit as per I.S. or as per existing norms for all equipment's.

v) The dimension and centreline of pedestals for supporting the Pumps as well as the valves should strictly be in line for both Civil & electromechanical works.

vi) The centre-to-centre distance of the pumps, Clearance from wall for pumps should be as per I.S specifications.

vii) The installation of all electrical equipment should be strictly as per I.E. Rules and as per IS specification.

viii) The minimum distance from the pump centre to centre is to be maintained in such a manner so that no vortex formation takes place in the entry of pump i.e. the flow should be maintained streamlined at the entry point of pump. The minimum distance of the pump motor centre line to wall of the pumping station will be maintained in such a fashion that no obstetrical is to be found at the time of maintenance.

ix) The Bidder has to submit parallel operation curves for pumps & the same is to be matched with the system resistance curve of the delivery grid to the Ground Level Reservoir. Pump head selection should be done after surveying of details rising main pipe line by supplying, laying of 2 X 450 mm dia. (400.00 meter long) spiral mild welded 12 mm thick M.S. rising main on both side of footway bridge from Collector well to MS manifold pipe line at the starting point of foot way bridge and Laying of 800 / 700 / 600 mm dia D.I. pipe line from MS manifold pipe line to GLR1 at Chinakuri Pump House (approx length 300 meter) including all necessary valves and specials up to the water ground level reservoir. Family curves for individual and multiple operations at all possible consequences depending upon the variation in % opening of the butter fly valves are to be submitted.

x) The total capacity of the pumping station will be 1560.625 M³/hour at head (supplied by the bidder after surveying the site condition) Meter with operation of two pumps for clear water supply (Running hours of 16 Hrs. / day) would yield to a supply of approx. 24.97 MLD as per present requirement. Two pumps will be kept stand by at any point of time. The pumps & Motors must be of continuous duty and vertical execution type.

The individual pump delivery pipelines should be connected to a common delivery manifold placed inside / outside of the pump house which will be connected with the rising main placing with butterfly valve, a temper proof kinetic air release valve and full bore type flow meter. The delivery pipes lines connected with the common delivery line below the 45 degree.

The suction bell mouth of the vertical turbine pumping unit should be placed in such a manner that no eddy and starvation occurred when pumping operation will put to operation at lowest flood level.

xi) The Bidder has to consider all butterfly valves electrical actuator control, NRV, dismantling joints in individual pump delivery pipe lines as per detail technical specification.

xii) The puddle collars/wall casting needed to be fixed into the wall for entry & exit of delivery pipelines are also to be considered (if required).

xiii) The Bidder must work out the natural frequency analysis for the structural work and the same should be verified with the RPM & critical speed of the rotating equipment's to eliminate any chance of vibration.

(xiv) All the cabling work required to operate the equipment at Collector well pumping station will be drawn from the LT PDB panel of the HT substation near the HT substation. Power cable of all sizes must be 11 KV grade 4 Nos. aluminium armoured 3 / 3.5 core 400 sq mm XLPE / PVC cable for all electrical component.

(B) COLLECTOR WELL PUMPING STATION AND RCC WALK WAY:

i) Designing, drawing and construction of intake RCC walkway with pump house building having good architectural view including machine foundation for pumps and motors will be constructed on the collector well pumping station on the river Damodar as per Bid drawing. The height of the pumping station is to be designed in such a manner that the no obstetrical will be allowed for repair maintenance of the vertical pump motor unit.

One electrically operated crane of 10 MT capacities shall have to be provided to handle pump and motor sets for repairing and maintenance purpose in the pump house. In order to accommodate control panel room equipment / appliances will be housed at a level of pumps floor. The common delivery line with valves unit is to be placed opposite to the entry of the pump house as well as in front of the control panel for easy movement of the operator. The control panel room shall have to be covered by wooden glass frame room.

ii) Designing, drawing and construction of Collector Well RCC bridge is to be made minimum three (3) meter width of RCC walkway with hand railing all along and arrangement for Supplying, Laying and fabricating of spiral welded mild steel M.S. Pipe

line (TATA / SAIL make) on both sides of foot way bridge 450 mm dia. including all necessary different types of valves and accessories all complete up to the ground level reservoir, supply & laying of 4 Nos. (2 Nos. on each side) aluminium armoured cable 400 sq mm 3 / 3.5 core cable and two nos. earthing GI (25 mm X 6 mm) strip, illumination system, aviation lighting arrangement and lightening arrester with separate earthing arrangement.

iii) The design of Collector well has to be made on the basis of the Static load of pump house as prescribed and dynamic loading pattern thereof, taking into account of the vibration both horizontally and vertically that will be generated due to operation of each pump motor set as well as parallel operation of the pumping unit.

iv) The Bidder, whose Bid is accepted in the Course will have to furnish details of the design of the pump house and Collector well in all level duly incorporating the requirement of the pump manufacturer.

(C) COLLECTOR WELL L.T. PANEL AND SOFT STARTER:-

The LT PDB room with APFC panel and room for the operator. The minimum size of the Panel will be as per approved drawing vetted duly by Superintending Engineer, submitted by agency.

(D) Supplying, Laying and fabricating of spiral welded mild steel M.S. Pipe line (TATA / SAIL make) on both sides of foot way bridge 450 mm dia. including all necessary different types of valves and accessories all complete from common manifold of the pumping units to ground level reservoir proposed High lift pump house of length 2 X 450 meter (approx) after supplying and installation all types of sluice valve, non-return valve, pressure release valve and air release valves along with valve chamber construction. Minimum 4 nos. air release valves will have to be provided by the bidder. Digital discharge meter and flow meter will be provided by the agency at the out late of collector well pump house.

E) Retaining cum boundary wall :- Both sides (2 X 30.00 Meter approx) of connecting portion of foot way bridge will be protected by a RCC retaining wall up to FGL and above it 1.8 m masonry boundary wall and over it designer barbed fencing with angle section. No passive pressure should be considered while designing the RCC retaining wall. The whole

area will be filled by good earth up to finished ground Level (FGL) with proper compaction & rolling in layers. A steel gate of width not less than 4.0 m will be provided for entrance. All internal roads will be of 4.0 m RCC (M20 grade) of 150 mm thickness & Minimum 0.12% Reinforcement over compacted and consolidated soil. All roads will be covered by designer paver block of thickness not less than 60 mm.

5.0 LIMIT OF CONTRACT:

The limit of contract starts from construction of collector well with pumping station including arrangement and installation of vertical turbine pumping unit with its electro-mechanical works and clear water delivery line with valves arrangement and interconnected with Supplying, Laying and fabricating of spiral welded mild steel M.S. Pipe line (TATA / SAIL make) on both sides of foot way bridge 450 mm dia. including all necessary different types of valves and accessories all complete which will be bidder's scope up to the ground level reservoir.

The minimum length of the total Collector well bridge with pumping station from the river bank will be as per design and drawings submitted by agency and approved by Superintending Engineer, Western Circle & SWID report whichever will be maximum (approx length 400 meter). A full bore digital discharge meter and flow meter with valve chamber at outlet of the collector well of pumping station will be in the bidder scope. The LT sources of Electric Power would be taken from High Lift LT panel room. Necessary arrangements to connect the cables of appropriate size with full satisfaction of Engineer in Charge are within the limit of this work. The excavation of cables trenches, laying the cables within boundary of intake jetty pumping station units, covering the cable trenches, insert plates, cable trays etc. also includes under this contract.

It is the responsibility of the contractor to make good or reconstruct the part or whole of a structure if gets damaged or demolished/ crushed/ settled down due to water thrust or similar external reasons or faulty design at his own cost. Faulty Design submitted by the contractor even if accepted by the department will not relieve the contractor from above responsibility. Contractor will be considered total responsible for any accident caused due to negligence on his part/poor workmanship/faulty design.

Contractor has liberty to go for design mix for achieving Rich concrete having minimum cement content as stipulated in I.S. code or go for variation if so required at the subject to the satisfaction & permission of E.I.C. The same is also applicable when contractor opt to adopt alternative methodology for facilitating any construction work.

Secretary
Asansol Municipal Corporation

SECTION- B

CONDITIONS & REQUIREMENTS FOR BIDDING

1. Submission of eBid document will not be allowed beyond the schedule time indicated in the eBidding.

2. Each Bidder shall upload his offer in envelopes (statutory and non statutory)& .xls sheet after digitally signed super scribing the name of the work, name & address of the bidder, NIB No and date of submission of the eBid.
3. Each page of the eBid documents, drawing etc. has to be digitally signed / initialled by the authorized signatory.
4. No eBid proposal will be entertained without the earnest money being submitted as indicated in the eNIB. No interest will be allowed for the said earnest money and the Bid issuing authority will hold the same till finalization of the eBid.
5. Any conditional eBid will be liable for rejection.
6. eBids will be opened in presence of the Bidder or their authorized representatives who opt to be present.
7. The Bid inviting Authority reserves the right to reserve or amend the eBid documents prior to the date notified for submission of the eBid or also to extend the time mentioned in the eNIB under intimation to the Bidders.
8. eBid once offered cannot be withdrawn within a period of 120 calendar days from the date set for opening of eBids. Any extension of this validity period if required will be subject to concurrence of the Bidders.
9. Bidders would be at liberty to point out any ambiguities, contradictions, omissions, etc. seeking clarifications thereof or interpretation of any of the conditions of the eBid documents before the Bid Inviting Authority by uploading his/her doubt within a period of seven days from the date of publishing of Bid documents. The bidder shall submit his/her queries in writing at least four working days in advance from the date of pre-bid meeting.
10. Written clarification or amendments etc. as may be issued by the Bid Inviting Authority in pursuance to the representation made by the intending Bidders under Clause 10 above shall be final and binding on the Bidders and shall form a part of the eBid documents. Bid Inviting Authority however, reserves the right to have pre Bid conference with the intending Bidders if deemed necessary.
11. Intending Bidders are required to inspect the site of the Project with particular reference to location and infrastructure facilities. They are to make a careful study

with regard to availability of materials and their sources and all relevant factors as might affect their rates and prices.

12. If expenses incurred for site inspection and all activities in the preparation and uploading of the eBid shall be borne by the Bidders.
13. Extra claim or any concession on the ground of insufficient data or information and absence of knowledge of conditions prevailing at the site or situation arising during the execution of the work shall not be entertained.
14. eBid, which have been considered valid on the result of general examination (Prequalification stage) at the time of opening, shall be subjected to subsequent detail scrutiny. Notwithstanding the general examination carried out earlier, the Bid Inviting authority reserves the right of rejection of any eBid, which may be found to be defective during the detail scrutiny.
15. Bidders before uploading the eBid documents shall have to ensure that “Declaration by the Bidder” in the pro-forma set out in the eBid documents is to be filed separately with the eBid documents in the form of Affidavit to be affirmed by the same person signing the Bid documents.
16. The Bid inviting authority reserves the right to accept or reject any or all of the eBid received or to split up the work in groups or to relax any clause without assigning any reason thereof.
17. This set of Bid documents consists of: a) Main Bid Documents consists of PART I & PART II (Technical) & financial (.xls sheet).

SECTION - C

General Conditions of Contract

1.0 DEFINITIONS AND INTERPRETATION

- (1) In the Contract, as hereinafter defined, the following words and expressions shall have to be meanings hereby assigned to them, except where the context otherwise requires:
- (a) "Approved" means provisionally approved in writing, including subsequent written confirmation of previous verbal approval and "approval" means provisional approval in writing, including as aforesaid. However in spite of approval from Competent Authority contractor is solely responsible for design-cum-execution of the whole project as it is turnkey job.
 - (b) "Authority" means the Secretary or his authorized representatives of Asansol Municipal Corporation.
 - (c) "Bank" means the "State Bank of India" or any other Scheduled Bank.
 - (d) "Calendar day" means a period of twenty four hours extending from midnight to midnight.
 - (e) "Cash" includes cheque, bank drafts and any other payment voucher authorizing payment from any bank or treasury.
 - (f) "Contractor" means the person or persons, firm or Corporation who have entered into the contract for the performance of the work.
 - (g) "Contract price" means the sum as stated in the Bid submitted by the contractor subject to such additions thereto or deductions therefore as may be made under the provisions of; the contract documents and accepted by the Employer.
 - (h) "Constructional Plant" means all appliances or things of whatsoever nature required in or about the execution or maintenance of the works but do not include materials or other things intended to form or forming part of the permanent works.
 - (i) "District" or Asansol Municipal Area means the area described as such in Schedule-I of The Act;

- (j) "Drawings" means the drawings referred to in the Bid documents and any modification of such drawings approved in writing by the Superintending Engineer, Western Circle or his representatives of Municipal Engineering Directorate from time to time or approved in writing by the Secretary, Asansol Municipal Corporation.
- (k) "Employer" means the Asansol Municipal Corporation acting through the Secretary.
- (l) "Engineer in Charge" means the Executive Engineer, Nadia Division of Municipal Engineering Directorate to whom the Secretary, Asansol Municipal Corporation delegate his Authority by the way of declaring him as EIC in the Bid documents.
- (m) "Engineer's Representatives" means any Assistant Engineer or Assistant of the Engineer or any Clerk of works appointed from time to time by the Employer or the Engineer to perform the duties set forth in Clause 2 hereof, whose authority shall be notified in writing to the Contractor by the Engineer-in Charge.
- (n) "Ground Level" means the level of the referred point of the exposed surface of the ground, road or pavement free from extraneous materials;
- (o) "Holidays" means a public holiday for the purpose of Section 25 of the Negotiable Instruments Act, 1881 or such other day on which the office of the Authority remains closed for the day;
- (p) "Local Authority" not only means a Municipal Corporation or Municipality or other authority legally entitled to the control or manage local funds but also includes the West Bengal State Electricity Board.
- (q) "Month" means English calendar month;
- (r) "Permanent Work" means the permanent works including equipment to be supplied, executed, erected and maintained in accordance with the Contract;
- (s) "Road" shall include a street, avenue, lane, by-lane or any other access routes over which a person authorized by a Local Authority has a right of way;
- (t) "Rupees" (or Rs. in abbreviation) shall mean Rupees in Indian Currency.
- (u) "Site" means the land and other placed on, under in or through which the Permanent. Works or Temporary Works are to be executed and any other lands and places provided or arranged by the employer for working space or any other

purpose as may be specifically designated in the Contract as forming part of the Site,

- (v) "Specification" means the specification referred to in the Bid and any modification thereof or addition thereto as may from time to time be furnished or approved in writing by the Secretary, Asansol Municipal Corporation.
- (w) "Store" means such storage areas including depot, go down, stockyard, dumping yard etc. maintained by the Authority) or where supply of any material for the construction or any work has been undertaken by any authorized agent, by such agent within the District.
- (x) "Temporary Works" means all temporary works of every kind required in or about the execution or maintenance of the Permanent Works.
- (y) "Bid Date" means the date fixed for receipt of Bids as per Notice Inviting Bids or as extended by subsequent notification(s).
- (z) "Bidder" means the person, or persons, firm or corporation submitting a Bid for the work contemplated either directly or through a duly authorized representative.
- (aa) "The Act" West Bengal Municipal Act, 1975
- (bb) "Time" expressed by hours of the clock shall be according to the Indian Standard Time.
- (cc) "Water main" means any pipe or conduit of cast iron, DI (Ductile Iron) pipe, steel or of any other material intended to convey or distribute water;
- (dd) "Works" shall include both Permanent Works and Temporary Works.
- (ee) "Work" means all of the work of the project called for or shown in the Bid documents including preparation, construction improvement and cleans up.
- (2) Singular and Plural: Works importing the singular only also include the plural and vice versa where the context demands.
- (3) Headings or Notes: The headings and marginal notes in these Conditions of Contract shall be deemed to be part thereof or be taken into consideration in the interpretation or construction thereof or of the Contract.

- (4) Cost: The work "cost" shall be deemed to include overhead costs whether on or off the Site.

2.0 ENGINEERS IN CHARGE AND HIS REPRESENTATIVES

1) Duties and Powers of Engineer in Charge and his Representative - The Engineer shall carry out such duties in issuing decisions, certificates and orders as are specified in the Contract. Fixation and acceptance of rates for altered or substituted items of work or for additional items of work or their deletion shall however always rest with the same authority (by designation) as had accepted the original Bid.

2) Representative(s) shall be responsible to the EIC and his / their duties are to watch and supervise the Works and to test and examine any materials to be used or workmanship employed in connection with the works. He shall have no authority to relieve the Contractor of any of his duties or obligations under the Contract, not, accept as expressly provided hereunder or elsewhere in the Contract, to order any work involving delay or any extra payment by the Employer, nor to make any variation of or in the Works.

The Secretary may from time to time in writing delegate to the EIC any of the power and authorities vested in the engineer and shall furnish to the Contractor and to the Employer a copy of all such written delegations of Power and authorities. Any Written instructions or approval given by Engineer's representative to the contractor within the terms of such delegation, but not otherwise, shall bind the Contractor as though it had been given by the Secretary, Asansol Municipal Corporation provided always as follows:

- a) Failure of the Engineer's Representative to disapprove any work of materials shall not prejudice the power of the Secretary thereafter to disapprove such work or materials and to order the pulling down, removal of breaking up thereof.
- b) If the Contractor shall be dissatisfied by reason of any decision of the Engineer's Representative he shall be entitled to refer the matter to the Secretary, who shall thereupon confirm, reverse or vary such decision.

ASSIGNMENT AND SUB LETTING

3.0 ASSIGNMENT

The Contractor shall not assign the Contract or any part thereof, or any benefit or interest therein or there under, otherwise than a change in the Contractor's bankers of any money

due or to become due under this contract, without the prior written consent of the Secretary.

4.0 SUBLETTING

The Contractor shall not sublet the whole of the Works. Except where otherwise provided by the Contract, the Contractor shall not sublet any part of the Works without the prior written consent of the Secretary, which shall not be unreasonably withheld and such consent, if given, shall not relieve the Contractor from any liability or obligation under the Contract and he shall be responsible for the acts, defaults and neglects of the said subcontractor including his agents, servants or workmen as fully as if they were the acts, defaults or neglects of the Contractor, his agents, servants or workmen, provided always that the provision of labour on a piece-work basis shall not be deemed to be a subletting under this clause.

5.0 CONTRACT DOCUMENTS

1a) Language: The Contract documents shall be drawn up in the English language. All correspondence, orders, notices etc. shall also be in English.

1b) Law: The law of India and of the State of West Bengal shall apply to the Contract and the Contract is to be construed accordingly.

2) Documents Mutually Explanatory: The several documents forming the contract are to be taken as mutually explanatory of one another but in case of ambiguities or discrepancies the same shall be explained and adjusted by the Secretary, who shall thereafter issue to the Contractor instructions thereon. Provided always that if, in the opinion of the Engineer, compliance with any such instructions shall involve the Contractor in any cost, which by reason of such ambiguity or discrepancy could not reasonably have been foreseen by the Contractor, the Engineer shall certify and the Secretary shall pay such additional sum as may be reasonable to cover such costs.

6.0 DRAWINGS

1) Custody of drawing: All the approved Drawings shall remain in the safe custody of the Executive Engineer, but one copy thereof shall be furnished to the Contractor free of charge. The Contractor shall provide and make at his own expenses any further copies required by him. At the Completion of the Contract, the Contractor shall return to the

Executive Engineer, Asansol Division, and M.E.Dte. All drawings as provided under the Contract.

2) Copy of drawing:- One copy of drawings to be kept on site. One copy of the Drawings furnished by the Contractor as aforesaid, shall be kept by the Contractor on the site and the same shall at all reasonable times be available for inspection and use by the Engineer and his/municipal Representatives and by any other persons authorized by the Engineer in writing.

3) Disruption of progress: The Contractor shall give written notice to Secretary whenever planning or progress of the works is likely to be delayed or disrupted unless any further approval of drawing or order, including a direction instruction or approval is issued by the Secretary on recommendation of Executive Engineer within a reasonable time. The notice shall include details of the drawing or order required, and of why and by whom it is required and of any delay or disruption likely to be suffered if it is further delayed.

7.0 FURTHER DRAWINGS

The Secretary shall have full power and authority to supply to or demand from the Contractor, from time to time, during the progress of the Works, such further drawings as shall be necessary for the purpose of the proper and adequate execution and maintenance of the Works. The Contractor shall carry out and be bound by the same. Adequacy as determined by the Secretary shall be final and binding on the Contractor.

8.0 GENERAL OBLIGATION

(1) Contractor's General Responsibilities - The Contractor shall, subject to the provision of the Contract, and with due care and diligence, execute and maintain the Works and supply all labour, including the supervision thereof, materials, equipment, Constructional Plant and machinery, tools and all other things whether of a temporary or permanent nature, required for such execution and maintenance, so far as necessary for providing the same is specified in or is reasonably to be inferred from the Contract. The Contractor shall take full responsibility for the adequacy, stability and safety of all Site operations and methods of construction, erection etc.

9.0 CONTRACT AGREEMENT

The Contractor shall, when called upon to do so, enter into and execute a Contract Agreement, to be prepared and completed in the form annexed with such modification as may be necessary.

10.1 GUARANTEE

The contractor shall stand guarantee for successful operation of the plant for 12 months from the date of successful commissioning of the pump and shall within the O & M period after 3 months trial run, remove / rectify / make good any such deficiency forthwith at his own cost. During the guarantee period (after the trial run period) the firm's representative shall visit the site once in a month and advise in writing the Secretary about the condition, state of health, and operation & maintenance procedure of the equipment. The successful Bidder shall also give the following guarantee in respect of the equipment supplied by him.

- i) All equipment shall be free from any defects due to faulty design of the components, materials and/or workmanship
- ii) The equipment shall operate satisfactory. The performance and efficiency shall not be less than guaranteed values.
- iii) Formal acceptance of the work or equipment covered under the contract will not be made by the Secretary until all the work done by the contractor has satisfactorily passed all tests required and run for a reasonable period to his satisfaction.

If during testing of work, including equipment prior of formal acceptance, the same or the material thereof must satisfy in respect of meeting the specification guaranteed or otherwise the Contractor shall replace all such equipment etc. in a condition which will meet the guaranteed performance and be up to the specification, in both material and workmanship.

Any such work shall be carried out by the contractor at his own expense, if such work shall, in the opinion of the Engineer-in-Charge, be necessary due to the use of materials or workmanship not in accordance with the contract and/or to the neglect or failure on the part of the contractor to comply with any obligation expressed or implied on the contractor's part under the contract. If the contractor shall fail to do any such work as per aforesaid requirement of the Engineer-in-Charge, the Secretary shall be entitled to have such work carried out by its own workman, or by others hired for the purpose, and if such work is in the opinion of the Engineer-in-Charge for which the contractor should have

carried out at the contractor's own cost, the department shall be entitled to recover from the contractor the supervision cost deemed fit together with the cost increased for the purpose and may deduct the same from any money due to or that may become due to the Contractor.

10.2 PERFORMANCE GUARANTEE

The contractor will have to entered into an agreement through banker to ensure performance guarantee on non-judicial stamps Rs.10/-. Suitable proforma will be supplied in due course of time.

11.0 INSPECTION OF SITE

The Secretary or his authorized person, Asansol Municipal Corporation shall have made available to the Bidder with the Bid documents such data like its location, distance from fixed point including the layout drawing and location of the primary grid point, level drawing data, the source of filling the reservoir and the Bid shall be deemed to have been based on such data. But the Bidder shall be responsible for his own interpretation thereof. The Bidder may also undertake investigations at his own cost on such levels or any other levels prior to submission of his offer.

The Bidder shall also be deemed to have inspected and examined the site and its surroundings and information available in connection therewith and to have satisfied himself, so far as is practicable, before submitting his Bid; as to the form and nature thereof, including the sub-surface conditions, topographical level of proposed site, the hydrological and climatic conditions, the extent and nature of work and materials necessary for the completion of the Works, the means of access to the Site and the accommodation he may require and, in general 'shall be deemed to have obtained all necessary information, subject as above mentioned, as to risks, contingencies and all other circumstances which may influence or affect his Bid.

12.0 SUFFICIENCY OF BID AND ADVERSE PHYSICAL CONDITIONS, ARTIFICIAL OBSTRUCTIONS

The Bidder shall be deemed to have satisfied himself before Biding as to the correctness and sufficiency of his Bid for the Works and 'of the rates and prices quoted in the Schedule of prices, which Bid rates and prices shall, except in so far as it is otherwise

provided in the Contract, cover all his obligations under the Contract and all matters and things necessary for the proper execution and maintenance of the Works.

If, however, during the execution of its Works the Contractor shall encounter physical conditions, other than Climatic conditions on the Site, or artificial obstructions, which conditions or obstructions could, in his opinion, not have been reasonably foreseen by an experienced contractor, the Contractor shall forthwith give written notice thereof to the Engineer and if, in the opinion of the Engineer, such conditions or artificial obstructions could not have been reasonably foreseen by an experienced contractor, then the Engineer shall certify and the Secretary shall pay the additional cost to which the Contractor shall have been put by reason of such conditions, including the proper and reasonable cost.

- a) Of complying with any instruction which the Engineer may issue to the Contractor in connection therewith, and
- b) Of any proper and reasonable measures approved by the Secretary on recommendation of Engineer in charge which the Contractor may take in the absence of specific instructions from the Secretary as a result of such conditions or obstructions encountered.

13.0 WORK TO BE TO THE SATISFACTION OF ENGINEER IN CHARGE

Save in so far as it is not legally or physically impossible, the Contractor shall execute and maintain the Works in strict accordance with the Contract to the satisfaction of the Secretary and shall comply with and adhere strictly to the Secretary's instructions and directions on any matter whether mentioned in the Contract or not touching or concerning the Works.

14.0 WORK PROGRAM

- (1) Program to be furnished: Within thirty (30) calendar days, the Contractor shall, after the acceptance of his Bid, submit to the Secretary for his approval a program showing the order of procedure in which he proposes to carry out the Works. The Contractor shall, whenever required by the Secretary, also provide in writing for his information, general description of the arrangements and methods, which the Contractor proposes to adopt for the execution of the Works.
- (2) If at any time it should appear to the Secretary that the actual progress of the Works does not conform to the approved program referred in sub-clause (1) of this

Clause, the Contractor shall produce, at the request of the Secretary, a revised program showing the modifications to the approved program necessary to ensure completion of the Works within the time for completion as defined in Clause 42 hereof.

(3) The submission to and approval by the Secretary of such program or the furnishing of such particulars shall not relieve the Contractor of any of his duties or responsibilities under the Contract.

15.0 CONTRACTOR'S SUPERINTENDENCE

The Contractor shall give or provide all necessary superintendence during the execution of the Works and as long thereafter as the Secretary may consider necessary for the proper fulfilling of the Contractor's obligations under the Contract. The Contractor or a competent and authorized agent or representative approved of in writing by the Secretary, which approval may at any time be withdrawn, is to be constantly on the Works and shall give his whole time to the Superintendence of the same. If such approval be withdrawn by the Secretary, the Contractor shall, as soon as is practicable, having regard to the requirement of replacing him as hereinafter mentioned after receiving written notice of such withdraw, remove the agent from the works and shall not thereafter employ him again on the Works in any capacity and shall replace him by another agent approved by the Secretary.

Such authorized agent or representative shall receive, on behalf of the Contractor, direction and instruction from the Secretary or, subject to the limitations of Clause 2 hereof the Engineer's Representative. The agent or representative of the Contractor must be able to speak and communicate in English/Bengali. In the absence of the Contractor's designated agent or representative for a particular operation on any site of the works the Contractor's supervisory staff or sub-agent or leading hands shall be instructed to receive and carry out any instruction or direction issued or given by the Secretary or the EIC.

16.0 EMPLOYEES

- (I) Contractor's Employees - The Contractor shall provide and employ on the Site in connection with the execution and maintenance of the Works
 - a) Such technical assistants as are skilled and experienced in their respective calling and such sub-agents, foreman and leading hands as are competent to give proper supervision to the work they are required to supervise, and

- b) Such skilled, semi-skilled and unskilled labour as is necessary for the proper and timely execution and maintenance of the Works.
- c) Employees covered under (a) and (b) may have to be provided with identity cards as specified by the Secretary.
- 2) The Engineer shall be at liberty to object to and require the Contractor to remove forthwith from the Work any person employed by the Contractor in or about the execution or maintenance of the Works who, in the opinion of the Secretary, misconducts himself, or is incompetent or negligent in the proper performance of his duties, or whose employment is otherwise considered by the Secretary to be undesirable and such person shall not be again employed upon the Works without the written permission of the Secretary. Any person so removed from the Works shall be replaced as soon as possible by a competent substitute approved by the Secretary.

17.0 SETTING-OUT

The Contractor shall be responsible for the true and proper setting-out of the Works in relation to original points, lines and levels of reference given by the Engineer in writing and for the correctness, subject as above mentioned, of the position levels, dimensions and alignment of all parts of the Works and for the provision of all necessary instruments, appliances/and labour in connection therewith. If, at any time during the progress of the Works, any error shall appear or arise in the position, levels, dimensions or alignment of any part of the Works, the Contractor, on hem), required to do so by the Engineer or the Engineer's Representative, shall at his own cost, rectify such error to the satisfaction of the Engineer or the Engineer's Representative, unless such error is based on incorrect data supplied in writing by the Engineer, in which case the expense of rectifying the same shall be borne by the Employer. The checking of any setting-out or of any line or level by the Engineer or the Engineer's Representative shall not in any way relieve the Contractor of his responsibility for the correctness thereof and the Contractor shall carefully protect and reserve all bench-marks, sigh trails pegs and other things used in setting out the Works.

18.0 WATCHING AND LIGHTING

The contractor shall in connection with the works provide and maintain at his own cost all lights, guards, fencing, as and when/where necessary or as required by the

Secretary or the Engineer's Representative, for the protection of the works, contractor's employees, employees supervisor or for any other reason deemed fit by the Engineer.

19.0 WORKS & RISKS

(1) Care of Works: From the commencement of the Works until the date stated in the Certificate of Completion for the whole of the Works, pursuant to Clause 47 hereof, the Contractor shall take full responsibility for the care thereof. Provided that if the Secretary shall issue a Certificate of Completion in respect of any part of the Permanent Works, the Contractor shall cease to be liable for the care of that part of the Permanent Works (O & M not counted) from the date stated in the Certificate of Completion in respect of that part and the responsibility for the care of that part shall pass to the Secretary provided further that the Contractor shall take full responsibility for the care of any outstanding work which he shall have undertaken to finish during the period to Maintenance until such outstanding work is completed.

In case any damage, loss or injury shall happen to the Works, or to any part thereof, from any cause whatsoever, save and except the expected risks as defined in sub-clause (2) of this Clause, while the Contractor shall be responsible for the care thereof the Contractor shall, at his Own cost, repair and make good the same, so that at completion the permanent Works shall be in good order and condition and in conformity in every respect with the requirements of the Contract and the Secretary instructions. In the event of any such damage, loss or injury happening from any of the excepted risks, the Contractor shall, if and to the extent required by the Secretary and subject always to the provisions of Clause 62 hereof, repair and make good the same as aforesaid at the cost of the Employer. The Contractor shall also be liable for any damage to the Works occasioned by him in the Course of any operations carried out by him for the purpose of completing any outstanding works or complying with his obligations under Clause 48 or 49 hereof.

(2) Expected Risks: The 'expected risks" are war, hostilities, invasion, act of foreign enemies, rebellion, revolution insurrection or military or usurped power, civil war or unless solely restricted to employees of the Contractor or of his sub-contractors and arising from the conduct of his workers, riot commotion or use or occupation by the Secretary of any part of the Permanent. Works, or a cause solely due to the Engineer's design of the Works, or ionizing radiations or contamination by radio-activity from any nuclear fuel or from any nuclear waste from the combustion of nuclear fuel, radio-active

toxic explosive, or other hazardous properties of any explosive, nuclear assembly or nuclear component thereof, pressure waves cause by aircraft or other aerial devices travelling at sonic or supersonic speeds, or any such operation of the force of nature as an experienced contractor could not foresee, or reasonably make provision for or insure against all of which are herein collectively recurred to as "the expected risks."

20.0 INSURANCE OF WORKS, ETC.

Without limiting his obligations and responsibilities under Clause 19 hereof the Contractor shall insure in the names of the Employer and the Contractor against all loss or damage from whatever cause arising, other than the expected risks, for which he is responsible under the terms of the Contract and in such manner that the Employer and Contractor are covered for the period stipulated in Clause 19(1) hereof and are also covered during the Period of Guarantee for loss or damage arising from a cause, occurring prior to the commencement of the Period of Guarantee, and for any loss or damage occasioned by the Contractor in the course of any operations carried out by him for the purpose of complying with his obligations under Clause 48 or 49 hereof.

a) The Works for the time being executed to the estimated current contract value thereof together with the materials for incorporation in the Works at the replacement value.

b) The Constructional Plant and other things brought on the Site by the Contractor to the replacement value of such Constructional Plant and other things. These shall include materials belonging to the Secretary but issued to or intended to be issued to the Contractor for use in the Works. Such insurance shall be affected with an insurer and in terms approved by the Employer, which approval shall not be unreasonably withheld, and the Contractor shall whenever required, produce to the Secretary or the Engineer's Representative the policy or policies of insurance and the receipts for payment of the current premiums.

21.0 DAMAGES

i) Damage to persons and property: The Contractor shall, except if and so far as the Contract provides otherwise, indemnify the Secretary against all losses and claims in respect of injuries or damage to any person or material or physical damage to any property whatsoever which may arise out of or in consequence of the execution, operation and maintenance of the Works and against all claims, proceedings, damages, costs,

charges and expenses whatsoever in respect of or in relation thereto except any compensation or damages for or with respect to :

- a) The permanent use of occupation of land by the Works or any part thereof.
- b) The right of the Secretary to execute the Works or any part thereof on over under, in or through any land.
- c) Injuries or damage to persons or property which are the unavoidable result of the execution, operation or maintenance- of the Works in accordance with the Contract.
- d) Injuries or damages to persons or property resulting from any act or neglect of the Employer, his agents, servants or other contractors, not being employed by the Contractor, or for or in respect of any claims, proceedings, damages, costs, charges and expenses in respect thereof or in relation thereto or where the injury or damage was contributed to by the Contractor, his servants or agents such part of the compensation as may be just and equitable having regard to the extent of the responsibility of the Secretary, his servant or agents or other contractors for the damage or injury.

2) Indemnity of Secretary: The Contractor shall indemnify the Secretary against all claims, proceedings, damages, costs charges and expenses in respect of the matters referred to the provision to sub-clause (1) of this Clause.

22.0 INSURANCE

1) Third Party Insurance: Before commencing the 'execution of the Works the Contractor, but without limiting his obligations and responsibilities under Clause 21 hereof, shall insure against his liability for any material or physical damage, loss or injury which may occur to any property, including that of the Secretary, or to any person, including any employee of the Secretary, by or arising out to the execution of the Works or in the carrying out of the Contract, otherwise than due to the matters referred to in the proviso to Clause 21 (l) thereof.

2) Minimum Amount of third party insurance - Such insurance shall be affected with an insurer and in terms approved by the Secretary, which approval shall not be unreasonably withheld, and for a least the amount started in the Appendix to the Bid. The Contractor shall, whenever required, produce to the Secretary or the Engineer's Representative the policy or policies or insurance and the receipts for payment of the

current premium. However, the Bidder should insure for an amount commensurate with the risk involved subject to the minimum amount prescribed elsewhere in the Bid.

3) Provision to indemnify Employer - The terms shall include a provision whereby, in the event of any claim in respect of which the Contractor would be entitled to receive It1dcnJmty under the policy being brought or made against the Secretary, the insurer will indemnify the Employer against such claims and any costs, charges and expenses in respect thereof.

23.0 ACCIDENT, INJURIES

1) Accident or injury to Workmen: The Secretary shall not be liable for or in respect of any damages or compensation payable at law in respect or in consequence of any accident or injury to any workman or other person in the employment of the Contractor or any subcontractor, save and except an accident or injury resulting from any act or default of the Secretary, his agents, or servants. The Contractor shall indemnify and keep indemnified the Secretary against all such damages and compensation, save and except as aforesaid, and against all claims, proceedings, costs, charges and expenses whatsoever in respect thereof or in relation thereto.

2) Insurance Against Accident, etc. to workmen: The Contractor shall insure against such liability with an insurer approved by the Secretary, which approval shall not be unreasonably withheld, and shall continue such insurance during the whole of the time that any person is employed by him on the works and shall, when required, produce to the Secretary or the Engineer's Representative such policy of insurance and the receipts for payment of the current premium. Provided always that, in respect of any person employed by any sub-contractor, the Contractor's obligation to insure as aforesaid under this sub-clause shall be satisfied if the sub-contractor shall have insured against the liability in respect of such persons in such manner that the Secretary is indemnified under the policy, but the Contractor shall require such sub-contractor to produce to the Secretary when required, such policy of insurance and the receipt for the payment of the current premium.

3) Notification to insurer: It shall be the duty of the Contractor to notify the insurers under any of the insurance referred to in Clause 20, 22 and 23 hereof any matter or count which by the terms of such insurance are required to be notified and the Contractor shall indemnify and keep indemnified the Secretary against all losses, claims, demands, proceedings, costs, charges and expenses whatsoever arising out of or resulting from any

default by the Contractor in complying with the requirements of this sub-clause whether as a result of the avoidance of such insurance or otherwise.

4) All Insurances at Contractor's cost - The insurances referred to in Clause 21, 22 & 23 hereof shall be entirely at the cost and expenses of the Contractor and be included within his rates.

24.0 REMEDY ON CONTRACTOR'S FAILURE TO INSURE

If the Contractor shall fail to effect and keep in force the insurance referred to in Clause 20, 22 and 23 hereof, or any other insurance which he may be required to effect under the terms of the Contract, then and in any such case the Secretary may effect and keep in force any such insurance and pay such premium or premiums including fines as may be necessary for that purpose and from time to time and deduct double the amount so paid by the employer as aforesaid from any moneys due or which may become due to the Contractor or recover the same as a debt due from the Contractor.

25 I) GIVING OF NOTICES AND PAYMENT OF FEES: The Contractor shall give all notices and pay all fees required to be given or paid by any National or State Statute, ordinance, or other law, or any rules regulation, or bye-law of any local or other duly constituted authority in relation to the execution of the Works and by the rules and regulations of all public bodies and companies whose property or rights are affected or may be affected in any way by the Works.

ii) Compliance with Statutes, Regulations, etc. - The Contractor shall conform in all respects with the provisions of any such Statute, Ordinance or Law as aforesaid and the Rules, regulations or bye-laws or any local or other duly constituted authority which may be applicable to the Works and with such rules and regulations of public bodies and companies as aforesaid and shall keep the Secretary indemnified against all penalties, fines and liability of every kind for breach of any such Statute, ordinance of Law, regulation of bye law.

26.0 FOSSILS, ETC.

All fossils, coins articles of value or antiquity and structures and other remains or things of geological or archaeological interest discovered on the site of the Works shall as between the Employer and the Contractor be deemed to be the absolute property of the Employer.

27.0 PATENT RIGHTS AND ROYALTIES

The Contractor shall save harmless and indemnify the Secretary from and against all claims and proceedings for or on account of infringement of any patent, rights, design Trade mark or name or other protected right in respect of any Constructional Plant, machine works, or material used for or in connection with the Works or any of them and from and against all claims, proceedings, damages, costs, charges and expenses whatsoever in respect thereof in relation thereto. Except where otherwise specified, the Contractor shall pay all tonnage and other royalties, rent and other payments or compensations, if any, for getting stone, sand, gravel, clay or other materials or equipment required for the works or any of them.

28.0 INTERFERENCE WITH TRAFFIC AND ADJOINING PROPERTIES

All operations necessary for the execution of the Works shall, so far as compliance with the requirements of the Contract permits, be carried on so as not to interfere unnecessarily or improperly with the convenience of the existing plant workers, member of the public, or the access to use and occupation of public or private roads, railways and footpaths to or of properties whether in the possession of the Secretary or of any other person or local authority.

29.0 TRAFFIC

1) Extraordinary Traffic: The Contractor shall use every reasonable means to prevent any of the highways, railways or bridges communicating with or on the routes to the Site from being damaged or injured by any traffic of the Contractor or any of this sub-contractors and, shall select routes, choose and use vehicles and restrict and distribute loads so that any such extraordinary traffic as will inevitably arise from the moving of plant and material from and to the Site shall be limited, as far as reasonably possible, and so that no unnecessary damage or injury may be occasioned to such highways, railways and bridges.

2) Special Loads: Should it be found necessary for the Contractor to move one or more loads of Constructional plant, machinery or pre-constructed units or parts of units of work over part of a highway, railway or bridge, the moving whereof is likely to damage any highway, railway or bridge unless special protection or strengthening is carried out, then the Contractor shall before moving the load on to such highway, railway or bridge give notice to the Secretary or Engineer's Representative or the local authority of the weight

and other particulars of' the load to be moved and his proposals for protecting or strengthening the said highway, railway or bridge. The Contractor at his own cost and expenses shall carry out such proposals, including any modifications thereto that the Engineer or the local authority may require.

3) Settlement of Extraordinary Traffic Claims: If during the Carrying out of the Works damage or injury to railways, railway or bridge occurs due to moving of one or more loads of Constructional Plant machinery or pre-constructed units or parts of units of work, the Employer shall conduct the necessary investigation for the purpose of determining the Contractor's liability. If the damage is due to failure on the part of the Contractor to observe and perform his obligations under sub-clause (1) and (2) of this Clause then the restoration / repair of the damaged portion of road or structure certified by the Engineer or local authority to be due to such failure shall be undertaken by or be chargeable against the Contractor.

4) Water-borne Traffic: Where the nature of the Works is such as to require the use by the Contractor of water-borne transport the foregoing provisions of this Clause shall be construed as though "highway" included a lock, dock, sea wall or other structure related to a waterway and "vehicle" included craft, and shall have effect accordingly.

30.0 RESTRICTION

a) Restriction of Movements: The work shall have to be executed within the protected area of existing water works. The existing rules and regulation related to ingress and egress of labour and material shall have to be followed strictly in consultation with and as per direction of the Secretary or the local authority as the case may be. No labour, Supervisor or Engineer of the contractor shall enter inside the treatment plant, pump house or any other existing installations without prior permission of concerned officers Secretary.

b) Opportunities for other contractors:The Contractor shall in accordance with the requirements of the Secretary, afford all reasonable opportunities for carrying out their work to any other contractors employed by the Employer and their workmen and to the workmen of the employer and of any other duly constituted authorities who may be employed in the execution on or near the Site of any work not included in the Contract or of any contract which the Employer may enter into in connection with or ancillary to the Works. If, however, the Contractor shall, on the written request of the Secretary or the

Engineer's Representative, make available to any such other contractor, or to the Employer or any such authority, any roads or ways for the maintenance of which the Contractor is responsible, or permit the use by any such of the Contractor's scaffolding or other plant on the Site, or provide any other service of whatsoever nature, the Employer shall pay to the Contractor in respect of such use or service such sum or sums if at all as shall, in the opinion of the Engineer, be reasonable.

31.0 CONTRACTOR TO KEEP SITE CLEAR

During the progress of the Works the Contractor shall keep the site reasonable free from all necessary obstruction and shall store or dispose of any Constructional Plant and surplus materials and clear away and remove from the Site any wreckage, rubbish or Temporary Works no longer required.

32.0 CLEARANCE OF SITE ON COMPLETION

On the completion of the Works the Contractor shall clear away and remove from the site all Constructional Plant, surplus materials, rubbish and Temporary Works of every kind, and leave the whole of the Site and Works clean and in a workmanlike condition to the satisfaction of the Secretary.

33.0 LABOUR: 1) Engagement of labour: The Contractor shall make his own arrangements for the engagement of all labour, local or otherwise, and save in so far as the Contract otherwise provides, for the transport, housing, feeding and payment thereof.

2) Supply of water: The Contractor shall, so far as is reasonably practicable having regard to local conditions, provide on the Site, to the satisfaction of the Secretary representative, an adequate supply of drinking and other water for the use of the Contractor's staff and work people.

3) Alcoholic Liquor or Drugs: The Contractor or his workmen shall not consume or sale or gift or be under the influence of any drug/narcotics or Alcoholic liquor within the vicinity of the Construction site.

4) Arms and Ammunition: The Contractor shall not give, barter or otherwise dispose of to any person or persons, any arms or ammunition of any kind or permit or suffer the same as aforesaid.

5) Festivals and Religious Customs: The Contractor shall in all dealing with labour in his employment have due regard to all recognized festivals days of rest and religious or other customs.

6) Epidemic: In the event of any outbreak of illness of an epidemic nature, the Contractor shall comply with and carry out such regulations, orders and requirements as may be made by the Government, or the local medical or sanitary authorities for the purpose of dealing with and overcoming the same.

7) Disorderly Conduct etc.: The contractor shall at all times take all reasonable precautions to prevent any unlawful, riotous or disorderly conduct by or amongst his employees or workers and for the preservation of peace and protection of persons and property in the neighbourhood of the Works against the same.

8) Compliance with Laws, regulation etc. relating to labour: In respect of the engagement, employment, transport, payment, feeding, housing and working conditions of labour and all matters connected there with the Contractor shall at all times during the continuance of the Contract, comply in all respects with and carry out all obligations imposed on him by the provisions and requirements of the following statutes.

a) The Apprentices Act 1961 (Act 52 of 1961) and Rules and Regulations issued there under from time to time.

b) The Contract Labour Regulation and abolition Act 1970 (Act 37 of 1970) and Rules made there under (West Bengal Contract Labour Regulation and Abolition Rules 1972) from time to time.

c) The Payment of Wages Act 1936, the Minimum Wages Act 1948, the Employees Liability Act 1938, the Industrial Disputes Act 1947, the Maternity Benefits Act 1961, the Employees State Insurance Act 1948 including modifications thereto the Rules and Regulations framed there under from time to time.

d) Other existing National or State Statute, Ordinance or other Law or any Regulation or Bye-law of any local or other duly constituted authority which may be applicable, including any such Law, Regulation or Order that may be passed or ordered from time to time and come into force during the tenure of the Contract.

9) Employees Provident Fund: The Contractor shall comply with the provisions of the relevant Employees Provident Fund Act or Rules in force in the State along with the provisions of all rules and Regulations made there under from time to time, and shall in particular be responsible for the payment of all contributions as laid down under the Act/Rules.

10) Trade union rights: The Contractor shall recognize the freedom of all workmen employed by him in and for performance of the Contract to be members of registered Trade Unions and shall not in any manner prevent or discourage any such workman from becoming a member of a registered Trade Union or discriminate against any workmen who is a member of a registered Trade Union.

11) Local Labour: As far as possible local labour shall be engaged as unskilled labour.

12) Fair Wages - The Contractor shall in respect of all workmen employed by him in and for the performance of the Contract pay rates of wages and observe the conditions of employment not less favourable than those provided under the relevant labour law as applicable to the State.

13) Medical Attendance: The Contractor shall provide, to the satisfaction of the Government or Local Authorities Concerned, adequate medical attendance for his employees and labour.

14) Report or Accident: The Contractor shall, within twenty four (24) hours of the occurrence of any accident at or about the site or in connection with the execution of the Work, report such an accident to the Engineer. The Contractor shall also report such accident to the competent authority whenever law requires such a report.

15) Report ~~REQUIRED BY LABOUR~~ Commissioner: The Contractor shall submit, at the request of the Labour Commissioner or of the Assistant Commissioner of the State such returns as may be called for from time to time in respect of labour employed by the Contractor and by his subcontractors in the execution of the Contract. If so required, the Contractor shall furnish the names and address of all subcontractors to the Labour Commissioner. Statutory provisions in these regards are to be also complied with.

16) The Contractor shall be responsible for observance by his subcontractor of all the foregoing provision of sub-clause (1) to (15) of this Clause 33.

34.0 RETURNS OF LABOR ETC.

The Contractor shall, if required by the Secretary, deliver to the Secretary, or at his office a return in detail in such form and at such intervals as the Secretary may prescribe showing the supervisory staff and the number of the several classes of labour from time to time employed by the Contractor on the Site and such information respecting Constructional Plant as the Secretary his Representative may require.

35.0 MATERIALS AND WORKMANSHIP

1) All materials and workmanship shall be of the respective kinds described in the Contract and in accordance with the Engineer's instructions and shall be subjected from time to time to such tests as the Engineer may direct at the place of manufacture or fabrication, or on the Site or at such other place or places as may be specified in the Contract, or at all or any of such places. The Contractor shall provide such assistance, instruments, machines, labour and materials as are normally required for examining, measuring and testing any work and the quality, weight or quantity of any material used and shall supply samples or materials before incorporation in the Works for testing as may be selected and required by the Secretary, be it at site or at the manufacturer/Vendors premises or elsewhere.

2) COST OF SAMPLES: The Contractor at the cost and expense of him shall furnish all samples of materials as may be required by the Secretary.

3) COST OF TESTS: The cost of making any test shall be borne by the Contractor if such test is clearly intended by or provided for in the Contract and in the cases only of a test under load or of a test to ascertain whether the design of any furnished or partially finished work in appropriate for the purpose which it was intended to fulfill, is particularized in the Contract in sufficient detail to enable the Contractor to price or allow for the same in his Bid.

4) COST OF TESTS NOT PROVIDED FOR, ETC.: If the Secretary orders any test, which is either;

a) Not so intended by or provided for, or

b) (In the cases above mentioned) is not so particularized, or

c) Though so intended or provided for is ordered by the Engineer to be carried out by an independent person or organization at any place other than the Site or the place of manufacture or fabrication of the materials tested, then the cost of such test shall be borne by the Contractor, if the tests shows the workmanship or materials not to be in accordance with the provisions of the Contract or the Engineer's instruction.

36.0 INSPECTION OF OPERATIONS

The Engineer and any person authorized by him shall at all times have access to the Works and to all workshops stores and places where work is being prepared or from where material manufactured articles or machinery are being obtained for the Works and the Contractor shall afford every facility for and every assistance in or in obtaining the right to such access.

37.0 EXAMINATION

1) Examination of work before covering up: No work shall be covered up or put out or view without the approval of the Engineer or the Engineer's Representative and the Contractor shall afford full opportunity for the Secretary or the Engineer's Representative to examine and measure any work which is about to be covered up or put out of view and to examine foundations before permanent work is placed thereon. The Contractor shall give due notice to the Engineer's Representative where any such work or foundations is or are ready or about to be ready for examinations and the Engineer's Representative shall, without unreasonable delay, unless he considers if unnecessary and advises the Contractor accordingly attend for the purpose of examining and measuring such work or of examine such foundations

2) Uncovering and making openings: The Contractor shall uncover any part or parts of the Works or make opening in or through the same as the Engineer may from time to time direct and shall reinstate and make good such part or parts to the satisfaction of the Engineer If any such part or parts have been recovered up or put out of view after compliance with the requirement of sub-clause (I) of this Clause and are found to be executed in accordance with the Contract, the expenses of uncovering, making openings in or through, reinstating and making good the same shall be, borne by the Employer, but in any other case all costs shall be borne by the Contractor.

38.0 REMOVAL

1) Removal of improper work and materials: The Secretary shall during the progress of the works have power to order in writing from time to time.

a) The removal from the Site, within such time or time as may be specified in the order, of any materials, which in the opinion of the Engineer, are not in accordance with the Contract.

b) The substitution of improper, substandard and unsuitable materials, and

c) The removal and proper re-execution, notwithstanding any previous test thereof or interim payment therefore, of any work which in respect of materials or workmanship is not in the opinion of the Engineer, in accordance with the Contract.

2) Default of Contractor in Compliance: In case of default on the part of the Contractor in carrying out such order, the Employer shall be entitled to employ and pay other persons to carry out the same and all expenses consequent thereon or incidental thereto shall be recoverable from the Contractor by the Employer, or may be deducted by the Employer from any sum due or' which may become due to the Contractor.

39.0 SUSPENSION

1) Suspension of work: The Contractor shall, on the written order of the Engineer, suspend the progress of the works or any part thereof for such time or times and in such manner as the Engineer may consider necessary and shall during such suspension properly protect and secure the work, so far as is necessary in the opinion of the Engineer. The extra cost incurred by the Contractor in giving effect to the Engineer's instruction under this Clause shall be borne and paid by the Employer unless such suspension is

a) Otherwise provided for in the Contract, or

b) Necessary by reason of some default on the part of the Contractor, or

c) Necessary by reason of climatic conditions on the Site, or

d) Necessary for the proper execution of the work or for the safety of workmen or Works of any part thereof in so far as such necessity does not arise from any act or default by the Engineer or the Employer or from any of the expected risks defined in Clause 19 hereof provided that the Contractor shall not be entitled to recover any such extra cost unless he gives written notice of his intention to claim to the Employer within twenty-eight days of the

Engineer's order. The Secretary shall settle and determine such extra payment and/or extension of time under Clause 43 hereof to be made to the Contractor in respect of such claim as shall in the opinion of the Employer be fair and reasonable.

2) Suspension lasting more than 90 days: If the progress of the Works or any part thereof is suspended on the written order of the Secretary and if permission to resume Work is not given by the Secretary within a period of ninety days from the date of suspension then, unless such suspension is within paragraph (a), (b), (c) or (d) of sub-clause (1) of this Clause, the Contractor may serve a written notice on the Employer requiring permission within twenty eight days from the receipt thereof to proceed with the Works, or that part thereof in regard in which progress is suspended and, if such permission is not granted within that time, the Contractor by a further written notice so served may, but is not bound to, elect or treat the suspension where it affects part only of the Works as an omission of such part under Clause 50 hereof, or where it affects the whole Works, as an abandonment of the Contract by the Employer.

40.0 COMMENCEMENT TIME AND DELAYS

Commencement of works: The Contractor shall commence the Works on Site within the period named in the Appendix to the Bid after the receipt by him of a written order to this effect from the Engineer and shall proceed with the same with due expedition and without delay, except as may be expressly sanctioned or ordered by the Engineer, or be wholly beyond the Contractors' Control.

The successful contractor shall within four weeks from the date of issue of Letter of Intent furnish one or more drawing stating and showing the following:

- 1.0 Dimensioned area requirement of the pumping station
 - 1.1 Cut-outs at the operating platform.
 - 1.2 Layout of motors, pumps, valves and other electrical units like MCC, Capacitors etc.
- 2.0 Centre line of VT Pumping units
 - 2.1 Foundation level of pumps & valves
 - 2.2 Centreline and sizes of pump delivery pipes, bends etc.
 - 2.3 Top of the Pump casing

- 2.4 Electrically operated 10.0 M.T. Crane rail.
- 3.0 Forces and Moments developed at different locations.
- 3.1 Static and Dynamic loads of pumps, motors, valves, etc. (showing dead loads separately) & load of various electrical equipments and machinery.
- 3.2 Moments and stresses developed at different locations.
- 3.3 Vibrations at different locations expected.
- 4.0 Foundation details showing bolt sizes and extent of embedding of the foundation bolts.
- 5.0 RSJ sizes, locations and fixing arrangements for motor support, RSJ/girder requirement for fixing HOT crane as clamp-on chain pulley blocks for attending of valves etc. at the pump floor level stating the maximum load that is required to be lifted.
- 6.0 Layout of cable trenches, cable trays showing the locations and levels together without position of hooks at the underside of the operating platform stating the maximum load required to be withstood.
- 7.0 Any other data that the Bid considers relevant for construction of civil structure.
- 8. Any other reasonable data that may be asked for.

41.0 POSSESSION

1) Possession of site: Save in so far as the contract may prescribe, the extent of portions of the Site of which the Contractor is to be given possession from time to time and the order in which such portions shall be made available to him and subject to any requirement in the Contract as to the order in which the Works shall be executed, the Employer will, with the Engineer's written order to commence the Works, give to the Contractor possession of so much of the Site as may be required to enable the Contractor to commence and proceed with the execution of the Works in accordance with the Programmed referred to in Clause 14 hereof, if any, and otherwise in accordance with such reasonable proposals, of the Contractor as he shall, by written notice to the Engineer, make and will, from time to time as the Works proceed, give to the Contractor possession of such further portions of the Site as may be required to enable the

Contractor to proceed with the execution of the Works with due dispatch in accordance with the said Programmed or proposals, as the case may be.

If the Contractor suffers delays or incurs cost for failure on the part of the Employer to give possession in accordance with the terms of this Clause, the Employer shall grant an extension of time for the completion of the Works and certify such sum as, in his opinion, shall be fair to cover the cost incurred, which sum shall be paid by the Employer.

42.0 TIME :-

1) Time of Completion and progress of Works: The progress of the work shall conform to the approved Work Programmed in terms of Clauses 14 hereof, and subject to any requirement in the contract as the completion of any section of the Works before completion of the whole, the whole of the Works shall be completed, in accordance with the provisions of Clause 47 hereof, within the time stated in the Contract calculated from last days of the period named in the Appendix to the Bid as that within which the Works are to be commenced, or such extended time as may be allowed under Clause 43 hereof.

2) Failure in keeping to stages of work Programmed: If the Contractor does not keep to the approved program and continues at any stage to fall behind his schedule by as much as twenty percent (20%) of the said approved work programmed, within thirty (30) days from receipt by him of a written notice from the Engineer, or if in the opinion of the Engineer the delay will substantially affect operation activities or execution of a major work item and it is ascertained by the Engineer that the Contractor cannot remedy the occasion within the stipulated time, the Secretary on recommendation of Engineer shall have full authority to undertake measures to recover from such adverse condition in terms of the provisions of Clause 62 thereof.

43.0 EXTENSION OF TIME FOR COMPLETION

Should the amount of extra or additional work of any kind or any cause of delay referred to in these Conditions, or other special circumstances of any kind whatsoever which may occur, other than through a default of the Contractor, be such as fairly to entitle the Contractor to an extension of time for the completion of the works, the Secretary on recommendation of Engineer shall determine the period of such extension and shall notify the Employer and the Contractor accordingly. Provided that the Engineer is not bound to take into account any extra or additional work or other special circumstances unless the

Contractor has within twenty-eight days after such work has been commenced, or such circumstances have arisen or as soon as is practicable, submitted to the Engineer full and detailed particulars of any extension of time to which he may consider himself entitled in order that such submission may be investigated at the time.

44.0 NO NIGHT OR SUNDAY WORK

Subject to any provision to the contrary contained in the Contract, none of the Permanent Works shall, save as hereinafter provided, be carried on during the night or on Sundays, if locally recognized as days of rest, or other locally recognized equivalent without the permission in writing of the Engineer, except when the works is unavoidable or absolutely necessary for the saving of life or property or for the safety of the Works, in which case the Contractor shall immediately advise the Engineer, provided always that the provisions of the Clause shall not be applicable in the case of any work which it is customary to carry out by rotary of shifts.

45.0 RATE OF PROGRESS AND NIGHT WORK WHEN PERMITTED

If for any reason, which does not entitle the Contractor to an extension of time, the rate of progress of the Works or any section is at any time, in the opinion of the Engineer, too slow to ensure completion by the prescribed time or extended time for completion, the Secretary on recommendation of the Engineer shall so notify the Contractor in writing and the Contractor shall thereupon take such steps as are necessary and the Engineer may approve to expedite progress as to complete the Works or such section by the prescribed time or extended time. The Contractor shall not be entitled to any additional payment for taking such steps. If as a result of any notice given by the Secretary under this Clause, the Contractor shall seek the Secretary permission to do any work at night or on Sundays, If locally recognized as days of rest, or their locally recognized equivalent, such permission shall not be unreasonable refused. When work at night has to be carried out, the Contractor shall, at his own cost and expense, make adequate arrangements for lighting and provide necessary facilities for safety etc. and comply with all stipulations as may have been imposed by the Secretary in granting permission for night work.

46.0 DAMAGES FOR DELAY

1) Liquidated Damages for Delay: If the Contractor shall fail to achieve completion of the Works within the time prescribed by Clause 42 hereof, then the Contractor shall pay to the Employer the sum stated in the Contract as liquidated damages for such default and

not as a penalty for every day of part of a day which shall elapse between the time prescribed by Clause 42 hereof and the date of certified completion of the Works, the Employer may without prejudice to any other method of recovery, deduct the amount of such damages from any money in his hands, due or which may become due to the Contractor. The payment or deduction of such damages shall not relieve the Contractor from his obligation to complete the Works, or from any other of his obligations and liabilities under the Contract.

2) Reduction of liquidated Damages: If, before the completion of the whole of the Works any part or section of the Works has been certified by the Engineer as completed, pursuant to Clause 47 hereof, and occupied or used by the Employer, the liquidated damages for delay shall, for any period of delay after such certificate and in the absence of alternative provision in the contract be reduced in the proportion which the value of the part or section so certified bears to the value of the whole of the Works.

3) Extent of Liquidated Damages: The liquidated damages referred to in sub-clause (1) for delay of each day or part thereof, shall be at the rate of one percent (1 %) or such smaller amount as the Employer may decide, or the total value of the Contract Price excluding the value of such part or section of the works as may have been covered by certificate of completion in terms of the provisions of sub-clause (2) above, Provided however that in no case shall the total amount of liquidated damages exceed ten percent (10%) of the total Contract Price for whole Works.

4) Liquidated Damage as Reasonable Compensation: The 'Liquidated damage' referred to in sub-clause (1) to (3) above, shall be considered as reasonable compensation to be applied to the use of the Employer without reference to the actual loss or damage sustained and whether or not any damage shall have been sustained.

5) No bonus for early completion: The Contractor shall not be entitled to payment of any bonus for early completion of the Works.

47.0 CERTIFICATION OF COMPLETION OF WORK

1) Erection: Erection of Mechanical and electrical equipment shall be construed to have been completed where equipment in question is placed in position undergoes all necessary tests such as those for alignment, verticality, leak proof mess, insulation etc. as may be specified elsewhere in the Bid documents and put to operation.

2) Completion: Completion is a stage when the equipment and the structure as a whole is certified by the Employer. The date shall only be indicative for the purpose of reckoning the period of Maintenance Period and shall not be co-related with the release of any payment provided that non-continuous or sporadic functioning shall not be deemed as commissioning and also provided that non-commissioning of minor works, the decision on determination of major or minor works resting with the employer, shall not multiply the act of completion for the aforesaid purpose.

An item shall be considered as minor work where its non-completion may not in the opinion of the employer, stand in the way of commencement of plant operation.

3) Trial Run: The Trial Run period shall be for three months including 72 hours with load operation of 8 hours at a stretch operation of all equipments as per specification and to the satisfaction of Engineer-in-Charge.

48.0 MAINTENANCE

1) Maintenance Period: Maintenance period shall be for a period of one year counted from the date of certified commissioning i.e. after successful trial runs of 3 months. The Contractor shall provide spare parts at his cost required during the maintenance period.

2) Cost of Execution of work of repair, etc.: The repair work shall be carried out by the Contractor at his own expense if the necessity thereof shall, in the opinion of the Engineer, be due to the use of materials or workmanship not in accordance with the Contract, or to neglect or failure on the part of the Contractor to comply with any obligation, expressed or implied, on the Contractor's part under the Contract. If, in the opinion of the Engineer, such necessity shall be due to any other cause, the value of such work shall be ascertained and paid for as if it was an additional work.

3) Remedy on contractor's failure to carry out work required: If the Contractor shall fail to do any such work as aforesaid requirement by the Engineer, the Employer shall be entitled to employ and pay other persons to carry out the same, which in the opinion of the Employer, the Contractor was liable to do at his own expense under the Contract. In the said event, all expenses consequent thereon or incidental thereto shall be recoverable from the Contractor by the Employer, or may be deducted by the Employer from any sum due or which may become due to the Contractor.

49.0 CONTRACTOR TO SEARCH

The Contractor shall, if required by the Secretary in writing, search under the directions of the Engineer, for the cause of any defect, imperfection or fault appearing during the progress of the Works or in the period of Maintenance. Unless such defect, imperfection or fault shall be one for which the contractor is liable under the contract, the cost of the work carried out by the contractor in searching as aforesaid shall be borne by the Employer. If such defect, imperfection or fault shall be one for which the contractor is liable as aforesaid, the cost of the work carried out in searching as aforesaid shall be borne by the contractor and he shall in such case repair, rectify and make good such defect, imperfection or fault at his Own expense in accordance with the provisions of Clause 48 hereof to the satisfaction of the Engineer.

50.0 ALTERATIONS, ADDITIONS AND OMISSIONS

1) Variations: The Employer may make any variation of the form, quality or quantity of the Works or any part thereof that may, in his opinion, be necessary and for that purpose, or if for any other reason it shall, in his opinion, be desirable, he shall have power to order the Contractor to do and the Contractor shall do any of the following:

- a) Increase or decrease the quantity of any work included in the contract.
- b) Omit any such work.
- c) Change the character or quality or kind of any such work.
- d) Change the levels, lines position and dimensions of any part of the Works and
- e) Execute additional work of any kind necessary for the satisfactory completion of the works or for deriving satisfaction of the Employer. It is expressly provided that no such variation shall, in any way vitiate or invalidate the Contract, but the value, if any, of all such variations shall be taken into account in ascertaining the amount of the Contract Price.

2) Orders for variations to be in writing: The Contractor shall make no such variations without an order in writing from the Employer. Provided that no order in writing shall be required for insignificant increase or decrease in the quantity of any work where such increase or decrease is not the result of an order given under this Clause, but is the result of the quantities exceeding or being less than those stated in the Schedule of prices. Provided also that if for any reason the Employer shall consider it desirable to give

any such order verbally, the Contractor shall comply with such order and any confirmation in writing of such verbal order given by the Employer whether before or after the carrying out of the order, shall be deemed to be an order in writing within the meaning of this Clause. Provided further that in the event of non-receipt of written confirmation from the Employer, the Contractor shall, within eleven working days, confirm the same from his end in writing to the Employer, and If such confirmation is not contradicted in writing within fourteen working days by the employer, it shall be deemed to be an order in writing by the Employer.

51.0 VALUATION

1) Valuation of variations: All extra or additional work done or work omitted or substituted by order of the Employer shall be valued at the rates and prices set out in the Contract if, in the opinion of the Employer, the same shall be applicable as it is or with addition to or subtraction from an accepted item, if the Contract does not contain any rates or prices applicable to the extra or additional work, then the rates or prices shall be obtained from the Central Circle, Public Works Department schedule of rates as was in vogue on the date of submission of the Bid. The same is being escalated to an extent determined by comparing the cost of a similar item appearing in the Schedule of Prices with those in PWD schedule. Where such rates are not available in P.W.D. schedule of rates, the market-analysed rate as approved by the Employer shall be final and binding. In case of such analysed rates, 10% profit including overhead consultant's fees, ST. Turnover Tax etc. shall be allowed. No other overhead, or other expenses shall be taken into account shall be considered to be inclusive of contractors profit.

2) Variation Exceeding 20 Percent: - If, on certified completion of the whole of the Works, it shall be found that a reduction or increase greater than twenty percent (20%) of the sum named in the Letter of Acceptance, excluding all fixed sums, provisional sums if any, results from

- a) The aggregate effect of all Variation Orders, and
- b) All adjustments upon measurement of the estimated quantities set out in the Schedule of Prices excluding all provisional sums, and adjustments of price made under Clause 66 (1) hereof but not from any other clause, of the Contract Price shall be adjusted by such sum as may be agreed between the Contractor and the Employer or, failing agreement,

fixed by the Employer having regard to all material and relevant factors, including the Contractor's site and general overhead costs.

c) Claims: The Contractor shall send to the Secretary once in every month an account giving particulars, as full and detailed as possible, of all claims for any additional payment to which the Contractor may consider himself entitled and of all extra or additional work ordered by the Employer which he has executed during the preceding month. No final or interim claim for payment for any such work or expense will be considered which has not been included in such particulars. Provided always that the Employer shall at his discretion be entitled to authorize payment to be made for any such working expense, notwithstanding the Contractor's failure to comply with this condition, that the Contractor has, at the earlier practicable opportunity, notified the Employer in writing that he intends to make a claim for such work, provided always that a release of payment shall be preceded by the claim and valuation of variation, in that order.

52.0 PLANT TEMPORARY WORKS AND MATERIALS

1) Plant, etc. exclusive use for the works: All Constructional Plant, Temporary Works and materials provided by the Contractor shall, when brought to the Site be deemed to be exclusively intended for the execution of the Works and the Contractor shall not remove the same or any part thereof, except for the purpose of moving it from one part of the Site to another, without the consent, in writing, of the Engineer which shall not be unreasonably withheld.

2) Removal of plant, etc.: Upon completion of the Works the Contractor shall remove from the Site all the said Constructional Plant and Temporary Works remaining thereon and any unused material provided by the Contractor to the satisfaction in the Engineer.

3) Employer not liable for damage to plant, etc.: The employer shall not at any time be liable for the loss of or damage to any of or damage to any of the said Constructional Plant, Temporary Works or materials same as mentioned in Clause 19 and 62 hereof.

4) Octroi, Sales tax, VAT, Cess and other imposts. The Contractor shall pay Octroi, Sales Tax, VAT, Cess, Work Contract Tax and all other taxes, duties and charges as may be applicable from time to time in respect of materials purchased by him

or plants and equipment brought to Site. No separate payment shall be made for all these and they shall be deemed to have been covered within the Contractor's rates for the finished items of work.

5) Temporary Works: At least fourteen (14) days in advance of taking up any temporary works, the contractor shall submit to the Engineer for approval complete drawings of all temporary works he may require for the execution of the Works. He shall, so required by the Engineer, submit his calculations relating to the strength of the temporary works proposed. Modifications that the Engineer may require shall be made by the Contractor at the latter's cost and expenses. At the discretion of the Engineer, a higher stress up-to a maximum of twenty five percent (25%) in excess of the stress normally allowed for permanent structures may be permitted in the design of temporary works.

Notwithstanding the approval by the Engineer of any of the temporary works, the contractor shall remain wholly responsible for their adequacy, safety, proper maintenance and of all obligations in regard to such works specified or implied in the Contract, until the removal of such works.

53.0 APPROVAL OF MATERIAL, ETC. NOT IMPLIED

The operation of Clause 52 hereof shall not be deemed to imply any approval by the Engineer of the materials or other matters referred to therein shall not interfere with rejection of any such materials at any time by the Engineer.

54.0 MEASUREMENT

For measurement, the metric system should be used.

55.0 WORKS TO BE MEASURED

The engineer shall, except as otherwise stated, ascertain and determine by measurement the value in terms of the Contract of work done in accordance with the Contract. He shall, when he requires any part or parts of the works to be measured, give notice to the Contractor's authorized agent or representative, who shall forthwith attend or send a qualified agent to assist the Engineer or the Engineer's Representative in making such measurement, and shall furnish all particulars required by either of them. Should the Contractor not attend, or neglect or omit to send his agent on two consecutive occasions, then in the third occasion the measurement shall be made unilaterally by the Engineer, which shall be taken to be the correct measurement of the work. For the purpose of

measurement such permanent work as is to be measured by records and drawings at suitable intervals of such work and the Contractor, as and when called upon to do so in writing shall, within fourteen days, attend to examine and agree upon such records and drawings, with the Engineer or Engineer's Representative and shall sign the same when so agreed. If the Contractor does not so attend to examine and agree upon such records and drawings on two consecutive occasions they shall be taken to be correct. If, after examination of such records and drawings, the Contractor does not agree with the same or does not sign the same as agreed, they shall nevertheless be taken to be correct, unless the Contractor shall, within fourteen days of such examination, lodge with the for decision by the Engineer, a notice in writing giving details of the respects in which such records and drawings are claimed by him to be incorrect together with reasons thereof.

56.0 METHOD OF MEASUREMENT

The Works shall be measured but, notwithstanding any general or local custom, except where otherwise specifically described or prescribed in the Contract.

57.0 PAYMENT

Sl. No.	TERMS OF PAYMENT : ITEM WISE BREAK UP	
1	<u>Collector Well pile Foundation:-</u> Planning, designing and construction of Pile foundation of Collector well and foot way bridge column, 22.5 cum pumping station in the River Damodar considering bid documents as per approval from competent authority and direction of EIC.	
	<i>Break up :</i>	
A.	Completion of pile foundation	50%
B.	Completion of bracing, extension of pile as column etc. and any other work required to complete the item in all respect.	30%
C.	After successful trial run of the plant.	20%
	Total =	100%
2	<u>Collector Well super Structure:-</u> Planning design and construction of supper structure of Collector well and foot way bridge cum pumping station including concrete wall, beam, pump house floor slab , roof slab including masonry works, painting, plastering, finishing , rolling shutter gate, fixing of door and window, roof treatment and arrangement for electrically operated	

	10.0 MT capacity electrically operated crane etc. in all respect considering bid documents as per approval from competent authority and direction of EIC.	
A	All structural works from floor level	60%
B	All other works including Masonry works, Painting, plastering, finishing, rolling shutter gate, fixing of door and window, Roof treatment and arrangement for electrically operated 5.0 MT gantry girders.	30%
C	After successful trial run of the plant.	10%
	Total =	100%
3	<u>Foot way Bridge:-</u> Planning design and construction of 3.0 m walk way above piles cap supported on pier including plastering, finishing, fixing of hand railings , supply and laying 600 mm dia. spiral welded mild steel MS Pipe 12 mm thick on both side, arrangement of cable tray etc. in all respect considering bid documents as per approval from competent authority and direction of EIC	
	<i>Break up :</i>	
A	All works completed in all respect.	90 %
B	After successful trial run of the plant.	10%
	Total =	100 %
4	<u>Vertical turbine Pump-Motor:-</u> Supply delivery installation of vertical turbine pumping units with its motor, column pipes, inside collector well L.T. cable, L. T Panel, soft Starter and column pipes with its all other allied job such as Common delivery main , Non Return Valve, actuator control butterfly valves, full bored type flow meter, etc. complete in all respect considering bid documents as per approval from competent authority and direction of EIC.	
A	Supply of Pump & Motors.	40%
B	Supply of all other materials.	20%
C	Installation of all materials.	30%
D	After successful trial run of the plant.	10%
	Total =	100%
5	<u>MCC Earthing arrangement :-</u> Supply delivery installation of MCC with its caballing and earthing arrangement of the pumping station (No welding allowed in earthing strip) complete in all respect considering bid documents	

	as per approval from competent authority and direction of EIC	
	Break up :	
A	Supply of all Electro-Mechanical equipments required to complete the item.	50%
B	Installation, fitting & fixing complete of all Electro-mechanical equipments and any other work required completing the item in all respect.	40%
C	After successful trial run of the plant.	10%
	Total =	100%
6.	<u>Transformer LT PDB Panel:-</u> Supply, delivery, installation, testing & commissioning of 11/0.433 KV, 315 KVA, No Loss Transformer Air Circuit Breaker, LT PDB Panel with copper Bus-Bar including Bus- Coupler arrangement at High lift substation end as per Bid document and as per direction of EIC & technical advisor (E/M), M.E.Dte.	
	Break up :	
A	Supply of all Transformer, L.T. Panel with Air Circuit Breaker, Soft Starter, 4 Nos. 400 sq mm 3 / 3.5 core Aluminum armored cable Electro-Mechanical equipments required to complete the item.	50%
B	Installation of Electro-mechanical equipment and any other work required to complete the item in all respect.	40%
C	After successful trial run of the plant.	10%
	Total =	100%
7.	<u>Electrical Wiring and Lighting arrangement:-</u> Supply delivery & erection of illumination fittings fixture, aviation lamp fittings, exhaust fan. Ceiling fan, lightening arrestor with its wiring and earthing arrangement in Collector well foot way bridge, pumping station complete in all respect considering bid documents as per approval from competent authority and direction of EIC	
	Break up :	
A	Supply of all Electro-Mechanical equipments required to complete the item.	50%
B	Installation of Electro-mechanical equipment and any other work required to complete the item in all respect.	40%
C	After successful trial run of the plant.	10%
	Total =	100%
8.	<u>Rising main Pipe line MS pipe on foot way bridge and DI pipe supplied by AMC under earth trench:-</u> Supplying, Laying and fabricating 12 mm thick 450 mm dia. (2 X 400.00 meter long) Spiral welded mild steel M.S. pipe (TATA/ SAIL make) both side on foot way bridge with necessary PN 1.6 Sluice valve, Butter fly Valve, minimum 6 Nos. Kinetic type Non-return valve, Air release valve, Pressure release valve and all necessary specials and laying of 800 mm / 700 mm dia D.I. pipe line (D.I. Pipe will be	

	<p>supplied from AMC office) including earth work in excavation in trenches, shoring (if necessary) of adequate width having minimum depth to keep the top surface of pipe 1.00 M below of the existing ground level in any kind of soil mixed with boulder, metal crust, concrete pavement, any road sub-grade and its flank etc., dewatering the trenches, preparing the bottom surface of the trenches for continuous bedding including sand filling (if necessary) or over ground installation to cross ditches etc. supported with RCC pillars as & when necessary and fitting, fixing, jointing (all types of joints) valves, specials etc. as per requirement, in position, cutting, chamfering of pipes as required, carriage of materials from Municipal stores to work at site, constructing sluice valve chambers including supply and fitting in position sluice valve of different dia. as per requirement, filling of the trenches with excavated materials, consolidating the same in layers, temporary road restoration, guarding trenches with temporary bamboo railing for safety where necessary, emergency horizontal auger boring (for roads other than NH & SH) where necessary, removing the surplus materials from site including all labour charges, tools and plants, pressure testing, cleaning and disinfection of pipes etc. complete in all respect as per IS 12288-1987 (latest edition) and instruction of E.I.C. The approximate length of rising main is (2 X 400 + 300 = 1100 meter). This item also include Temporary road restoration after testing & consolidation of back filling with 150 mm thick (in two layers) Brick bats with screening materials and morrum.</p>	
	Break up :	
A.	Supply of 12 mm thick Spiral Mild Welded MS pipe line 2 X 450 mm dia 400 meter long & MS manifold line 1000 mm dia of TATA / SAIL make, flange joint with Sluice valve, Non-Return Valve, Air release Valve, Pressure Release.	40 %
B.	Fabricating and jointing with 3.00 meter long 16 mm thick 1000 mm dia MS manifold line, flange joint with Sluice valve, Non-Return Valve, Air release Valve, Pressure Release valve all complete.	40%
C.	Laying of D.I Pipe line 800 mm dia / 700 mm dia.	10 %
D.	After 3 months from trial run	10%
	Total =	100%
9.	<p><u>RCC Retaining wall (at river bank starting point of foot way bridge 2 X 30.00 meter long):-</u> R.C.C. retaining wall both side of Planning, Designing & Construction of R.C.C retaining wall to retain earth up to FGL along with plastering, Boundary wall (1.5 m Height From FGL over retaining wall) with</p>	

	barbed Fencing along with 4.0 m Steel gate with anti corrosion paint, Filling & Land development of Whole Premises up to FGL With good earth with proper compaction & consolidation, 4 m wide road on consolidated pavement with M20 grade of concrete having min. Thickness of 150 mm and nominal reinforcement (min. 0.15 % of Gross area) at top and bottom both ways and over it Paver Block (not less than 60 mm in thickness) inside the premises etc and Finishing complete in all respect per approved drawing and direction of E.I.C.	
A	Construction of RCC retaining wall	25%
B	1.5 M Masonry boundary wall over Retaining wall & steel gate	20%
C	Barbed fencing over boundary wall	15%
D	Filling & land development up to FGL	15%
E	4.0 m wide internal road	15%
F	After successful trial run of the plant.	10%
	Total =	100%
10.	<u>Infiltration gallery:-</u> Construction of 750 mm dia. and suitable length (required length as per designed by the bidder minimum 250.00 meter long) Infiltration gallery including surveying, investigation Planning, design, drawing and construction of Civil, Electrical and Mechanical works including supply, carriage of all materials with foundation for the various units of Infiltration gallery of collector well and provision of following accessories.	
A	Supply of Slotted pipe including fabricated flange, man machineries etc.	30 %
B	Laying of Infiltration gallery, Packing suitable size gravels and filling the same with different graded sand.	40%
C.	Bouldering with netting arrangement and completion of work.	20 %
D.	After 3 months from trial run	10%
	Total =	100%
11.	<u>40 Nos. 300 mm dia Strainer Pushing:-</u> Supplying, investigation, drawing and designing of 40 Nos. 300 mm dia slotted 10 mm thick spiral welded mild steels (TATA / SAIL make) in two / three rows one is at RL 13.50 meter, another one at RL- 15.00 meter and other is at 16.50 meter which is at 6.25 meter, 7.25 & 8.00 meter below the river bed of R.L. 22.825 meter. The spiral welded mild steels pipes of 300 mm inner dia. of 10 mm thick M.S. Pipe. On every meter length of pipes with slotted holes of 960 Nos. slotted holes of size 75 mm X 2.5 mm, is made in 20 rows @ 48	

	Nos. holes in each row. 40 Nos. 300 mm dia. of required length Strainer will be pushing Including supplying and fixing of Butter fly valve 300 mm dia ISI marked as per IS: 14846 with test certificate of Kriloskar / Upadhaya / Kalpana make with necessary extended spindle, Plummer block, head stock with gear arrangement, spacer with anchor bolt etc. to operate from inspection gallery just after pump platform. A bullet head of cast steel 300 mm dia. is initially to be welded to a 2.50 meter length pipes on its one end and to be placed one by one up to 30 meter long (required length as per designed by the bidder minimum 18.00 meter long).	
A.	Supply of Slotted pipe 10 mm thick TATA / SAIL slotted pipe.	20 %
B.	After completion of Jack pushing of 300 mm dia MS pipe.	70%
C.	Washing and developing by hydraulic test.	10 %
D.	After 3 months from trial run	10%
	Total =	100%
12	<u>Electro Mechanical Item :- Testing & Commissioning</u> of the whole installation as per I.E Rules with Govt. Electrical inspector's fees as complete in all respect and as per Bid document & as per direction of EIC & technical advisor (E/M), M.E.Dte.	
A	Supply of all Electro-Mechanical equipments required to complete the item.	60%
B	Installation of Electro-mechanical equipment and any other work required to complete the item in all respect.	30%
C	After successful trial run of the plant.	10%
	Total =	100%
14.	<u>Testing and Commissioning:-</u> Testing & Commissioning of the whole installation as per I.E Rules with Govt. Electrical inspector's fees as complete in all respect and as per Bid document & as per direction of EIC & technical advisor (E/M), M.E.Dte.	
	Break up :	
A	Supply of all Electro-Mechanical equipments required to complete the item.	60%
B	Installation of Electro-mechanical equipment and any other work required to complete the item in all respect.	30%
C	After successful trial run of the plant.	10%
15.	<u>Operation and maintenance of the plant:-</u> Operation and maintenance of the plant for 5 (Five) years. The work includes supplying adequate number of operator personnel and skilled labour with a provision for necessary training to the personnel appointed by the ULB including supplying all sundry materials, and replacement of all types of damaged component etc. as per	

	Bid document and complete in all respect and as per direction of Engineer-in Charge. N.B:- This item will be executed after three (3) months trial run.	
	Break up :	
A	Lump sum price to be quoted which will be paid yearly basis throughout whole operation and maintenance work.	100%
	Total =	100%
16	<u>Security deposit:-</u>	
A	<i>2% of Earnest money deposited earlier will be converted into Security deposit after awarding the Contract and 8% of security deposit, will be recovered from each running account bill.</i>	
B	<i>b) The 80 % of Security deposit or Retention money will be returned after completion of successful operation & maintenance period for 12 months without any interest & rest 20 % security money will be returned after completion of successful operation & maintenance period for 60 months without any interest.</i>	
C	<i>There will be no security deposit for Sl no. 13 and payment for operation and maintenance will be made yearly basis.</i>	
D	<i>The total amount to be quoted & uploaded by the bidder in .xls format of BOQ under Financial document will be as per the clause 57 of section C.</i>	
E	<i>The items which is not covered here but required for successful completion of the project in all respect are to be considered by the bidder while quoting their rates in uploaded BOQ.</i>	

58.0 APPROVAL ONLY BY MAINTENANCE CERTIFICATE

No Certificate other than the Maintenance Certificate referred to in Clause 59 hereof shall be deemed to constitute final approval of the Works.

59.0 MAINTENANCE CERTIFICATE

1) The Maintenance Certificate stating that the Works have been completed and maintained to the satisfaction of the Engineer, shall be issued by him within twenty eight days after the expiration of the period of Maintenance, or if different periods of maintenance shall become applicable to different sections or parts of the Works, the expiration of the latest such period, or as Soon thereafter as any works ordered during such period, pursuant to Clauses 4) and 48 hereof (shall have been completed to the

Satisfaction of the Engineer). With regard to defects that may arise during the Period of Maintenance, the Contractor shall be responsible to carry out restoration/rectification of damages as are attributable to defects in works carried out under this Contract. The decision of the Employer in the regard shall be final and binding on the contractors.

2) Cessation of Employer's liability: The Employer shall not be liable to the Contractor for any matters or thing arising out of or in connection with the Contractor for any matters or thing arising out of or in connection with the Contract or the execution of the Works, unless the Contractor shall have made a claim in writing in respect thereof before the delivery of the Maintenance Certificate under this Clause.

3) Unfulfilled obligations: Notwithstanding the issue of the Maintenance Certificate the Contractor and, subject to the sub-clause (2) of the Clause, the Contractor shall remain liable for the fulfilment of any obligation incurred under the provisions of the Contract prior to the issue of the Maintenance Certificate which remains imperforated at the time such Certificate is issued and for the purpose of determine the nature and extent of any such obligation, the Contract shall be deemed to remain in force between the parties hereto,

60.0 REMEDIES AND POWERS

1) Default of contractor: If the Contractor shall become bankrupt, or have a receiving order made against him, or shall present his petition in bankruptcy, or shall made an arrangement with or assignment in favour of his creditors, or shall age to carry out the Contract under a committee of inspection of his creditors or, being a corporation, shall go into liquidation (other than a voluntary liquidation for the purpose of amalgamation or reconstruction), or if the Contractor shall assign the Contract, without the consent in writing of the Employer first obtained, or shall have an execution levied on his goods, or if the Engineer shall certify in goods, or if the Engineer shall certify in writing to the Employer that in his opinion the Contractor :

a) Has abandoned the Contract, or

b) Without reasonable excuse has failed to commence the Works or has suspended the progress of the Works for twenty eight days after receiving from the Engineer written notice to proceed, or

- c) Has failed to remove materials from the Site or to pull down and replace work for twenty eight days after receiving from the Engineer written notice that the said materials or work had been condemned and/or rejected by the Engineer under these conditions, or
- d) Despite previous warnings by the Engineer, in writing, is not executing the Works in accordance with the Contract, or is persistently or flagrantly neglecting to carry out his obligation under the Contract, or
- e) Has, to the detriment of good workmanship, or in defiance of the Engineer's instructions to the contrary, sublet any part of the Contract.

Then the Employer may, after giving fourteen day's notice in writing to the Contractor, enter upon the Site and the Works and expel the Contractor therefore without thereby avoiding the Contract, or releasing the Contractor from any of his obligations or liabilities under the Contract, or affecting the rights and powers conferred on the Employer or the Engineer by the Contract, and may himself complete the Works or may employ any other contractor or agency to complete the Works. The Employer or such other contractor may use for such completion so much of the Constructional Plant, Temporary Works and materials, which have been deemed to be reserved exclusively for the execution of the Works, under the provisions of the Contract, as he or they may think proper and the Employer may, at any time, sell any of the said Constructional Plant, Temporary Works used and unused materials and apply the proceeds of sale in or towards the satisfaction of any sums due or which may become due to him from the Contractor under the Contract.

2) Valuation at date of forfeiture: The Engineer shall, as soon as may be practicable after any such entry and expulsion by the Employer, fix and determine expert, or by or after reference to the parties, or after such investigation or enquiries as he may think fit to make or institute and shall certify what amount, if any, had at the time of such entry and expulsion been reasonably earned by or would reasonably accrue to the Contractor in respect of work then actually done by him under the Contract and the value of any of the said unused or partially used materials, and Constructional Plant and any Temporary Works.

3) Payment after forfeiture: If the Employer shall enter and expel the Contractor any money on account of the Contract until the expiration of the Period of Maintenance and thereafter until the costs of execution and maintenance, damages for delay in completion, if any and all other expenses incurred by the Employer have been ascertained and the

amount thereof certified by the Engineer. The Contractor shall then be entitled to receive only such sums or sums, if any, as the Engineer may certify would have been payable to him upon due completion by him after deducting the said amount. If such amount shall exceed the sum which would have been payable to the Contractor on due completion by him, then the Contractor shall, upon demand, pay to the Employer the amount of such excess and it shall be deemed a debt due by the Contractor to the Employer and shall be recoverable accordingly.

61.0 URGENT REPAIRS

If, by reason of any accident, or failure, or other event occurring to in or in connection with the Works, or any part thereof, either during the execution of the Works, or during the period of Maintenance, any remedial or other work or repair shall, in the opinion of the Engineer or the Engineer's Representative, be urgently necessary for the safety of the Works and the Contractor is unable or unwilling at once to do such work or repair, the Employer may employ and pay other persons to carry out such work or repair as the Engineer or the Engineer's Representative may consider necessary.

If the work or repair so done by the Employer is work which in the opinion of the Engineer, the Contractor was liable to do at his own expense under the Contract, all expenses properly incurred by the Employer in so doing shall be recoverable from the Contractor by the Employer, or may be deducted by the Employer from any sums due or which may become due to the Contractor, Provided always that the Engineer or the Engineer's Representative, as the case may be, shall, as soon after the occurrence of any such emergency as may be reasonably practicable, notify the Contractor thereof in writing.

62.0 SPECIAL RISKS

Notwithstanding anything in the Contract contained:

1) No liability for war, etc., Risks- The Contractor shall be under no liability whatsoever whether by way of identity or otherwise for or in respect of destruction of or damage to the Works, same to work condemned under the provision of Clause 38 hereof prior to the occurrence of any special risk hereinafter mentioned, or to property whether of the Employer or third parties, or for or in respect of injury or loss of life which is the consequence of any special risk as hereinafter defined The employer shall indemnify and save harmless to Contractor against and from the same and against and from the same

and against and from all claims, proceedings, damages, costs, charges and expenses whatsoever arising there out or in connection therewith.

2) Damage to works, etc., by special risks - If the Works or any materials on or near or in transit to the Site, or any other property of the Contractor used or intended to be used for the purposes of the Works, shall sustain destruction or damage by reason or any of the said special risks the Contractor shall be entitled to payment for:

a) Any permanent work and for any materials so destroyed or damaged and so far as may be required by the Engineer, or as may be necessary for the completion of the Works, or the basis of cost plus such profit as the Engineer may certify to be reasonable;

b) Replacing or making good any such destruction or damage to the Works;

c) Replacing or making good such materials or other property of the Contractor used or intended to be used for the purposes of the Works.

3) Projectile missile etc.: Destruction, damage, injury or loss of life caused by the explosion or impact whenever and wherever occurring of any mine, bomb, shell, grenade, or other projectile, missile, ammunition, or explosive of war, shall be deemed to be a consequence of the said special risks.

4) Increase cost arising from special risks: The Employer shall repay to the Contractor any increased cost of or incidental to the execution of the Works, other than such as may be attributable to the cost of reconstructing work condemned under the provisions of Clause 38 hereof, prior to the occurrence of any special risk, which is howsoever attributable to or consequent on or the result of or in any way whatsoever connected with the said special risks, subject however to the provisions in this Clause hereinafter contained in regard to outbreak of war, but the Contractor shall as soon as any such increase of cost shall come to his knowledge forthwith notify the Secretary thereof in writing.

5) Special Risks: The special risks are war, (whether war be declared or not), invasion, act of foreign enemies, the nuclear and pressure waves risk described in Clause 19(2) hereof, or in so far as it relates to the country in which the works are being or are to be executed or maintained, rebellion, revolution, insurrection, military or usurped power, civil war, or unless solely restricted to the employees of the Contractor or of his Sub-Contractor and arising from the conduct of the Works, riot, commotion or disorder.

6) Outbreak of war: If, during the currency of the Contract, there shall be an outbreak of war, whether war is declared or not, in any part of the world which, whether financially or otherwise, materially affects the execution of the works, the Contractor shall, unless and until the Contract is terminated under the provisions of this Clause, continue to use his best endeavours to complete the execution of the Works. Provided always that the Employer shall be entitled at any time after such outbreak of war to terminate the Contract by giving written notice to the Contractor and upon such notice being given, this Contract shall, except as to the rights of the parties under this Clause and to the operation of Clause 64 hereof, terminate but without prejudice to the rights of either party in respect of any antecedent breach thereof

7) Removal of plant of termination: If the Contract shall be terminated under the provisions of the last preceding sub-clause, the Contractor shall, with all reasonable dispatch, remove from the Site all constructional Plant and shall give similar facilities to his Sub-Contractors to do so.

8) Payment if Contract terminated: If the Contract shall be terminated as aforesaid, the Contractor shall be paid by the Employer, in so far as such amounts or items shall not have already been covered by payments on account made to the Contractor, for all work executed prior to the date of termination at the rates and prices provided in the Contract and in addition

a) The amounts payable in respect of any preliminary items, so far as the work carried out or performed, and a proper proportion as certified by the Engineer of any such items, the work or service comprised in which has been partially carried out or performed.

b) The cost of materials or goods reasonably ordered for the Works which shall have been delivered to the Contractor or of which the Contractor is legally liable to accept delivery such materials or goods becoming the property of the Employer upon such payments being made by him.

c) A sum to be certified by the Engineer, being the amount of any expenditure reasonably incurred by the Contractor in the expectation of completing the whole of the Works in so far as such expenditure shall not have been covered by the payments in this sub-clause before mentioned.

d) Any additional sum payable under the provisions of sub-clause (1), (2) and (4) of this Clause. Provided always that against any payments due from the Employer under this

sub-clause, the Employer shall be entitled to be credited with any outstanding balances due from the contractor for advances in respect of Constructional Plant and materials and any other sums which at the date of termination were recoverable by the Employer from the Contractor under the terms of the Contract and provided that if the termination be made in exercise of Clause C-60(1), no payment shall be released under ClauseC-62(8) (a) to (d).

63.0 FRUSTRATION

Payment in event of Frustration: A war, or other circumstances outside the control or both parties, arises after the Contract is made so that either party is prevent from fulfilling his contractual obligations, or under the law governing the Contract, the parties are released from further performance, then the sum payable by the Employer to the Contractor in respect of the work executed shall be the same as would have been payable under Clause 62 hereof if the Contract had been terminated under the provisions of Clause 62 thereof.

64.0 SETTLEMENT OF DISPUTES

Settlement of Disputes: If any dispute or difference of any kind whatsoever shall arise between the Employer and the Contractor or the Engineer and the Contractor in connection with, or arising out of the Contract, of the execution of the Works, whether during the progress of the Works or after their completion and whether before or after the termination, abandonment or breach of the Contract, it shall be settled in the court of law having jurisdiction within Nadia District, provided that such a recourse shall not be resorted to without exhausting all other reasonable avenues of redresser.

65. NOTICES

1) Contractor's local office and service of notices to contractor: The Contractor shall have a local office at or near the Site of work, full address thereof shall be intimated by the Contractor or his authorized Agent to the Employer as well as to the Engineer. All Certificates notice or written orders to be given by the Employer or by the

Engineer to the Contractor under the terms of the Contract shall be deemed to have been served by sending by post to or delivering the same to the Contractor's local office.

2) Service of notice to employer: All Notice to be given to the employer under the terms of the Contract, shall be served by sending by Registered post or delivering the same to the address given below: **The Secretary. Asansol Municipal Corporation, P.O: Asansol, Dist: Paschim Bardhaman, Pin 713301.**

(3) Change in Address of the Employer, the Engineer or the Contractor may change a nominated address to another address by prior written notice to the other two and in that event shall resume receiving of communication 28 days after delivery of such notice.

66.0 PRICE ADJUSTMENT

(1) The prices to be paid to the contractor for the whole work shall remain firm during the stipulated contract period or extension thereof and no price adjustment shall be allowed.

(2) The statutory changes in price in the form of Taxes, duties etc. shall however be taken into account. For this purpose the taxes and duties prevailing on the last date of submission of the technical bid (or revised price bid, if applicable) shall be taken as the base. Such taxes and duties for different bought out items shall be specified by the contractor, falling which the assessment of the Employer shall be final and binding. Changes in price of Petrol, Diesel Lubricants, and Electricity etc. shall not be considered.

67.0 MISCELLANEOUS

Dangerous materials: Explosive, chemicals, combustible articles and items and similar materials intended for the Works shall be conveyed, stored and used by the Contractor and his sub-contractors In accordance with all laws, decrees, instruments, orders and regulations imposed by the Government or any of its instrumentalists. Observance of all safety provisions shall be the obligation of the Contractor and nothing herein shall release him from full responsibility for damage or injury to persons or properties resulting from his use of these dangerous materials.

67.0 CONTRACT CONFIDENTIAL

Except with the prior written approval of the Employer and to subject the such conditions

as may be prescribed, the Contractor and/or any member of his organization shall not in any case communicate to any person or entity and information connected with the performance of the Services or in carrying out the Works not make public any information for the purpose of publication or advertisement. The Contractor shall treat all matters related to the Contract as private and confidential.

68.0 CONTRACTOR TO PROVIDE FACILITIES

The Contractor shall provide such labour, materials and other facilities that the Engineer or his Representative may require to assist them in carrying out normal tests and checks on materials and workmanship and in measurement of works.

69.0 INTERFERENCE WITH EXISTING FACILITIES

The Contractor shall carry out the works in such a way as to the minimum extent of interference to the use of existing facilities of any kind.

70.0 ACTS OF INFLUENCE

Neither the Contractor nor any of his Agents, Representatives, Employees or members of his organization shall commit any act which may influence the judgment or decision of the Employer or the Engineer or any their agents, representatives, employees or members of their respective organization. Any breach of this provision shall constitute a breach of Contract on the part of the Contractor and apart from penal measures against the Contractor according to the law the Employer shall have the Authority to take action for the Contractor's default in terms of the provisions of Clause 60 hereof.

71.0 INDIVIDUALS NOT PERSONALLY RESPONSIBLE

No personal liability shall be imposed on the members or the Employer or on the Engineer or their duly authorized representatives, agents or employees for acts performed or discharged in the exercise of their authorized duties or responsibilities or in carrying out their obligations by virtue of the provisions or scope of work contained in the Contract, if being understood that they are acting solely as agents and representatives of the Employer in good faith.

72.0 CONTRACT EMBODIES WHOLE ARRANGEMENT

The Contract becomes effective immediately on Issue of the letter of acceptance to the

successful Bidder. The Contract (with annexure if any) as subsequently executed embodies the whole arrangement between the parties entering into the Contract All previous correspondence, negotiations, representation, explanations statements, promises or guarantees (whether oral or written) as are not included with the Contract as executed, shall normally be excluded in the interpretation of the Contract.

73.0 COMPLETION DRAWING

Completion drawing including detailed construction drawing shall have to be submitted in original with 6 (six) copies of prints of each. The original drawings shall be drawn on thick polyester film approved by the Engineer-in-Charge. Scale and size of drawings shall also be as specified by the Engineer-in-Charge. Soft copy of drawing copied in CD/DVD should be submitted in addition. No extra payment will be made for it. The Completion drawings are to be got approved by the Employer and shall have to be submitted before the issue of certificate of final acceptance as in Clause C-57 (6).

SECRETARY
ASANSOL MUNICIPAL CORPORATION

SECTION - D

SPECIAL PROVISIONS

1.0 GENERAL

1.1 EXTENDED SCOPE OF THE CONTRACT:-

The contract comprises the surveying, planning, designing, drawing supplying materials and equipment, construction, testing of the plant, Trial Run for 3 months, commissioning of E/M Equipments with continuous operation for 72 hrs and maintenance for a period of (60) sixty months accept rising main after successful trial run upon completion of the works and commissioning and except in so far as the contract otherwise provides, the provision of all labour, materials, constructional plant, temporary works and everything (whether of a temporary or permanent nature) required red in and for such planning,

design, construction, completion and maintenance so far as the necessity for providing the same is specified in or reasonably to be inferred from the contract.

1.2 ITEM WISE DETAILS OF THE LUMP SUM PRICES AND INTERIM PAYMENT SCHEDULE:-

The successful contractor will, against each of the job items quoted in the schedule or prices on lump sum basis, submit a detailed break up of lump sum prices for the approval of the Secretary for the purpose of preparing interim payment schedule and calculating the consumption of materials to be issued by the Authority. The break ups will be such as to fairly agree with the lump sum price quoted. The Secretary, on recommendation of Superintending Engineer of Western Circle of Municipal Engineering Directorate shall have the authority to modify the breakup of prices keeping, however, the total of the prices fairly equal to the lump sum amount quoted. Lump sum prices quoted in the schedule of prices shall remain fixed irrespective of the variations (i) in Items and quantities during actual execution compared with those provided in the break-ups.

SECTION – D

SPECIAL PROVISIONS

1.0 GENERAL

1.1 Extended scope of the contract:-

The contract comprises the surveying, planning, designing, drawing supplying materials and equipment, construction, testing of the plant, Trial Run for 3 months, commissioning of E/M Equipments with continuous operation for 72 hrs and maintenance for a period of (60) sixty months accept rising main after successful trial run upon completion of the works and commissioning and except in so far as the contract otherwise provides, the provision of all labour, materials, constructional plant, temporary works and everything (whether of a temporary or permanent nature) required red in and for such planning, design, construction, completion and maintenance so far as the necessity for providing the same is specified in or reasonably to be inferred from the contract.

1.2 ITEM WISE DETAILS OF THE LUMP SUM PRICES AND INTERIM PAYMENT SCHEDULE:-

The successful contractor will, against each of the job items quoted in the schedule or prices on lump sum basis, submit a detailed break up of lump sum prices for the approval of the Secretary for the purpose of preparing interim payment schedule and calculating the consumption of materials to be issued by the Authority. The break ups will be such as to fairly agree with the lump sum price quoted. The Secretary, on recommendation of Superintending Engineer of Western Circle of Municipal Engineering Directorate shall have the authority to modify the breakup of prices keeping, however, the total of the prices fairly equal to the lump sum amount quoted. Lump sum prices quoted in the schedule of prices shall remain fixed irrespective of the variations (i) in Items and quantities during actual execution compared with those provided in the break-ups.

Such break-ups for Civil Works shall include for each of the unit of the intake jetty pumping station with HT substation, laying of 700mm dia. pipe lines up to the inlet well of the clear water treatment plant following broad items of works:

- i) Piling
- ii) Cement Concrete
- iii) Reinforcement
- iv) Brick Work
- v) Structural Steel Work
- vi) Doors, Windows, Rolling Shutters, Gates etc.
- vii) Roof Treatment
- viii) Plumbing and Sanitary Works
- ix) Pipe Lines and appurtenant structures
- x) Finishing works and other miscellaneous works (to be specified by the Contractor). Break-ups for Mechanical Equipment shall be into the following broad items:
 - i) Pumping unit of intake jetty
 - ii) Electrical actuator control valves, and penstocks

- iii) Structural Steel Works if any
- iv) Pipes and specials
- v) Flow meters & Flow measuring meter
- vi) Discharge meter
- vi) Miscellaneous (to be specified by the Contractor)
- vii) Laying of rising main 700 mm dia.(supplied by the dept,) with valves and jack pushing Break-ups for Electrical Equipment shall be into the following broad items:
 - i) Motors
 - ii) Cables
 - iii) Motor control panel with APFC panel
 - iv) HT Switch gears
 - vi) Other electrical equipment (to be specified by the contractor)

The above-mentioned details should be submitted by the contractor as early as possible after receipt of the Letter of Intent in order to enable him to start any sub-items of work and to receive interim payments. Where a component includes civil mechanical and electrical equipment, the break ups should invariably be submitted.

1.3 STORE SHED

The Contractor shall provide at his own cost a store shed of adequate capacity for storing materials. The shed should be of such construction that it must protect the materials against deterioration. A raised platform well above the highest flood level shall be made for stacking cement in such a way that the cement procured earlier can be consumed first so as to avoid deterioration due to prolonged stacking. If any modifications to the store shed is suggested by the Secretary recommendation of the Engineer for better storing of materials that should be carried out by the Contractor at his own cost.

1.4. LAND FOR CONTRACTOR'S ESTABLISHMENT

For the purpose of constructing Contractor's Store yard, go-downs, site office and ancillaries, he may utilize portion of the land belonging to the Employer at such location as would not interfere to execute other co works. For all these, the Contractor shall have to

obtain the requisite permission of the Engineer. The Contractor shall for this purpose submit to the Engineer for his approval a plan of the proposed layouts for the site facilities. The Engineer reserves the right to alter and modify the Contractor's proposals as the Secretary may deem fit.

1.5 WATER AND ELECTRICITY FOR CONSTRUCTION

1.5.1. The Contractor shall have to make his own arrangement for supply of water and for electrical power that may be required for or in connection with the works. No payment on this account will be entertained. However, Municipality may assist in getting power.

1.5.2. Arrangement for supply of piped water may not be possible. The Contractor will have to make arrangement for supply of drinking water and water required for constructions works by sinking tube wells or other suitable alternatives. The Tenderer shall investigate this matter during site inspection before submission of tenders: No payment will be entertained on this account.

1.5.3. Nevertheless electrical power from usual supply agencies may not be continuously available due to various reasons including load shedding. In case of non-availability of electrical power the contractor will have to make his own arrangements for electrical power through generations. Contractor should include such aspects while quote his rate. No payment will be entertained on this account. When drawing power from the Municipality power point, the contractor shall have to bear the cost of electrical charges. The route of conveyance shall be subject to approval by the Engineer-in-Charge and will be in accordance with prevailing I.E. Rules.

1.6 FIRST-AID FACILITIES:- The Contractor shall arrange for medical attentions to be promptly available when necessary. He shall for this purpose provide a number of First-Aid stations at suitable locations within easy reach of the workmen and other staff engaged in the Works. Each First-Aid station shall be properly equipped and will remain in charge of a suitably qualified person. The Contractor shall also provide for transport of serious cases to the nearest hospital. All these arrangements shall be to the approval of the Secretary.

1.7 FIRE FIGHTING ARRANGEMENT / FIRE EXTINGUISHING ARRANGEMENT:- The Contractor shall provide suitable arrangement for fire fighting / fire Extinguishing. For this purpose he shall provide requisite number of Fire Extinguishers and adequate number of buckets, some of which are to be always filled with sand and some with water. These

equipments shall be provided at suitable prominent and easily accessible places and shall be properly maintained.

1.8 SAFETY MEASURES: - The Contractor shall be responsible for the safety of all workmen and other persons entering or in the works and shall at his own expense and to the approval of the Secretary, take all measures necessary to ensure their safety.

Such measures shall include the provisions of helmets (Specially where work at a height is involved), provision of gum-boots to workers engaged in cement concrete or other works, scaffolding or other measures required for working at a height, shall be strong and rigid and have to be provided with suitable and convenient access. Shoring required for deep excavation must be adequate and rigidly braced and strutted. The Contractor shall provide depending on the exigencies of the location and nature of work and other relevant factors, other safety measure that the Secretary may direct.

1.9 SUPERVISORY STAFF:-

The Contractor shall engage an experienced and qualified Site Manager to be in day-to-day charge of the work and he should be authorized to receive instructions from the Engineer. He shall receive orders given by the Engineer from time to time and shall act on them promptly. The Contractor shall, during working hours, maintain engineer and supervisors of sufficient training and experience to supervise the various items and operations of the work. Orders and directions as given to such engineers and supervisors or other staff of the Contractor shall be deemed to have been given to the Contractor. The Chief Engineer of the Contractor responsible for this work, by whatever designation he may be known, but who will be specified on award of the Contract shall at least once in a fortnight inspect the works and shall discuss with the Engineer the conduct and progress of the work.

1.10 JOINT SURVEY

The Contractor shall satisfy himself regarding the correctness of the layouts, levels etc. as are shown in the drawings or given in the specifications. Before starting the work he shall also carry out at his own cost, survey of the whole work site jointly with the representative(s) of the Authority. Discrepancies noticed between drawings and the joint survey shall be informed in writing to the Secretary and got set right before execution of works. Such deviations as may arise out of the joint survey shall not violate the provisions of contract or entitle the Contractor to any extras in any way.

1.11 LAYOUT AND CHECKING

The contractor shall provide all labour, skilled and unskilled and all materials needed for carrying out, as directed, survey, laying out, setting out, checking of works, taking measurements, testing hydraulic and other structures, without any extra payment. The Contractor shall also provide approach and access to all the works and stores without any extra cost.

1.12 REFERENCE POINTS

After the joint survey has been plotted and approved by the Secretary recommendation of the Engineer, permanent base lines, cross line and bench marks shall be established by the Contractor so as to serve as reference points and "Dimensional Control Basis" of works. He shall prepare and submit a plan showing such reference points with their full description.

1.13 CO-OPERATION WITH OTHER CONTRACTORS

Some works in plant site, have been already done/are being done/will be done through other contractors. In the event of any such work the contractor shall have to work in full co-operation and in close co-ordination with other contractor/contractors. Any difficulty that may arise in this connection will have to be amicably settled by the contractors amongst themselves. If that be not possible, the matter shall be referred to the Secretary whose decision shall be final and binding on all the parties.

However, the site allocated to the contractor may be fenced at the Contractor's cost provided any necessary access to others as it required is given. The contractor will be permitted to use only the access to the site as indicated on the site plan of Tender Drawing.

1.14 APPROVAL OF MATERIALS AND EQUIPMENT TO BE USED

Samples in large enough quantity of materials and descriptive data therefore requiring prior approval shall be furnished by the contractor to the Secretary in good time before the collection of such materials and equipment so as to permit inspection and testing. The samples shall be properly marked to show the name of the materials, name of the manufacturer and place of origin and item for which it is to be used. Only upon approval, the materials of approved quality shall be brought to site. Samples approved shall be on

exhibition at all times, properly stores and prevented from deterioration for the purpose of comparison with the materials brought to site of work from time to time for use in work.

1.15 TESTING & TESTING EQUIPMENT

1.15.1. Testing of materials to be used in the permanent work or of the quality of finished items, shall have to be done from approved laboratory at the expense of the contractor.

The contractor shall afford at his own cost necessary facilities in providing the requisite materials and other assistance that may be required by the Engineer including transport of the test specimens to the laboratory referred to above,

1.15.2 The Contractor shall provide at his own cost necessary equipment for such testing which by the nature of work may have to be done at site or for taking samples for testing in laboratories. These include sufficient number of slump cones, standard 150 mm metal cube moulds, sets of I.S sieves, weighing balances, graduated measuring cylinders, complete set of equipment for in-site density test, thermometers and any other miscellaneous equipment that may be required by the Engineer or his Representative. The Contractor shall also provide necessary arrangement for curing of concrete cube specimens as instructed by the Engineer.

1.16 CONSTRUCTION RECORDS

The Contractor shall keep and supply to the Engineer the up-to-date records of the dimensions and positions of all permanent works (showing therein any approved deviation between the drawing and the work as actually executed), The information available from the records must be adequate and complete to enable preparation of "as-made" drawing by the Contractor from these records,

1.17 PROGRESS PHOTOGRAPHS

The Contractor shall at his own cost and expense arrange to take periodic photographs to show the progress of work or interesting features thereof. The time and the position where from a photograph is to be taken should be as per direction of the Engineer or his Representative, Three copies of each of these photographs to an enlarged size of about 25 cm x 20 cm together with the CD / DVD, shall be supplied to the Secretary and these shall become the property of the Employer. Each photograph shall be suitably captioned with the date of the photograph, location and other relevant particulars, further prints and

CD of the photograph, location and other relevant particulars shall not be kept by the Contractor or reproduced without written permission of the Employer. Digital Camera with 10.0 Mega pixels should be used for taking photos.

Restrictions to photography or security restrictions that may be applicable to any particular area must be carefully and rigidly observed.

The number of photographs (each consisting of three prints and the CD/DVD as aforesaid) for the complete works is not expected to exceed 100 (one hundred), No photograph of the plant and other installations shall be taken without prior approval of the concerned officers

1.18 SATISFACTORY COMPLETION OF VARIOUS ITEMS

The sub-works included in the Schedule of Prices are job works on lump sum basis. The various items of the sub-work are to fit in perfectly in the whole plant in every respect so as to form effective working parts of the whole plant as per satisfaction of the Secretary. Each sub-work will be considered as complete when it is completed as per specifications and put into commission, as per standards, as a successful component part of the whole plant.

1.19 CHECKING QUALITY OF WORK

Should the Engineer consider it necessary to satisfy himself as to the quality of the work, the Contractor shall, at any time during continuance of the contract, offer sample of work done or if necessary pull down a reasonable part of the work enough for such inspection and testing as the Engineer may direct and the Contractor shall make good the same at his cost and to the satisfaction of the Engineer without any extra cost.

1.20 RECORDING MEASUREMENTS

Though the offer is on lump sum basis, the Contractor shall give not less than five days notice, in writing to the Engineer, about the work which is proposed to be covered or placed beyond the reach of measurements so that measurements may be taken before the work is covered, bar bending schedule is to be provided five days before the casting date. If any work is covered without such written notice, the same shall be uncovered at the cost of the Contractor and in default hereof no payment or allowances shall be made

for such work. These requirements apply for all the component items executed for the sub-work for which lump sum price is quoted

1.21 REPORTS AND RETURNS

The Contractor shall maintain at Site daily records of progress with regard to the works carried out, labour engaged and construction equipment deployed. These will form the basis of preparing periodic reports and returns as may be required by the Engineer and in the manner as directed by him.

These daily records shall be made accessible to the Secretary & Engineer or his Representative as and when desired by him.

1.22 SITE ORDER BOOKS

1.22.1 For the purpose of quick communication between the Engineer or his Representative and the Contractor or his Agent or Representative, Site Books shall be maintained at site in the manner described below. Any communication relating to the works may be conveyed through records in the Site Books. Such a communication from one party to the other shall be deemed to have been adequately served specified elsewhere in the General Conditions of Contract. Each Site Book shall have machine-numbered pages in triplicate and shall be carefully maintained and preserved.

1.22.2 The Contractor shall keep Site Books at various places Site work is being carried out so as to be readily available to the Engineer or his Representative. Any instruction or order which the Engineer or his Representative may like to issue to the Contractor may be recorded by him in the Site Book and two copies thereof taken by him for his record. The Contractor or his Agent or Representative may similarly maintain separate Site Book for any communication he may like to send to the Engineer or his Representative. Two copies thereof when sent to the Engineer's Representative and receipt obtained thereof, will constitute adequate service of the communication to the Engineer.

2.0 MATERIAL

2.1 The Contractor is liable to procure materials like Cement and Steel of required specifications from his own for smooth progress of the work under terms and conditions stipulated hereinafter.

Procurement of cement and steel materials require prior permission from appropriate authorities (Superintending Engineer, Municipal Engineering Directorate) for approval of Brand & quality of materials to be procured by the Contractor.

2.2 However, if, in the interest of the Works, any material be issued to the Contractor, the provisions of Clause 2 shall apply mutates mutants and the issue rate thereof shall be as fixed by Secretary.

2.3 CEMENT :-

The Cement shall be Ordinary Portland Cement of strength not less than 53 MPa (53 Grade) complying with IS: 12269; 1987.

2.4 STEEL

Steel bars for use in reinforcement shall be cold twisted bars complying with IS: 1786; 1985 (Reaffirmed 1990) specifications.

3. TECHNICAL ASSISTANCE

Training of Technical Personnel: - The Contractor shall undertake to train one technical personnel selected and sent by the ULB to the works of the Contractor. These engineers shall be given special training in the shop and drawing office where the equipment will be designed and manufactured and where possible in any other plant where Contractor's manufactured equipment of similar type is under installation tests or maintenance, to enable them to become fully familiar with the equipment being supplied by the Contractor. The period of training shall be as decided by the ULB but in any case shall not exceed six months for any individual. During the period of training the Contractor shall arrange for reasonable accommodation of the engineers and transport from the place of accommodation to the works or plant.

The Contractor's supervisory personnel at site shall continuously and intensively instruct and train an adequate number of the ULB authority operating and maintenance personnel at site during erection and commissioning of the plant to enable them to take over the operation and maintenance of the plant after the maintenance period. No extra payment shall be made by ULB for the training of personnel under this clause.

4. TERMS OF PAYMENT:-

AS PER CLAUSE 57 OF SECTION C

5. NO INTEREST ON DUES: - No interest will be payable by the Employer on the amount due to Contractor pending final settlement.

6. DISPOSAL OF THE EXCAVATED MATERIALS

All materials obtained from any excavation required to be carried out under this contract will be the property of the ULB and the Contractor shall not have any claim on it. It will not be used for any purpose other than refilling the excavations as needed or levelling the compound or in construction of any embankment or in any manner as directed by the Engineer. After completion of work or earlier if so directed by the Employer the surplus excavated materials shall be disposed off by the contractor to any distance without any extra cost, but only after being so directed by the Employer.

7. POSSESSION PRICE TO COMPLETION

The Authority shall have the right to take possession for use of any completed or partly completed part of the work. Such possession or use shall not be deemed to be an acceptance of any work not completed in accordance with the agreement.

8. TENDER TO STRICTLY COMPLY WITH SPECIFIED CONDITIONS AND ALL OTHER SPECIFICATIONS

It should be clearly noted that the Bidders have to strictly comply with the specifications and other terms and conditions laid down in this document and no variations are permissible. This is necessary for the purposes of comparison of tenders received.

The Contractor shall stand guarantee for producing potable water as per the standards laid down in the tender and for the works carried out under this Contract.

SECRETARY

ASANSOL MUNICIPAL CORPORATION

SECTION - E

GENERAL SPECIFICATIONS OF WORKMANSHIP AND MATERIALS FOR CIVIL WORK

1.0 GENERAL

1.1 GENERAL MATERIALS

1.1.1. All materials used in the permanent works shall be of the best quality of the kind and to the approval of the Engineer-in-Charge. Any material not covered by these Specifications, shall comply with the relevant latest Indian Standard Specifications (Referred to as IS as revised or modified up-to the date one month prior to Tender date). British or American Standard Specifications shall be referred to in case any particular specification is not available in any of the aforesaid Specifications. For materials not specified in the aforesaid, direction of the Engineer-in-Charge shall be followed. All disputes shall be referred to the Employer, whose decision shall be final and binds.

1.1.2. Samples of materials to be supplied and used, by the Contractor in the works shall be to the prior approval of the Engineer-in-Charge. For this purpose the Contractor shall furnish in advance representative samples in quantities and in the manner as directed by the Engineer-in-Charge for his approval. Materials brought to the Site, which in the option of the Engineer-in-Charge do not conform to the approved sample and if so directed by him shall be removed by the Contractor from the Site and replaced by the materials of approved quality.

1.1.3. In spite of approval of the Engineer-in-Charge of any materials brought to the site, he may subsequently reject the same if in his opinion the materials has since deteriorated due to long or defective storage or for any reason whatsoever and is thereby considered unfit for use in the permanent works. Any material thus rejected shall be immediately removed from the Site at Contractor's cost and expense.

1.1.4. All materials brought to the Site shall be properly stored and guarded in the manner as directed by the Engineer-in-Charge and to his satisfaction.

1.1.5. The Engineer on written request of Secretary may carry out test of materials as he may decide. The Contractor shall, at his cost and expenses, for this purpose supply requisite materials and render such assistance to the Engineer-in-Charge as he may require.

1.2 WORKMANSHIP

All works are to be carried out in proper workman like manner. Items of works not covered by these Specifications or by other tender documents shall be carried out as per best practice according to the direction of the Engineer-in-Charge and to his satisfaction. The relevant IS Specifications or in case of necessity British or American Standard Specifications shall be taken as guide for the purpose.

1.3 WORKS INCLUDED

The rates for all items, unless specifically stated otherwise in the Contract, must cover the cost of all materials, labour, tools, machinery, plant, pumps, explosives, scaffolding, staging strong props, bamboos, ropes, templates, pages and all appliances and operations whatsoever necessary for efficient execution of work.

1.4 GROUND CONDITIONS

The Contractor is to visit the site and ascertain local conditions, traffic restrictions and obstructions in the area and allow for extra expenses likely to be incurred due to any limitations whatsoever.

1.5 SETTING OUT AND LEVELLING

The Contractor is to set and level the works, and will be responsible for the accuracy for the same. He is to provide all instruments and proper qualified staff required for checking the Contractor's work.

1.6 SAFETY

The Contractor shall take adequate precaution to provide complete safety for prevention of accidents on the site.

1.7 KEEPING WORKS FREE FROM WATER

The Contractor shall provide and maintain at his own cost, electrically or other power driven pumps and other plant and equipment to keep site excavated foundation pits and trenches free from surface as well as subsoil/leakage water from any other source thereof and continue to do so to the complete satisfaction of the Engineer-in-Charge till the site is handed over. Method of dewatering shall need approval of the Engineer-in-Charge but no payment whatsoever is allowed on this count.

1.8 RUBBISH

1.8.1. The Contractor shall clear all rubbish, vegetation, roots, soda etc., and dump them in the area indicated to the satisfaction of Engineer-in-Charge. No separate rate shall be allowed for the above work.

1.8.2. After the work is completed, the Contractor shall clear the area surrounding the buildings, all hutments and excess stores and remnants of building materials such brick bats, metal, sand, timber, steel etc.

1.9 BENCH MARKS AND GROUND WATER GAUGES

The Contractor shall protect surveyor's benchmarks and ground water gauges, zero line marks and base line marks and base line marks from damage of movement during work.

1.10 INSPECTION

The Contractor shall inspect the Site of works and ascertain site condition and the nature of soil to be excavated.

1.11 CONTRACTOR'S STAFF :- The Contractor must provide at all times efficient staff of trustworthy, skilful and experienced assistance capable of carrying out the work in accordance with the drawings and specification and to correct levels. The cost this establishment should be included in his rates.

1.12 METHOD OF MEASUREMENT :- Unless otherwise specified, the method of measurement for building works shall be as per IS: 1200.

1.13 SPECIFICATIONS REFERRED TO

1.13.1 The specification contained herein is not exhaustive and for such items of works which may arise and which are not covered by these specifications, the provisions in the relevant Indian Standard (Latest Edition) shall apply.

1.13.2 A list of some Indian Standards is given herein.

1.13.3 Wherever reference to the Indian Standard mentioned below or otherwise appears in the specification, it shall be taken as reference to the latest version of the Standard.

IS Code No	Description
IS: 1200	Method of measurement of building and Civil Engineering works.
IS: 1542	Sand for plaster.
IS: 383	Aggregates-Coarse and fine, from natural source for Concrete.
IS: 515	Aggregates for use in Mass Concrete, natural and manufactured.
IS: 456	Code of Practice for Plain and Reinforced Concrete for General Building construction.
IS: 3370	Code of Practice for Concrete Structures for the Storage of Liquids.
IS: 12269	Specification for 53 Grade Ordinary Portland cement.
IS: 1786	Specification for High Strength Deformed bars& wires for concrete reinforcement.
IS: 1077	Common Burnt Clay Building Bricks.
IS: 1235	Flooring Tiles, Cement Concrete, Floor Finish
IS: 1443	Cement Concrete, Flooring Tiles, Laying and finishing.
IS: 1661	Cement and Cement Lime Pointing Plaster finishes on walls and Ceilings.
IS: 226	Structural Steel (Revised) Iron Work
IS: 800	Code of Practice for use of Structural Steel in General Building Construction.
IS: 1199	Workability of Concrete
IS: 1893	Earth quake code

2.0 EARTH WORK IN EXCAVATION & FILLINGS

2.1 GENERAL :- Applicable provisions of Conditions of contract shall govern work under this section.

2.2 EXCAVATION FOR FOUNDATION, TRENCHES, PIT ETC.

The excavation work shall be carried out in all kinds of Soil including Sand in workman like manner without endangering the safety of the nearby Structures or works without causing any hindrance to other activities in the area. The existence of old buildings, boundary walls, hutment, sewer lines, water lines, if any very close to the area of excavation should be given careful consideration while designing carrying out the excavation work. The excavation shall be done in such method as would technically be appropriate and befitting the site conditions subject to the approval of the Engineer-in-Charge. All foundation trenches shall be excavated to the full width and depths shown on the approved drawing or to such ordered to the Contractor.

The Contractor shall not undertake any earthwork without having obtained prior approval from the Engineer-in-Charge to the methods he proposes to employ in order to execute the work in the most efficient manner. He shall not modify such methods without the approval of the Engineer-in-Charge. This approval, however, shall not in any way make the Engineer-in-Charge responsible for any consequent loss or damage.

2.2.2. Should any excavation be taken down the specified levels, the Contractor shall fill in such excavation at his own cost with concrete as specified for foundations, well rammed in position until it is brought up to the specified level.

2.2.3. The Contractor shall notify when the excavation is completed and no concrete or masonry shall be laid until the soil for each individual footing, rafts etc. is approved.

2.2.4. The Contractor shall keep the site clear of water at all times. To this end he shall provide arrangements for bailing and pumping or any special arrangements as required within his quoted prices.

2.2.5. All foundation pits shall be refilled to the finished ground level (formation level) with approved materials, which shall be suitably consolidated in layers to the satisfaction of the Engineer-in-Charge.

2.2.6. Nothing extra will be paid for bailing out water collecting in excavation due to rains, ordinary springs, leakage from any other sources etc., or any other reason.

2.2.7. For the work of excavation the Bidder shall include in his quotation the shoring, sheeting, bracing and sheet piling (if required). The quotation shall also include the cost of

compaction of foundation sub-base, removal and storage of excavated materials and back filling.

2.3 SHORING:- Timber shoring whenever required shall be closed boarded with minimum 50mm thick good and seasoned timber planks of sufficient length driven side-by-side to the required depth. The gaps between adjacent timber planks shall such would not allow any flow of soil particles, if necessary, the sides of the planks shall be planed smooth to ensure this. Sufficient numbers of bracing struts, walling etc. are to be provided to make the shoring rigid and non-yielding by earth pressure. Where necessary, sheet piling shall be done to ensure safety to the adjoining structures, if it is found that it is not feasible to protect the structure by timber shoring only. The Bidder is strongly advised to inspect the site before tendering and apprise himself of the requirement of any Sheet piling in addition to the timber shoring before submitting his Quotation accordingly.

2.4 BACK FILLING

The space around the foundations in trenches or sites shall be cleared of all trash and loose debris and filled with approved excavated earth, all clods being broken up to the finished G.I. Filling shall be done in 200mm layers, each layer to be properly moistened and well rammed. Any Excavated materials which is surplus or which is consolidated unsuitable for back filling is to be disposed of in spoil dumps as directed by the Engineer-in-Charge. No extra payment will be made for this.

3.0 CONCRETE

3.1 GENERAL

3.1.1 Applicable provisions of Conditions of Concrete shall govern work under this section.

3.1.2. All concrete work, plain or reinforced shall be carried out strictly in accordance with this specification and any working drawing or instructions given from time to time to the Contractor.

3.1.3. The Contractor's states shall allow for wastages in all materials as well as for all tests of materials and concrete.

3.1.4. No concrete shall be cast in the absence of the Engineer-in-Charge or any other person duly authorized by him. The Contractor's Engineer shall personally check that both the form work and reinforcement have been correctly placed and fixed, and shall satisfy himself that all work preparatory to the casting is completely ready, before informing the

Engineer-in-Charge for final inspection and approval and for which purpose at least 24 hours' notice shall be given by the Contractor.

3.1.5. The Indian Standards wherever referred to herein shall be the latest addition of such standards.

2.3 CEMENT

Cement shall conform for IS: 12269; 1987 Cement tests shall have to be carried out at Contractor's expense as and when directed. Cement, which has or practically set, shall not be used under any circumstances. The important structures should be constructed with the grade of cement not below 53 (Grade-53). No extra payment will be made for using Grade-53 cement or more grades available in departmental store.

The brand of cement will be of Lafarge Concreto / Ambuja Plus / Ultratech Premium / ACC F 2 R make.

2.4 AGGREGATES

The fine and coarse aggregates shall conform to all provisions and test methods of IS: 383 and/or IS: 515. Samples of aggregates, proposed to be used in the work shall be submitted free of charge in sufficient quantities to the Engineer-in-Charge with sieve analysis and other physical and chemical analysis data for his approval. He will preserve approved samples for future reference. This approval will not in any way relieve the Contractor of his responsibility of producing of specified qualities.

2.5 COARSE AGGREGATES

Coarse aggregates for use all reinforced and other plain cement concrete works shall be crushed black granite trap stone obtained from approved source and shall consist of uncoated, hard, strong dense and durable pieces of crushed stone, and be free from undesirable matters, viz. Disintegrated stones soft, friable, thin, elongated or laminated pieces, dirt, salt, alkali, vegetable matter or other deleterious substances. The aggregates shall be thoroughly washed with water and cleaned before use to the satisfaction of the Engineer-in-Charge at no extra cost of the Employer.

The maximum size of coarse aggregates shall be as follows unless specified otherwise elsewhere.

Reinforced Concrete : 20 mm

Plain Concrete	:	20 mm
Thin R. C. C. Members		
With very narrow space	:	12 mm.
Mat/Lean Concrete	:	20/40 mm.

(The actual size to be agreed by the Engineer-in-Charge)

Grading of coarse aggregates for a particular size shall generally conform to relevant I.S Codes and shall be such as to produce a dense concrete of the specified proportions and or strength and consistency that will work readily in position without segregation.

2.6 FINE AGGREGATES

Sand shall be clear River sand brought from approved source and consist of siliceous material, having hard, strong, durable uncoated particles, free from undesirable matters viz. dust lumps, soft or flaky particles or other deleterious substances. The amount of undesirable shall not exceed the percentage limits by weights as specified in relevant IS Codes. Washing of aggregates by approved means shall be carried out, if desired by the Engineer-in-Charge, at no extra cost to the Employer.

Coarse and fine sand shall be well graded within the limits by weight as specified in relevant IS Code. Fineness Modulus shall not vary by more than plus or minus 0.20 from that of the approved sample. Fineness Modulus for sand should not be less than 2.5.

3.0 REINFORCEMENT: - REINFORCEMENT WILL BE OF SAIL / TATA / RINL MAKE

3.1 The Contractor shall prepare and furnish to the Engineer-in-Charge, Bar Bending Schedules in considerations of the approved drawings for all R.C. C. works for review and checking by the Engineer-in-Charge well before taking up the work.

3.2 The High Yield strength deformed bar (HYSD) shall conform to IS: 1786-1990. All steel for reinforcement shall be free from loose, oil, grease, paint or other harmful matters immediately before placing the concrete.

3.3 The Reinforcement shall be bent to the shapes shown on the approved drawings prior to placing and all bars must be bent cold. The Steel shall be placed in such a way that it is rigidly held in position while concrete is being cast. The correct clearance from the form

shall be maintained by either pre-cast mortar blocks or by metal supporting chairs to be supplied by the Contractor free of charge.

The intersection of roads crossing one another shall be bound together with soft pliable with No. 16 to 18 SWG at every intersection so that reinforcement will not be displaced in the process of depositing concrete. The loops of binding wire should be tightened by pliers and welding of reinforcement for lapping & binding should be done if desired by E.I.C. No extra payment will be made for this purpose.

3.4 The work of reinforcement shall also be inclusive of stirrups distribution bars, binders, initial straightening and removing of loose rust, if necessary, cutting to requisite length, hooking and bending to correct shape, placing in proper position including supplying and binding with block annealed wire as stated in clause 3.4.3 above.

3.5 The brand of steel used for the work will selected & approve by the E.I.C in writing before execution of work.

3.5 WATER

The Water shall be clean and free from Alkali oil or injurious amounts of deleterious materials. As far as possible, the water is of such quality that it is potable. If any chemical analysis of water is necessary and ordered, the same shall be carried out at an approved laboratory at the Contractor's cost and expenses.

3.6 CONCRETE PROPORTIONING

3.6.1 The concrete proportions shall be as indicated on the approved drawings and shall conform to IS: 456 & IS: 3370. The quality and character of concrete shall be governed by IS: 383. It should be sampled and analyzed as per IS: 1199. The concrete should stand the test specified in IS: 516.

3.6.2 The minimum cover of main reinforcement shall be as per relevant IS: Codes. Cover to any reinforcement of R.C.C. piles shall be minimum 65 mm in case in-situ and 50 mm in case of pre-cast piles. Suitable spacer blocks shall be provided at intervals not exceeding 1.2 m. throughout the length of the pile.

3.6.3 The workability shall be measured by slump. Slump for different grades of concrete shall not exceed following unless specifically permitted by the Engineer-in-Charge.

i) For M 15 concrete - 3.75 cm.

- ii) For M 20 concrete - 2.50 cm.
- iii) For M 25 concrete – 2.00 cm

3.6.4 All concrete works shall be thoroughly compacted and fully worked around the reinforcement, around embedded fixtures and into comers of the form work.

The Concrete shall be thoroughly and shall be efficiently vibrated during laying. The use of mechanical vibrators shall comply with IS: 2608, IS: 2506 and IS: 4656. Whenever vibration has to be applied externally, the design of formwork and deposition of vibration shall receive special consideration to ensure efficient compaction and to avoid surface blemishes.

3.6.5 TEST FOR WATER TIGHTNESS OF STRUCTURES / PIPES

For liquid retaining structures including inlet chambers etc. shall be deemed to be satisfactory water tight as per relevant clause of IS: 3370. The Contractor at his own expenses, if necessary, shall undertake approved corrective measures.

As regards the pipelines, the tests shall be performed for the Hydrostatic Pressure of 10 Kg./Sq. cm in case of S.W.M., D.I. Pipes and 2 Kg./Sq. cm. for P. S. C. respectively. The tests shall be carried out as per relevant IS Codes and pipes shall be considered satisfactory if the tests results satisfy the requirements of the relevant clauses of the Codes. The Contractor shall give all these Hydraulic Tests by making his own arrangements for water supply and filling and disposing the water after the tests. The Contractor shall rectify the defects noticed and carry out the tests again and repeat the testing operation till successful result is obtained and accepted by the Engineer. The rates Quoted for the work shall be considered as inclusive of cost of all Labour, materials and equipment required to give successful tests for Water tightness.

3.7 WORKMANSHIP

3.7.1 All Concreting work shall be carried out according to the IS: 456, IS: 3370, and other related codes. It should, however, be noted that for every 15 M3 of concrete placed or for every one day's volume of concrete whichever is lower, a minimum of 3 (three) Cubes shall be kept for test purpose, and tested at the Contractor's cost and expenses at a Laboratory as approved by the Authority. The number of test cubes may, however, be

altered at discretion of the Engineer-in-Charge. It is compulsory to test 3 (three) cubes in each case.

3.7.2 STRUCTURAL CONCRETE: - Design mix Concrete shall be on all concrete works except in case of Mud-mat concrete lean concrete where nominal mix concrete will be allowed. Design mix Concrete will be used in Reinforced Concrete Structures shall be in Grade of M20, for works other than water training structure & water retaining structure Grade of concrete as per latest amendment of IS:3370. The mix shall be designed to produce the grade of concrete having required workability and a Characteristic Strength not less than appropriate values given in IS: 456 - 2000. For mix design, procedure given in Indian Standard recommendation or any other standard procedure shall be adopted. As long as the quality of materials does not change a mix design done earlier may be considered adequate for later work. Batching mixing, sampling and Strength Test of concrete shall be carried out in compliance with the relevant clause of IS: 456-2000 and all other relevant Indian Standards recommended therein.

The mix design by the Contractor shall be used for works only after obtaining written approval of the Engineer-in-Charge. Mix design shall be entirely the responsibility of the Contractor and any approval by the Engineer-in-Charge shall not relieve him of his responsibility in respect thereof.

The Contractor shall prepare all the Calculations, Tabulations, Graphs etc. pertaining to Mix Design Test result and supply copies of such Calculations, tabulations, Graphs etc. required by the Engineer-in-Charge.

On proportioning concrete, the quantity of both cement and aggregate shall be determined by weight, where the weight of cement is determined on the basis of weight per bag a reasonable number of bags be weighed periodically to check the net weight or should be either weighed or measured by volume in calibrated tanks, All measuring equipments shall be maintained in a clean serviceable condition and shall periodically checked for accuracy.

The grading of coarse and fine aggregates shall be checked frequently and frequency of testing shall be determined by the Engineer-in-Charge. Where weight batching is not possible or practicable, the quantities of coarse and fine aggregates may be determined by volume but cement in any case shall be weighed by weight only. If fine aggregate and volume batching is adopted, allowance shall be made for bulking. The bulking shall be determined in accordance with IS: 2386 (Part-III).

The Water-Cement Ratio shall be maintained to its correct value. Surface moisture content of aggregate shall be determined as per IS: 2386 (Part-III) and the amount of water to be added shall be adjusted accordingly to maintain the correct Water-cement ratio.

During the progress of work in order to ensure correct strength of concrete proper control should be exercised by the Contractor as specified in Specifications mentioned in the Clause 3.7.1 above. Test strength of every sample shall be determined in accordance with the recommendations of IS: 456-2000. If one out of ten consecutive test cubes shows a deficiency in strength up-to a maximum limit of 10%, the concrete will be deemed satisfactory. If two of the test cubes out of ten shows a deficiency in strength up to a limit of 10%, the concrete shall be deemed to be less satisfactory and a reduction of 1 % will be made on the cost of such concrete. If three out of ten test cubes show deficiency in strength up to a limit of 10%, a reduction of 5% will be made on the cost of such concrete. If more than three test cubes show a deficiency in strength up-to a limit of 10% a reduction of 10% will be made on the cost of such concrete. If more than five shows a deficiency in strength up-to a limit of 10%, the concrete shall be rejected. Such rejected concrete work shall have to be dismantled and replaced to the satisfaction of the Engineer-in-Charge by the Contractor free of cost to the Employer. No payment for the dismantled concrete, the relevant formwork and reinforcement, embedded fixtures etc. wasted in the dismantled portion, shall be made. In the course of dismantling, if any, damage is done to the embedded items or adjacent structures, the same shall also be made good free of charge by the Contractor to the satisfaction of the Engineer-in-Charge.

If the deficiency in strength of one-test cubes exceeds the 10% limit, a reduction of 5%) will be made on the cost of such concrete. if the deficiency in strength to two out of ten test cubes exceeds the 10% limit, a reduction of 10% will be made on the cost of such concrete. If the deficiency in strength of three out of ten test cubes exceeds the 10% limit, a deduction of 20% on the cost of such concrete will be made.

With permission of the Engineer-in-Charge for any above mentioned grades of concrete, if the quantity of water has to be increased in special cases, cement shall also be increased proportionally to keep the ratio of water to cement same as adopted in trial mix design for each grade of concrete. No extra payment for additional cement will be made.

3.8 PRE-CAST CONCRETE

Pre-cast Concrete items shall conform to relevant IS Specifications. Pre-cast items shall be suitably marked with the date of casting identification marks and shall show the right way up as may be required. The arrangements to be made by the Contractor for Site manufacture and handling of pre-cast items shall be done to the approval of the Engineer-In-Charge. Each pre-cast unit shall be cast in one operation and no construction joints shall be permitted. No damaged or defective units shall be built into the works and units shall be so stored that they are not over' stressed.

Pre-cast units shall be provided in places as shown in the approved drawings. The pre-cast units shall be cast at site strictly following the Specifications of Pre-cast Concrete work. Proper care shall be taken to ensure that the units are obtained from the moulds without any damage. Before erecting in position the units shall be cured adequately by keeping units immersed in water.

3.9 FRAME WORK

3.9.1. The Form Work shall conform to IS: 456. Whenever necessary, shuttering must be provided. The work shall also include providing all necessary staging, centring, formwork and moulds for placing concrete. Shuttering may be of approved dressed timber true to line, not less than 37 mm. thick. Surface to be in contact with concrete are to be planed smooth. Alternatively, sufficiently rigid plywood shuttering or steel shuttering may be used. In every case, joints of the shuttering are to be such as to prevent the loss of liquid from the concrete. In timber shuttering the joints shall, therefore, be either tongued or grooved or the joints must be perfectly close and lined with draft paper polythene films or other types of approved materials. In case of plywood or steel shuttering also the joints are to be similarly lined. All shuttering and framing must be adequately stayed and braced to the satisfaction of the Engineer-in-Charge for properly supporting the concrete, during concreting and the period of hardening. It shall be so constructed that it may be removed without shock or vibration to the concrete. No through bolts are allowed for holding the shuttering in water retaining structure.

3.9.2 CLEANING, TREATMENT AND REMOVAL OF FORMS

All forms shall be thoroughly cleaned of old concrete, wood shavings, saw dust, dirt and dust sticking to them before they are fixed in position. All rubbish loose concrete chippings, shavings, saw dust etc. shall be scrupulously removed from the interior of the

forms before the concrete is poured. Formwork shall not be used/reused, if declared unit or unserviceable by the Engineer-in-Charge.

If directed by the Engineer-in-Charge, compressed air jet/or water jet shall be kept handy along with wire brushes, brooms etc. for the purpose of cleaning.

Before shuttering is placed in position, the form surface in contact with the concrete shall be treated with approved non-staining oil or composition. Care shall be taken that the oil or composition does not come in contact with reinforcing steel or existing concrete surface. They shall not be allowed to accumulate at the bottom of the shuttering.

Forms shall be struck in accordance with the relevant clause of IS: 456 or as directed by the Engineer-in-Charge. The Contractor shall record on the drawings or in other approved manner, the date in which the concrete is placed in each part of the work and the date on which the form work is removed there from and have this recorded checked and countersigned by the Engineer-in-Charge.

The Contractor shall be responsible for the safe removal of the formwork, but the Engineer-in-Charge may delay the time of removal if he considers it necessary. Any work showing signs of damage through premature removal of formwork or loading shall be entirely reconstructed without any extra cost to the Employer.

3.10 PROTECTION AND CURING OF CONCRETE

Newly placed concrete shall be protected by approved means; from rain, sun and wind and extreme temperature. Concrete placed below the ground level shall be protected from falling earth during and after placing. Concrete placed in ground containing deleterious substance shall be kept free from contact with such ground or, with water draining from such ground during placing of concrete and for a period of at least 3 (three) days or as otherwise directed by the Engineer-in-Charge, the ground water around newly poured concrete shall be kept to an approved level by pumping or other approved means of drainage at the cost of the Contractor. Adequate steps shall be taken to prevent flotation or flooding. Steps, as approved by the Engineer-in-Charge, shall be taken to protect immature concrete from damage by debris, excessive loading, vibration, abrasion, mixing with earth or other deleterious materials, etc. that may impair the strength and durability of the concrete.

As soon as the concrete has hardened sufficiently for the surface to be marked it should be covered with Hessian, canvas, or similar materials and kept continuously wet for at

least 7 (seven) days after final setting. This period may be extended at the discretion of the Engineer-in-Charge, up-to 14 (fourteen) days. Concrete slabs and floors shall be cured by flooding with water of minimum 25 mm depth for the period mentioned above.

Approved curing compounds may be used in lieu of moist curing with the permission of the Engineer-in-Charge. Such compound shall be applied to all exposed surface of the concrete as soon as possible after the concrete has set. No extra payment is allowed on such count.

3.11 CONCRETE FINISH

The Concrete surface on removal of form work shall be such that no finish is necessary, If, however, the surfaces is not satisfactory the Contractor shall, if so instructed, remove unwanted, projecting parts by chipping and smoothing the surface with cement rendering at his own expenses. The shutter marks shall invariably be removed by rubbing with carborandum stone. The Contractor shall therefore take all precaution for avoiding the shutter marks.

3.12 CONSTRUCTION JOINTS

These shall be in according with IS: 337 or as directed.

3.13 Expansion Joints: - Expansion joints shall be provided at position as directed and the spacing shall not exceed the limits specified in IS: 456. These shall comply strictly with the details shown on approved construction drawings. Reinforcement shall not extend across any expansion Joint and the break between the two sections must be complete.

3.14 Details of typical expansion joints and construction joints should comply with the suggestive arrangements shown in IS: 3370 (Part-I), Clause 8.1 (a)(2), Figure 2 (for expansion Joints) and Clause 8.1(a) Figure 1, Clause 8.1 (b) Figure 4 (for construction joints).

3.15 PVC WATER STOPS: - The materials shall be durable and tough and as per approval of the Engineer-m-Charge. The minimum thickness of PYC sealing strips shall be 6 mm. and the minimum width 225-mm actual shape and size shall be as per drawings. The materials should be of good quality polyvinyl chloride highly resistant to learning abrasion and corrosion as well as to chemicals likely to come in contact with during use. The physical properties will generally be as follows:

Specific Gravity	1.3 to 1.35
Shore Hardness	60 A to 80 A
Tensile Strength	100 to 150 Kg./Cm ²
Minimum Safe Continuous Temperature	75 ⁰ C
Ultimate Elongation	Not less than 275%
Water Absorption	Not more than 5% by weight in a 7 day test.

3.16 RUBBER WATER STOPS

The materials must be very durable and tough and as per approval of the Engineer-in-Charge. The ribs shall be sufficient to ensure proper bonding with concrete. The width shall be minimum 225 mm and thickness minimum 6 mm. The rubber water stop must be used in long lengths to avoid splicing as far as practicable. Ends shall have at least 200 Cu M overlaps and vulcanised. The materials shall be natural rubber and be resistant to corrosion tear and also to attacks from acid, alkalis and chemicals normally encountered in service. The physical properties will generally be as follows:-

Specific Gravity	1.1 to 1.15
Shore hardness	65 A to 75 A
Tensile Strength	250 to 300 Kg/ Cm ²
Maximum safe continuous temperature	750C
Ultimate elongation	Not less than 350%
Water Absorption	Not more than 350% by weight in a 7 day test

3.17 CONTRACTOR'S SUPERVISION

The Contractor shall provide constant and strict supervision of all the items of construction during progress of work, including the proportioning and mixing of the concrete and bending and placing of reinforcement. Before any important operation, such as concreting or stripping of form work adequate notice shall be given.

The cement and sand shall be thoroughly mixed dry in specified proportions. Water shall then be added just sufficient to make a stiff and workable paste. The mortar shall be used within half an hour of mixing.

4.1 The Contractor shall build all brickwork uniformly no one portion being raised more than 1 meter above another at a time. The joints shall not exceed 12 mm. in thickness and should extend the full thickness of the brickwork. All joints shall be properly raked and the surface washed down.

4.2 All the bricks shall be kept fully immersed in water at least for a minimum period of six hours till they are completely soaked and only thoroughly soaked bricks shall be used in the work.

4.3 The Contractor shall keep wet all brickwork for at least 10 (ten) days after laying. The surface of unfinished work shall be cleaned and thoroughly wetted before joining new work to it.

5.0 PLASTERING, PAINTING AND SURFACE TREATMENT

5.1 CEMENT PLASTER

5.1.2 The plastering work shall be governed by IS: 1661. Unless otherwise specified cement plaster shall be composed of 1 part of cement and 6 parts of sand. For ceiling plaster, the composition shall be 1 part of cement and 4 parts of sand. The thickness of ceiling plaster shall be 6 mm. The thickness of plaster to the fair faces of brickwork shall be 19 mm. The thickness mentioned shall be minimum thickness. The Contractor shall allow in his rate for any rubbing out due to inequalities of brickwork.

5.1.2 The rate shall also include for forming of any moulding drip course etc., and for extra thickness due to corbelling of brick work in parapet or at any other place, If required, all internal angles shall be rounded off as per drawing or as directed by the Engineer-in-Charge without any extra charges.

5.1.3. Cement and sand shall be measured and mixed dry thoroughly to a uniform colour on a platform specially constructed for the purpose. Care should be taken to see that no foreign matters get mixed with the mixture. Only enough water shall be mixed to make the mixture workable. The mix shall then be turned over and again to a uniform colour and

texture number more cement mortar shall be mixed at a time than cannot be used within thirty (30) minutes of mixing.

5.1.4. Surface to be plastered are to be brushed clean, wetted for 24 hours before the plaster is put in and the joints of the brick work raked out 12 mm. deep minimum. The concrete faces to be plastered shall be chipped, roughened and soaked with water for achieving required bond with the plaster without any extra cost.

5.1.5 The surface of the plaster shall be finished absolutely in one plane. The Contractor shall rub down any unevenness with carborandum stones at his cost and expenses. Care shall be taken to see that no mark remains at the junction of plastering done at different times. If necessary, the junctions shall be rubbed with carborandum stones to eliminate such undesirable marks. The Contractor may be required to use normal sprinkling of thin cement slurry on the surface for satisfactory finishing of the plastering work for which no extra payment shall be made.

5.1.6 Plaster shall be protected and cured by keeping it thoroughly wet with sprinkling of water for 10 (ten) days continuously.

5.1.7 The cost of plastering work shall also include the cost of necessary scaffolding, staging etc. as would be required for the work.

6.0 SURFACE FINISHING

6.1 GENERAL :- The cost of all the items of work under this section should include the cost of necessary scaffolding, staging, preparing sub base, removing stains from the floor, skirting, wood work, glass etc. caused through execution of the work.

6.2 APPEX Emulsion Exterior & Interior Distemper colouring

6.2.1 APPEX Emulsion Exterior & Interior distemper colouring shall be done with approved make of colouring as per direction of Engineer-in-Charge. The surface of the wall is to be brushed thoroughly cleaned before the colouring is applied. Each coat of colouring has to be laid on with brushes. Each coat of colouring means one continuous strike of brush with the prepared wash from top downwards. Another similar strike bottom upward over first strike followed by another similar strike from right to left and another from left to right over the right application of brush before it dries. Each coat must be perfectly uniform when finished and free from brush mark etc.

6.2.2. Three coats of colouring will mean a minimum of 3 (three) coats to produce an opaque white surface to the entire satisfaction of the Engineer-in-Charge. If the surface is blotchy or otherwise unsatisfactory, number of coats shall be applied till the desired effect is produced to the satisfaction of the Engineer-in-Charge without any additional cost.

6.2.3 Interior wall shall be finished by acrylic distemper (two coats) over interior grade acrylic primer as per manufacturer's specification.

6.3 EXTERIOR WALL FINISH

6.3.1 External surface shall be finished with two coats of Protective and decorative acrylic emulsion paint of approved colour, shade and manufacture over acrylic primer. The surface to be finished shall be previously cleaned down to remove loose dust or dirt by use of stiff wire brush. All inequalities to be rubbed down and defects rectified. The surface to be wetted well with water and the surface water is to be allowed to run off. The acrylic emulsion paint to be applied strictly as per manufacturer's specification. The first coat should be well brushed into the surface to form a good bond. Second coat should be applied carefully to give a good finished appearance may be applied by brushing or spraying. Each acrylic emulsion paint application shall be wetted at the end of the day with a fine water spray.

6.4 PAINTING TO STEEL WORKS

6.4.1 Any shop coat of paint shall not be considered as a coat of paint for the purpose of specification.

6.4.2. Ready mixed synthetic enamel paint of 'Jenson & Nicholson' 'British Paints', 'Shalimar Paints or similar other approved make and approved colour and shade shall only be used. The primer shall be red oxide zinc chromate primer (1S: 2074) or any other anticorrosive primer as approved and directed by the Engineer-in-Charge. The Contractor shall furnish the details of paints to the Engineer-in-Charge for approval of paints before commencement of painting work.

6.4.2. The surface to be painted shall be properly cleaned, de-rusted, all loose scales removed and smoothed with emery papers. Then a coat of anticorrosive priming shall be evenly applied. After this has dried up, two successive coats of best quality ready mixed synthetic enamel paint shall be given to the entire satisfaction of the Engineer-in-Charge. Brushes of approved size and make shall only be used for application of paint and use of cloth is definitely prohibited.

7.0 DAMP PROOFING WORK

7.1. Unless otherwise specified, damp proof course shall be 25-mm thick cement concrete (1:2:4) with stone chips graded 10 mm to 3 mm with 3% cico or similar approved water proofing compound conforming of IS: 2645 by weight of cement. The proportioning, laying etc., shall be done in conformity with specification for cement concrete work. The damp proof course shall be used for all brick walls of the building.

8.0 ROOF WATER PROOFING TREATMENT

8.1. Both flat and curved roofs, whether accessible or inaccessible, shall have to be provided with polyurethane based water proofing paint. Specification for Roof Water Proof Treatment with Polyurethane based Water Proof Paint

8.2 PREPARATION OF SURFACE: - The top surface of the roof shall be chipped off where necessary and all loose particles, dust impurities, are to be removed by rubbing the entire roof surface with wire brush and by application of High Pressure Compressed Heated Air to have a complete dust free and moisture free surface.

The roof surface, receiving polyurethane based Water Proofing paint, shall be provided with cement punning having smooth finish. A cross slope of 1 in 300 shall be provided in the roof of Building to allow proper drainage of rainwater.

8.3 SPECIFICATION OF MATERIALS: - The polyurethane based paint is essentially an elastic and water proof film having a good adhesion to concrete; water and abrasion resistant properties and shall have long term weather proof characteristics. The paint / film material shall be of two components which are to be mixed and processed as per manufacturer's specification. The mixture shall be homogeneous before applications, as it has tendency to settle.

The polyurethane based water proofing system shall be manufactured by reputed manufacturers of proven record and shall be approved by the Central Building Research Institute (CBRI)/ National Chemical Laboratory (NCL)/ The Council of Scientific and Industrial Research/New Delhi (CSRI)/ National Test House, Kolkata or similar such Government/ Public Sector Undertakings. The materials are to be inspected / approved by the Engineer-in-Charge as per procedure to be mutually agreed upon the agency and in charge of the work.

8.4 Since the product has a very short self-life, the materials are to be used in the work shall not be older than four (4) months from the date of manufacture (i.e. the date of bottling). Necessary Test Certificate of CBRI/NCL/CSIR/National House etc. are to be furnished by the contractor or the Department, for the materials procured for the water proofing work.

8.5 APPLICATION: - The two components of polyurethane based water proofing system should be mixed as per manufacturer's specification before application. The tack coat should be applied by brushing or roller to the entire surface in normal temperature and 406 hours setting time should be allowed before application of the second coat. The record and final coat of polyurethane based mixed waterproofing sealing over the priming coat to be applied at normal temperature and curing time between 36 to 48 hours should be allowed. The application to be made by technically trained and approved applicators duly certified by the manufacturers.

8.6 GUARANTEE PERIOD

The entire waterproofing job shall be covered with a written guarantee of leak proof performance for a minimum period of 10 (ten) years.

8.7 DEFECTS LIABILITY PERIOD

Ten percent (10%) of the cost of all works shall be retained by the Department for one (1) year from the date of commissioning. Any defect observed during the Defect Liability Period shall be rectified by the Contractor without any extra cost to the Department.

9.0 FLOORING

9.1. Patent Stone Floorings shall be 25mm. thick in M20 grade concrete with 10mm. to 6mm. stone chips laid in rectangular panel with diagonal length not exceeding 3.00M and finished smooth with neat cement punning 1.5mm thick. After finishing, the surface shall be left undisturbed for two hours and then with wet bags and after 24 hours cured by flooding with water and kept wet for at least 7 (seven) days. Required Camber or Slope should be provided in floor draining wash water, if necessary.

9.2. Cast-in-Situ Mosaic in floor shall be 25mm.thick (finished) laid in panels as directed with necessary underlay of cement concrete (1:2:4) with stone chips with 12mm. thick terrazzo topping finished to 9 mm. after final grinding with 0 to 10 mm. size Mosaic chips highly polished etc. - complete as per specification of IS; 2114-1962. Cast-in-situ Mosaic

in Skirting and dado shall be 12mm. thick. The Mosaic work shall be of approved colour and to the entire satisfaction of the Engineer-in-Charge.

9.3. 'Ferro site' or 'Ironies' Flooring shall be 50 mm. Thick to be laid in two layers. First a layer of 25mm. thick patent stone flooring shall be laid in M20 grade concrete and allowed to dry. Then the second layer of 25mm.thick flooring of M20 grade concrete with 10mm.to 6mm. stone chips using at least 1Kg. / sq. m. of floor hardening compound of approved quality and make shall be laid and cured. The flooring shall be laid in rectangular panel with diagonal length not exceeding 3.0 meters.

10.0 IRON MONGERY: - 10.1. The rain Water pipe of the materials and of size as specified shall be of approved manufacture end jointed as follow:

10.1.1 For heavy cast iron pipes with gasket and lead properly caulked.

10.1.2. Where required these are to be run in chase left out in walls, columns, slabs and to be encased in cement concrete 1:2:4 (1 Cement, 2Sand 4 washed Stone Chips 19mm. down) with metal wrapping or with M.S: loops placed at approximately 325mm centre to centre or as directed by the Engineer-in-Charge. All pipes encased in walls, columns or under floors must be heavy cast iron with lead caulked joints. For exposed lengths of pipes, these are to be neatly secured clear from the finished wall face with nails and bobbing in the case of cast iron pipes, nails or screwed to hard wood tapping pugs embedded in wall.

10.1.3. All cast iron rain water pipes shall be painted two coats inside with approved anticorrosive paint. The exposed cast iron pipes shall be painted outside with two coats of ready mixed Synthetic Enamel Paints of approved makes, shade and colour over a coat of priming of approved make.

10.1.4. The mouth of rain water pipes shall be fixed with C.I grating and the pipe jammed in position in 1:2:4 cement concrete with stone chips and neat finish on the surface.

10.1.5. The work shall include all supply, fitting and fixture of materials cutting, making chases, encasing, painting, jointing, etc. complete in all respect. The work shall include supplying, fitting, fixing, and jointing of all the specials required for the completed work.

10.1.6. Rain water Spouts shall be of C.I pipes cut to exact length as per approved drawing or direction of the Engineer-in-Charge and laid in position in 1:2:4 cement concrete with stone chips, adjoining roof being finished in neat cement. The interior faces

shall be painted two coats with anticorrosive paint and the faces shall be painted with two coats of ready mixed Synthetic Enamel paint of approved make, shade and colour over a coat of priming of approved make.

10.2 METAL CASEMENT

10.2.1. Unless specified otherwise, all doors, windows and ventilation in general should be of mild steel casement with sections as per IS: 1038. They shall be of approved make. The Contractor will submit the name and address of the manufacturer whose metal casements he intends to use for approval of the Engineer-in-Charge. The workmanship shall be of high quality and shall be up to the entire satisfaction of the Engineer-in-Charge.

10.2.2 All the steel doors and windows sashes shall be given a shop coat of Red Oxide Zinc Chromate Primer IS: 2070 after these are thoroughly cleaned off dust, dirt, scales etc., and passed after inspection by the Engineer-in-Charge.

10.2.3. Windows are to be prepared for puffy glazing from the outside and for opening outwards unless otherwise mentioned. All steel sashes shall have holes drilled at suitable places for inserting glazing clips which shall also be supplied by the Contractor All glazing shall be fixed to the shutters or frames in addition to glazing clips with quality putty of Shalimar or equivalent make. Glass must not be placed directly against the metal. A thin layer of putty must be evenly spread over the glazing rebate and the glass pressed firmly against it.

10.2.4. Ventilators shall be constructed from solid rolled universal casement section being double weathered at all points to ensure water tightness and bedded in mastic and screwed to the sashes.

10.2.5. The fitting shall be of heavy pattern bronze oxidized brass and of approved quality, side hung casement will have two point locking handle and casement fasteners. The hung windows shall have 200mm. long adjustable casement stay, arrange to lock the windows from inside horizontally at the centre, hung windows shall have spring catch designed for hand cord or pole operation as approved by the Engineer-in-Charge. The fittings to be fitted either by screwing to the window sections or to steel bracket welded to the window section as approved by the Engineer-in-Charge.

10.2.6. Galvanized weather bars shall be provided to sills of all windows.

10.2.7. Metal casement is on no account to build in at the time the walls are constructed. Holes to accommodate the fixing lugs are to be left or cut and the casement fixed after all rough masonry plaster works have been finished. The lugs of the casement shall be jammed in 1:2:4 cement concrete with stone chips after holding the casement in proper position, line or level.

10.2.8. Glazing for windows and ventilators shall weight not less than 8.0 Kg. /Sq. m for doors; 6mm thick wire net reinforced glazing shall be used as approved by the Engineer-in-Charge. The glasses shall be cut to size accurately to suit all openings to glaze with slight margin of about 1.50mm on all sides or as directed. These shall be securely fixed in position in the manner described earlier. On completion of the building, the Contractor shall clean all the glass and leave the same perfectly in a tidy condition.

10.2.9. The cost of marginal doors, windows and ventilations shall include supplying fixing, fitting, glazing cleaning, necessary scaffolding, staging etc. and shall be for the complete work in all respects to the satisfaction of the Engineer-in-Charge.

10.2.10. The Contractor shall without any extra charge, submit three sets of shop drawings from the manufacture showing full details of each type of doors, windows and ventilators including section, position of all fittings and fixtures for the approval of the Engineer-in-Charge before manufacture and finally six sets of approved final drawings with notes on the method of fixing.

10.2.11. Where specified, mosquito fly proof brass wire screen of approved gauge and mesh shall be used in combination with windows. The screen shall be fixed to the inside of the frames and the windows to be opened outside and be fitted with 'Flow operator' for opening to any position and closing. Additional intermediate members are fixed to the frames to receive the fly screen so that the clear span of the screen does not exceed 300 m or as approved by the Engineer-in-Charge.

10.2.12. All windows shall be provided with grills of approved design made of 25 mm x 6 mm M.S. Flats and the other clean openings not exceeding 100 mm.

10.2.13. The work for metal casements shall also include the cost of painting with 2 coats of ready mixed synthetic enamel paint of approved make, quality colour and shade over a coat of approved anticorrosive primer.

10.3 COLLAPSIBLE GATE: - The M.S. collapsible gates will be obtained from manufacturer as approved by the Engineer-in-Charge. These shall be of mild bar type, out

of 20 mm. channels and shall be top hung with roller bearing and shall have locking arrangement. Collapsible gates under 2.700 m height shall be with 4 sets of lattices. Guide tracks shall be to the entire satisfaction of the Engineer-in-Charge. The gates shall be fixed in position, de-rusted, discaled and painted with 2 "coats of approved ready mixed paint over a coat of approved anticorrosive primer.

10.4 ROLLING SHUTTER

10.4.1. The M.S. roller shutter shall be obtained from manufacturer as approved by the Engineer-in-Charge. The roller shutter shall be of 18 G x 75 mm galvanized mild steel lath of convex corrugation complete with one piece construction. These shall be fitted with pressed side guides and pressed bottom rail, brackets, door suspension shafts, top rolling springs (of strong English Continental Spring Steel Wire) with a four lever concealed lock as also separate locking arrangements for padlocks, pulling hooks, handles and top cover. The roller shutters shall be fixed in position with all accessories and the workmanship shall be to the entire satisfaction of the Engineer-in-Charge. This shall be finished with two coats of approved read/ mixed paint over a coat of approved anti corrosive primer.

11.0 STRUCTURAL STEEL WORK

11.1. All Structural Steel to be used for gantry beam etc. shall be of tested quality conforming to IS: 226 and IS: 2062 latest addition.

Finished steel shall be free from cracks, lamination and other visible defects. Section shall be adequately protected from rusting and scaling. Rivets and bolts, nuts and washers shall be of mild steel and comply with requirements of relevant IS Codes. Steel used for rails shall have tensile strength of about 50-60 Kg/Sq. mm. and yield point at 26 Kg/Sq. mm. The electrodes for welding shall conform to IS: 814. All steel work shall be fabricated and erected as per IS: 800 and IS: 806. Welding shall be carried out as per IS: 814, IS: 815, IS: 816 and IS: 823, all of the latest editions.

11.2. All steel work, after preparation of surface, shall be given a coat of red oxide zinc chromate primer (IS: 2074) and finished with two coats of Synthetic enamel paint. Surface to be painted shall be thoroughly cleaned of mill scale, oil grease, rust etc. over coating and finishing paints shall be of well-known make (vice Jenson & Nicholson/ Berger Paints/ Shalimar Paints). The Contractor shall furnish details of Paints to the Engineer-in-Charge for approval of paints before commencement of painting work.

11.3. Steel work shall be hoisted and erected in position in a safe and proper manner. No riveting or permanent bolting shall be done until proper alignment has been made. For grouting, cement and clean fine sand shall be used in a proportion of 1:2 and properly mixed with water. All trapped pockets shall be fully vented for full penetration of grout. All grouting shall be cured for a minimum period of seven days.

12.0 CABLE TRENCHES

12.1. The cable trenches should normally be of dimension 750mm x 600 mm (D x W) with insert plates made of M.S. of dimension 100 mm x 75 mm x 12 mm (W x D x T) are to be provided on the wall side of the cable trench 600 mm apart all along.

12.2. The Cable Trenches shall be covered with pre-cast concrete slabs of dimension 650 x 600 adequate thickness to withstand a load of 500 Kg/m² are to be provided as covers of trench all along. For easy access of cable from room to room, the design of the tie beam and level of the rooms may be adjusted to avoid bend in the cable.

12.3. The cable trenches shall be absolutely free from any obstructions as to allow the cables to be lowered in the trenches from top only during laying. The space inside the trenches throughout the entire lengths shall in no case be encroached by any beam or columns.

13.0 POCKETS & HOLDING DOWN BOLTS

Provision has also to be kept for pockets and holding down bolts as per requirement of the electrical and mechanical equipment's at no extra cost. The exact details of such pockets and holding down bolts will be supplied to the Contractor as per specifications of the suppliers of the equipment after award of the contract. It is contemplated that M.S. hangers shall be provided from the underside of slab/beam of the operating floor, and is to be executed in a separate contract. However, for the above arrangement suitable pockets and holding down bolts are to be left.

14.0 CHEQUERED PLATES ETC.

These shall be manufactured from structural steel conforming to IS: 226. They shall be of the specified size, thickness and pattern as per relevant drawings or as directed by the Engineer-in-Charge. Cover plates will generally be of Chequered plates with or without stiffeners as detailed in the drawings. For convenience, the Contractor shall prepare detailed floor plans of the layout of cover plates for floors and platforms so as to include all

openings, cuts etc. and so as to match the patterns of adjacent cover plates/gratings. Where necessary, the floor will have to be made leak proof by properly welding cover plates. If necessary, packing shall be welded to the bottom of cover plates to raise the cover plates on sides, so as to provide necessary slopes as shown in the drawings or as directed by the Engineer-in-Charge in the floors and platforms to drain away any liquid falling on the floors and platform. Necessary gutters at the ends of platforms shall be provided for sloping floors and platforms as shown in the approved drawings or as directed by the Engineer-in-Charge. Krebs of flats shall be provided where necessary, around openings and cuts in order to prevent liquids falling to lower floors or platforms.

15.0 HAND RAILING

Double rows of 32 mm diameter G.I. (TATA Medium) tubular hand railing fixed in G.I. stanchions shall be provided on the edge of walkways and platforms as specified. The stanchions shall be fixed with mild steel rag bolts with chromium plated cap nuts. The stanchions shall not be less than 1000 mm. high and placed at a distance not exceeding 2500 mm. The hand railing shall be fixed true to exact line and level. G.I. stanchions and hand railing layout shall be of architectural design with pleasing appearance.

16.0 SANITARY INSTALLATIONS

16.1. The Urinals shall be of flat back, front lipped having a size of 46.5 cm. x 36.5 x 26.5 cm. or nearest available size. The Indian type W.C. shall be of minimum 58 cm. Complete with footrest in one piece.

16.2. All Sanitary works shall be of "Parry, "Nicer", or any other equivalent make. They shall be of approved quality conforming to relevant IS Codes and shall bear ISI Certification marks. All G.I. pipes shall be of ITC or equivalent make heavy quality conforming to relevant IS Code. Wheel valves and stop cocks shall be of gun metal and of "Leader" or "Annapurna" or equivalent make as approved by the Engineer-in-Charge and shall conform to relevant IS Codes.

16.3. Two urinals, one Indian W.C., one European W.C. (Commode) have to be provided in the toilet block.

17.0 MANHOLE COVERS

Heavy-duty plastic fiber reinforced concrete manhole covers shall be of heavy duty type conforming to IS: 1726.

18.0 TIMBER DOOR

The timber door shall be of 1st. Class CP Teak Wood for both frame (100 mm x 100 mm) and shutters (49 mm thick). All such doors shall be fully panelled. All timber shall be of best' quality, well seasoned and/or well treated for prevention and protection against decay etc. It shall be uniform in substance, straight in fibbers, free from large or dead knots, sap, flaws, sub cracks, shakes, or blemishes of any kind. Any insect damage or spoils across the grain shall not be permissible. The colour of the timber shall be uniform throughout, firm and shining with a silky lustre when placed and shall not emit dull sound when struck. The doors shall be made as per approved drawings and as directed by the Engineer-in-Charge and the timber shall be sawn in direction of the grains and shall be straight and square. The door fittings shall be highly polished as per direction of the Engineer-in-Charge.

19.0 M.S. PIPELINES

M.S. Pipe line (TATA / SAIL make)s in required lengths and should be spiral welded mild steely welded from reputed manufacturers and M.S. specials will be fabricated from the said MSSW pipe or from M.S. Plates cut to exact size and shape, bent true to curvature and welded using standard electrodes after necessary edge preparations. Both the inside and outside surfaces of the MSSW pipes and specials shall thereafter be thoroughly cleaned after de-rusting and brushing. The outside surface shall then be wrapped and coated with a protective coal tar based insulating tape of 4 mm. average thickness as approved over one coat of approved primer leaving 150 mm. on either end of pipes unwrapped. The inside-surfaces will be provided with 3 (three) coats of non-toxic paint over one coat of primer.

The pipes and specials will be lowered in trenches for laying only after testing the same with spark test by holiday detector so as to ensure that the pipes and special are free of holidays. The pipes thus lowered will then be interconnected by welding and the portions of 150 mm. width left unwrapped on either side of pipes will then the wrapped with said insulating tape. The thickness of SWMS pipes and specials of 900 mm diameter shall be 12 mm.

20.0 P.S.C. PIPLINES / N.P.-2 CLASS PIPELINE

P.S.C./ N.P.-2 Class Pipes will be laid on suitably designed 1:3:6 concrete bedding of 150 mm thickness. The pipes will join by rubber rings. Bends and specials will be of mild steel.

The P.S.C./N.P.-2 Class pipes will be joined with M.S. special and machined ends will be wrapped and coated with an approved protective coal tar based insulating tape of 4 mm. average thickness over one coat of approved primer. The inside surface will be provided with 3 (three) coats of non-toxic paint over one coat of primer.

21.0 ELECTRICALLY OPERATED OVERHEAD CRANE

Provisions have to be made for a electrically operated 10.0 M.T. capacity travelling Crane suitable for inching operation with a lift up to motor floor level and longitudinal travel of 12 M for handing pump, motor and other accessories. They shall be of reputed make as per vendor list and as approved by Engineer-in-Charge. Suitable type of crane rails, girders and all other accessories as necessary for installation and operation of the crane are to be designed and provided by the contractor within the Lump Sum pipe quoted. The two travels and two hoists i.e. long cross & main Auxiliary etc. must be mechanical operation. The buffers must be spring-loaded operation. Suitable vertical clearance is to be provided over the rail level to the bottom of the roof beam

22.0 LIGHTNING ARRESTOR AND AVIATION LIGHT

Required sets of Lightning Arrestor and Aviation lighting arrangement shall be provided by the Bidder at the highest point or such places or of the Pump House Building conforming to the I.E. Rules specifications as per standard practice. The job includes supplying, fixing and commissioning of sufficient no. of lightning arrestors which includes air-terminals, separate earth electrodes, grid earthing and individual earthing with approved size of air-terminals, earth electrodes, earthing strips as per IE rules/IS codes. Detail Calculations to be vetted by the department in the final design.

23.0 MOTOR FLOOR AND CONTROL ROOM

There must not be any column in the motor floor for easy movement of the HOT Crane. Similarly in the Control room cum office room, there must not be any columns in the room. The motor floor should have suitable openings at appropriate location as per requirement of the pump manufacturer for lowering and taking up of pumps, motors, valves, entry of cable etc. The motor floor shall be suitably designed to take care of the vibration generated from the motor pump assembly while in operation.

24.0 WRAPPING COATING

This work is to be completed in all S.W.M.S. pipe at ground level with 4 mm. thick coal tar based tape. Necessary 'Holiday Test' to be done to ensure perfection. This job is to be done before commencement of work of respective stretch.

25.0 TRIAL RUN

When in the opinion of the Engineer the initial performance tests as specified in Section- I are satisfactory the Contractor shall arrange for trial run of the plant at its rated capacity and also their performance tests. During such tests, the Contractor shall arrange to collect samples of effluents from the clarifier and representative. Samples minimum of SLX samples of each effluent shall be collected at intervals specified by the Engineer each day for 14 consecutive days. These samples shall be sent by the Engineer or his authorized representative to the plant laboratory or any other laboratory nominated by the Engineer, for analysis and determination of the quality of the two effluents. All costs of the sample collection, delivery to the laboratory and test shall be borne by the Contractor.

The Plant shall be deemed to be ready to be put into normal use when trial run of the plant and the quality of the clarified water and filtered water are certified satisfactory by the Engineer. The period of maintenance shall be reckoned from the date of the Engineer's certificate.

26.0 OPERATION AND MAINTENANCE

After the plant is deemed to be ready to be put into normal use the Contractor shall operate and maintain the same for a period of twelve months by his own establishment and technical experts under the overall supervision chemicals and other consumable stores required for the operation of the plant shall be provided by the contractor at his cost. The Employer shall also bear the cost of electrical energy. During the aforesaid period of operation of the plant the Contractor's supervisory staff shall train and instruct technicians and other staff deputed by the Employer about the correct method of operation and maintenance of the plant as a whole and its various mechanical and electrical components. The Training shall be such as would enable the Employer's staff to take over the plant from the Contractor for its operation and maintenance independently. The Contractor's training personnel shall give special attention to this.

During the period of operation and maintenance the Contractor shall arrange to take regular samples of the clarified and filtered effluents as directed by the Engineer and shall

have such samples tested at his cost in the plant laboratory or any other laboratory nominated by the Engineer, to determine the quality of the samples and the performance of the plant. Such tests shall be continued up-to the penultimate week prior to the end of the maintenance period and the plant shall be taken over by the Employer subject to the final performance tests being certified as satisfactory by the Engineer.

The Bidders shall submit with their offer a list of technical and non-technical staff they propose to engage for operation and maintenances of the plant for twelve months.

27.0 GUARANTEE PERIOD

The Contractor shall stand guarantee for the successful operation of the plant for 12 (Twelve) months period from the date of the certified commissioning as stated in clause C-48 & 49 within which any defects and short coming due to faulty design of the plant, defective mechanical and electrical equipment or defective construction will have to be made good without any extra cost to the Authority. During the guarantee period the Contractor shall ensure thorough checking of the plant at least once every month and arrange for immediate rectification of any defects detected during this special drive by his experts.

28.0 GUARANTEES

The Contractor shall give the following guarantees

28.1 CIVIL AND STRUCTURAL WORKS: - The Contractor shall guarantee the plant against any structural failure due to faulty design, bad workmanship, substandard materials, etc. for a period of twelve months. Any defect found during the guarantee period shall be rectified by the Contractor to the satisfaction of the Engineer without any extra cost.

28.2 PLANT AND EQUIPMENT: - Even when a plant or equipment has been manufactured and / or marketed by a vendor, it would be deemed to have been supplied and installed under the contractor's supervision. The Contractor shall provide back-to-back guarantee along with the vendor but shall solely be responsible for its repair/replacement. He shall not cite the vendor and claim absolvent. In addition, all equipment shall be free from any defects due to faulty designs, materials and / or workmanship. The equipment shall operate satisfactorily and performances and efficiencies shall not be less than the values guaranteed by the manufacturer and endorsed by the Contractor.

Formal acceptance of the work or equipment covered under the Contract by the Engineer shall not be made until all the work done by the Contractor has satisfactorily passes all tests required by the specifications.

If, during testing of work and / or equipment prior to formal acceptance, any equipment or materials shall fail in any respect to meet the guarantees, the Contractor shall replace such equipment in a condition, which will meet the guaranteed performance. Any such work shall be carried out by the Contractor at his own cost and expenses in necessity thereof, shall in the opinion of the Engineer be due to the use of materials or workmanship not in accordance with the Contract or to neglect or failure on the part of the Contractor to comply with any obligation expressed or implied on the Contractor's part under the Contract. If in the opinion of the Engineer, such necessity shall be due to any other cause, the value of such work shall be ascertained and paid for as if it were additional work.

If the Contractor shall fail to do any such work as aforesaid, required by the Engineer, the Employer shall be entitled to carry out such work by its own workman or by others and if such work is supposed to be carried out by Contractor the cost thereof, or may deduct the same from any money due or that may become due to the Contractor.

29.0 IMPORTANT GUIDELINES AND SPECIFICATIONS

29.1 Unless otherwise **Collector well and foot Way Bridge** specified elsewhere, the work shall be carried out as per the following specifications.

29.1.1. All civil works shall be carried out as per specifications contained in other section of these tender specifications.

29.1.2. All electrical works including supply of all electrical equipment shall be carried out as per specifications contained in other section of the tender specification.

29.1.3. All mechanical works including supply of equipment shall be carried out as per specifications contained in other section of these tender specifications.

29.1.4. The erection and commissioning works shall be carried out as per specifications contained in other section of these tender specifications.

29.1.5. Walkways and operating plant forms shall be provided with hand railings as specified in other section.

29.1.6 Roofs shall be provided with polyurethane paint.

29.1.7. All the exterior doors and windows shall be provided with R.C.C. chajja of approved design.

29.1.8. All windows and ventilators/skylights shall be provided with mild steel grills of approved design.

Secretary
Asansol Municipal Corporation

SECTION – F

GENERAL TECHNICAL SPECIFICATION

The structure of the Collector well and foot way bridge and pumping station with LT PDP panel , soft starter will be constructed above 1.0 M of the High Flood Level in the area of the Asansol Municipal Corporation. The Bidder shall verify the location by inspection of the site and shall apprise himself of the local condition before submitting the Bid.

2.0 SUB-SOIL REPORT

Sub-soil investigation is to be carried out by soil-experts engaged by the contractor at the site of the Collector well and foot way bridge and collector well pumping station site.

The Bidder should satisfy himself about the adequacy of the data for the design of pile foundation for the Collector well and foot way bridge and collector well pumping station. The Bidder must carry out sand investigation of collector well before submission of his Bid by drilling bore hole at work site at his own cost for his own satisfaction. The successful Bidder shall have to undertake fresh investigation of sand at the exact location of collector well of the structure at his own cost to design the foundation properly. Records of such sub-sand investigation such as borehole logs, soil samples, SPT values etc., shall be done by the contractor duly witnessed and authenticated by the Engineer in Charge or his competent authorized representative.

In the event of variation in soil data between that of Bid inviting authority and those obtained by the contractor during execution, the more conservative values obtained from the two sets of reports shall be adopted for design without any extra claim over the quoted price as accepted by the Department, unless otherwise permitted by the concerned Superintending Engineer, Western Circle, Municipal Engineering Directorate.

3.0 BID DRAWINGS

The General Arrangement of the Collector well, footway bridge, PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 600 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) up to Ground level Reservoir will be reflected in the enclosed site lay out plan by the bidder. These lay out drawing is meant for giving the Bidder a general idea of the proposed site of Collector well, footway bridge, PDB Panel, soft starter and collector well pumping station. The various levels and dimension of the Collector well Pumping station and laying of rising

main up to the ground level reservoir of High lift pump house is to be fixed by the Bidders as per the conditions mentioned in the Bid document.

4.0 DESIGN CRITERIA OF THE DESCRIBED PROJECT

4.1. The basic layout plan and elevation of the Collector well, footway bridge, PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 600 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) up to Ground level Reservoir shall be as per Bid drawings drawn by suitable Architectural design based on the Bid drawings. The Bidder shall submit with his Bid, the Architectural Elevation of the Collector well, footway bridge, PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 600 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) up to Ground level Reservoir. However, the architectural Elevation with fixation of Plinth level may have to be modified at the time of approval by the Superintending Engineer, Western Circle, Municipal Engineering Directorate for which no extra charge will be paid. Design and construction of all R. C. C. Structures, brick masonry walls and Foundation shall conform to the latest edition of the following IS Codes.

- | | | |
|----|------------------------------------------|------------------------------------------|
| a) | Loading Standards | IS: 875 |
| b) | Earthquake Resistant Design | IS: 1893 & IS: 4326 |
| c) | Reinforced and Plain Concrete | IS: 456, 2000 |
| d) | Foundations | IS: 1080, IS: 2950 , IS: 2911 & IS: 2974 |
| e) | Liquid Retaining Structures | IS: 3370 |
| f) | Structural Steel | IS: 800 |
| g) | Reinforcement Mild Steel | IS: 456 & IS: 432 |
| | Ribbed Tor Steel | IS: 1786 & IS: 1139 |
| h) | Masonry and Brickwork | IS: 1905 & ISS: 2212 |
| i) | National Building Code of India | IS: 2910 |
| j) | Design & Construction of Pile Foundation | IS: 2911 |

(Considering the latest edition of the code)

4.1. The Collector well, footway bridge, PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 600 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) up to Ground level Reservoir shall be designed as per requirement based on the Report of soil investigation.

If pile foundation is obligatory as per Report, piles shall be bored Cast-in-situ R. C. C. Piles. The design, construction and workmanship for these piles shall fully conform to and satisfy the requirements of IS: 2911 (Latest Edition). Concrete to be used in Piles shall be of M-25 Grade having Cement content not less than 440 kg/m³. Reinforcement in piles shall be in conformity with the requirements contained in IS: 2911 (Latest Edition). The minimum area of Longitudinal Reinforcements shall be as per requirements and such requirements shall be provided for the full length of piles. For piles subject to Upward Tension, reinforcement shall be provided throughout the full length and such reinforcement shall be designed on the basis of upward load they are supposed to carry.

The safe working loads of the R. C. C. Cast-in-situ bored piles should be that as computed as per IS: 2911 on the basis of Sub-soil Parameters of the Site with a minimum Factor of Safety 2.5 (Compression) and 3.00 (Up lift) applied there on or that indicated in a table, whichever is less.

Pile termination levels shall be chosen carefully. The safe working load of the piles shall be substantiated by Routine Load Test. The Pile termination level shall not be reduced from that stated herein above unless otherwise permitted by the Engineer-in-Charge.

These Piles shall be designed for Seismic Condition also. The Importance factor for Seismic Analysis of Structure shall be 1.50. The Bidder shall include in his Lump Sum price the cost for Load Test of at least working pile (Routine Test) per 100 piles or part thereof. The testing should be as per Code Stipulations.

4.2. While designing the Foundation of different structures, the Bidder may use the Soil Investigation results enclosed in the Bid.

5.0 DESIGN PARAMETERS PUMPING STATION

5.1 Loadings: - The pump floor is to be designed for a live load of 500 kg/M² and the superimposed Load of saturated earth of 450 mm depth.

A) i) Live Load on Roof 150 Kg/m².

ii) Live load on pump house Floor/walkway	500 Kg/m ² .
iii) Live load on Control Room Floor	300 Kg/m ² .
iv) Weight of each Empty Pump (approx.)	2000 Kg.
v) Weight of each Motor (approx.)	2000 Kg.
vi) Weight of 500 mm diameter Sluice Valve (approx.)	1200 Kg.
vii) Weight of 400 mm diameter Sluice Valve (approx.)	900 Kg.
viii) Load due to Electric Panel (approx.)	800 Kg/m ² .
ix) Weight of 400 mm diameter pipe (approx.)	300 Kg/m ² .

N.B. Loading details given herein above are tentative and subject to verification during final execution. No extra cost will be paid to the Contractor on account of variation within ± 30 % limit. Vertical load data for pumps and motors are inclusive of impact factor subject to confirmation of the Pump Manufacturer during final design. The cost in this regard shall be included in the lump sum offer by the Bidder and no additional claim will be entertained in future due to variation in load data, if any.

The floor slab is to be designed for the worst loading conditions that the floor will be subjected due to the equipment to be housed and may be put anywhere on this floor. The floor slab should be so designed as to withstand such loads.

The floor supporting M.S suspenders/Cable trays are to be designed for a concentrated static load of 200 Kg at any point. The Cable Trenches shall be absolutely free from any obstruction so as to allow the Cables to be lowered in the trenches from top only during laying.

Load of M.S Chequered Plates 50 Kg/ sq. m.

For trench covers over opening in Floor 500 Kg/ sq. m.

Loading up to 5.00 M.T H.O.T electrically operated crane:- As per Crane Manufacturer's specifications

A surcharge of 500 Kg/Sq. is to be taken into consideration while designing the sidewalls of the Collector well, footway bridge, PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 600 mm dia. M.S.

spiral welded mild steel rising main pipe line (TATA / SAIL make) up to Ground level Reservoir.

The Bidder has to design in such a way that the permissible limit of vibrations of Rotor dynamic Equipment shall be within the limit as specified in IS: 11724-1985. The R. P. M. of pump Motor set will be not less than 750 R.P.M. Sync, subject to confirmation award of equipment contract.

N.B.:- For calculating earth pressure on the boundary cum retaining wall, the worth value among co-efficient of active earth pressure (K_a) and that of Earth pressure at rest (K_o) is to be considered. Standard backfill materials with conservative soil data are to be considered. No extra claims are to be entertained in this regard.

5.2. Special Notes on vertical turbine pump in vertical Execution Pump Foundation Design is to be considered

5.3.1. Foundation system for support of Rotary machines such as vertical pumping unit shall strictly comply with the requirements of Code IS: 2974 (Part-IV) - latest edition. The Rotary Machine support system require careful study of the foundation system with due consideration of vibration characteristics. For satisfactory design and construction, the following precautions need be taken with careful dynamic analysis of machine foundation and its supporting structures:

- i) The natural frequency of the Foundation System shall be analysed and the mass of the Foundation System shall be considerably larger than the mass of the whole machine.
- ii) Dynamic Analysis due to insufficient clearance between impeller and casing of Pumps should be checked and frequency out of this type of vibration need to be made as per relevant IS Code.
- iii) Dynamic Response check of the block foundation may be carried out as per relevant IS Code.
- iv) Permissible amplitude of Vibration of displacement as per IS Code 2974 (Part-IV), is to be calculated and the design will be checked accordingly.
- v) Permissible stresses in Soil/Concrete be suitably as per IS Code.

vi) Natural frequency of Foundation System shall be such as will avoid resonance with the Operating Speed of the Machine. The natural frequency of the foundation system should not be within +20% of the operating speeds of the machine.

vii) The foundation system shall be so dimensioned that the resultant force due to mass of the machine and mass of the Foundation passes through the Centre of gravity of the base area of the Foundation.

5.3.2: The Bidder is required to submit a "Technical Write-up" with relevant details of Foundation System along with the Part-I of this Bid. This would help the Department to fix up the accepted Parametric Norms of the foundation System that would finally be adopted in the design and construction of the Building and Structures after award of the contract.

6.0 ARRANGMENT OF ROOF & LEAKAGE TREATMENT:

6.1: It is proposed that the intake cum pumping station with HT substation top should be open with requisite Roof Treatment.

7.0 DESIGN DRAWING AND OTHER INFORMATIONS TO BE SUBMITTED BY THE CONTRACTOR (SUCCESSFUL BIDDER)

7.1. On the award of the Contract Contractor shall submit to the Superintending Engineer, Western Circle, Municipal Engineering Directorate and detailed design and drawings of different structures within fourteen (14) days from the date of issue of Letter of Acceptance and thereafter the balance drawings and design calculations will have to be submitted phase wise keeping pace with the work Program.

If called upon the Contractor shall also submit within reasonable time relevant books and other references, which have been referred to or used in the design. Such books and other relevance will be returned to the Contractor when done with. Secrecy in regard to details of design materials and equipment etc. shall not be pleaded by the Contractor in the name of "Trade Secret" for not furnishing the requirement details asked for by the Superintending Engineer, Western Circle, and Municipal Engineering Directorate. The design and drawings shall be subjected to modifications at no extra cost, if found

necessary and such modifications shall not vitiate the contract. Similarly, the Contractor shall submit any additional new drawings as found and the drawings shall form part of the Contract Drawings.

Notwithstanding what has been stated above the Contractor shall be responsible for the correctness and soundness of the design and if any provisions are found inadequate or faulty necessary modification will have to be carried out at any stage up-to the expiry of the Guarantee period at no extra cost.

The Contractor will not be permitted to commence the Actual Work at site unless the EIC on written recommendation to concerned Superintending Engineer, Western circle of Municipal Engineering Directorate approves detailed design and working drawings. Four copies of the approved design and six copies of the approved drawings are to be furnished by the Contractor free of cost for use by the Employer during execution of the work. Any additional copies of same drawings, if required, should also be submitted by the Contractor free of cost at the request of the EIC. If the drawings are done with Auto Cad, then copy of the folders containing drawings in CD/DVD may be submitted for records only. If required on the urgent basis the soft copy of any drawing is to be sent by E- Mail to "Office of The Executive Engineer" as per verbal discussion or Telephonic discussion within 2 hours.

A tentative work Program in Network Diagram using CPM & Bar Chart technique is required to be submitted by the successful Bidder within a fortnight from the date of issue of the letter of acceptance. The drawings from foundation onward will have to be submitted by the successful Bidder successively as per the work Program to be approved by the Engineer-in-Charge. Adequate resources are to be mobilized during execution of the work, for which no extra payment shall be made.

7.2 Completion of Drawings and Other Documents to be submitted the Contractor. The Contractor shall submit within one month after the completion of all construction works the followings drawings and documents free of cost.

a) Six copies of all approved Completion drawings. These drawings shall be on black and white prints of thick paper and there shall be one transparency of each drawing. These drawings are to be submitted in a presentable form as directed by the Superintending Engineer, Western Circle of Municipal Engineering Directorate. In addition to this, CD/DVD's with folders of these drawings drawn in Auto CAD or scanned copies are to be submitted.

- b) Four copies of final designs in properly bound form as directed by the Superintending Engineer, Western Circle Municipal Engineering Directorate.
- c) Four copies of detailed specification and schedules of the completed intake jetty pumping station and substation of intake jetty pumping station.
- d) Six copies of Instruction Manuals for the Operation, Maintenance and overall of intake jetty plant.
 - i) The Instruction Manuals shall contain the following basic categories of information in practical, complete and comprehensive manner prepared for use by operating and/ or maintenance personnel:
 - a) Relevant information as regards initial installation.
 - b) Instruction for operation, maintenance and repair.
 - c) Recommended inspection points and period of inspection.
 - d) Ordering information for all replaceable parts, etc.
 - ii) The information shall be organized in a logical and orderly sequence. A general description of the system including important technical characteristics shall be included in order to familiarize operating and maintenance personnel with the system.
 - iii) Necessary reproducible drawing and/or other illustrations shall be included or copies of appropriate certified drawings shall be bound in the manual. Test, adjustment and calibration information, as appropriate, shall be included and shall be identified to the specific equipment. Safety and other warning notices and installation, maintenance and operating cautions shall be duly emphasized.
 - iv) A part list shall be included showing part nomenclature, manufacturer's part numbers and/or other information necessary for accurate identification and ordering of replacement parts.
 - v) If a standard manual is furnished covering more than the specific equipment purchased, the applicable model (or other identification) number, parts number and other information for the specific equipment purchased shall be clearly identified.
 - vi) The instruction Manual shall include list of all special tools and tackle furnished with complete drawings and instructions for use of such tools and tackle.

vii) The Instruction Manual shall also include recommendations for consumable supplies e.g. packing, lubricants, etc., for the plant installed as well as for chemicals for treatment and laboratory reagents.

viii) All the pages of the Instruction Manual shall be clearly legible and prepared on good quality paper.

ix) The Instruction Manual shall need the approval of the Superintending Engineer, Western Circle of Municipal Engineering Directorate. All the copies of the Instruction Manual shall be presented in durable and bound form as directed by the Superintending Engineer, Western Circle Municipal Engineering Directorate.

7.3 Release of Security Deposit (Retention Money):- The Security Deposit (Retention Money) shall not be released until all the above-mentioned Completion Drawings and Documents (as per Clause 7.2) are submitted by the Contractor.

SECRETARY

ASANSOL MUNICIPAL CORPORATION

SECTION - G

DETAILED TECHNICAL SPECIFICATIONS FOR CIVIL WORKS FOR INTAKE JETTY PUMPING STATION WITH HT SUBSTATION

1.0 SPECIAL NOTES

1.1 The layout of the plant as shown on the drawing attached is not binding on the Bidder but is only indicative.

1.2 The Bidder shall not quote for works differing from the specifications of the Bid unless specifically permitted elsewhere in the Bid documents.

1.3 The suitability of the intake jetty pumping station with HT substation will not be decided only by the low capital cost but the economy in the operational & maintenance costs will also be considered. For this purpose all relevant details should be furnished.

1.4 There shall not be any ambiguity in the offer. Bid containing any ambiguity may be interpreted in a manner advantageous to the Employer.

1.5 If not mentioned elsewhere in the Bid documents, the contractor shall provide the following arrangements:

a) The Collector well, footway bridge, PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 450 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) on both side of footway bridge up to Ground level Reservoir shall be erected that the filter water from the river Damodar shall be such that water pumped out by the vertical pumping unit at the highest flood level as well as at the time of lowest flood level, filter water shall be pumped out to the ground level reservoir. The total quantity of the raw water shall be pumped to at lowest flood level as well as highest flood level in respect of 24.97 MLD (considering 16 Hrs. Pumping in a day) from Collector well for Kulti Town.

1.6) All valves, sluice gates, Butterfly, Kinetic non-return, Air release, pressure release etc. shall be of Kriloskar / Kalpana / Upadhyay make having PN 1.6.

1.7) The Collector well, footway bridge, PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 450 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) on both side of footway bridge up to Ground level Reservoir works being a process plant, and laying of 800 mm / 700 / 600 mm dia D.I. pipe line (D.I. pipe will be supplied from AMC office) from Chinakuri

river bank to GLR1 including all necessary valves, specials. It is imperative that the layout of the plant inclusive of all Civil, Mechanical and Electrical Components should meet the requirements of Indian Factory Act, Indian Explosives Act and all other relevant statutes of the State and Central Government.

1.8 In order to provide a net output of 1506.625 m³ / hour filter water (16 hours operation) at whatever condition of water level of the river Damodar the pumping unit shall be placed on the floor of the pump house. The common manifold and valves shall be placed in such a way that that no obstacles found at the entry gate of the pumping station.

2.0 ITEMS OF WORKS

The items of works have already been detailed in these documents. However, it is repeated below:

- a) Collector well, footway bridge, 750 mm dia. of required length (minimum 250 meter) Infiltration gallery with 40 Nos. 300 mm dia. spiral welded mild steel strainer of required length (minimum 18 meter), PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 450 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) on both side of footway bridge to River bank in a 100 mm dia 16 mm thick spiral mild welded manifold line and discharge to GLR 1 by 800 / 700 / 600 mm dia D.I. pipe line (D.I. pipe will supplied from AMC office) approx length 300 meter up to Ground level (civil & electro-mechanical part).
- b) Back filling shall have to be done from the excavated earth (if required), in case of short fall the same shall have to be arranged by the bidder free of cost.
- c) Retaining cum boundary wall & Illumination of the Collector well, footway bridge, PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 450 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) on both side of footway bridge up to Ground level Reservoir, the scope is to be finalized after given view consideration of the actual site condition and soil report.

Components should meet the requirements of Indian Factory Act, Indian Explosives Act and all other relevant statutes of the State and Central Government.

1.8 In order to provide a net output of 1506.625 m³ / hour raw water (16 hours operation) at whatever condition of water level of the river Damodar the pumping unit shall be placed on the floor of the pump house. The common manifold and valves shall be placed in such a way that that no obstacles found at the entry gate of the pumping station.

a) The above scope of works is to be indicative not to be exhaustive. Anything not covered in NIB but required for successful commissioning of the plant in all respect are to be provided by the e-Bid.

2.1 SOURCES OF CLEAR WATER SUPPLY & DESIGN FLOW

The source of raw water supply is the river Damodar. Collector well, footway bridge, 750 mm dia. of required length (minimum 250 meter) Infiltration gallery with 40 Nos. 300 mm dia. spiral welded mild steel strainer of required length (minimum 18 meter), PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 450 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) on both side of footway bridge to River bank in a 100 mm dia 16 mm thick spiral mild welded manifold line and discharge to GLR 1 by 800 / 700 / 600 mm dia pipe line (D.I. pipe will supplied from AMC office) approx length 300 meter up to Ground level (civil & electro-mechanical part).

2.2 QUALITY OF THE CLEAR WATER

For designing the Collector well pumping station the quality test of clear water should be done in presence of representative of E.I.C and quality of raw water should be checked from authentic Govt. Department by the bidder at his own cost for getting actual data required for pumping unit designing.

3.0 DESIGN SUBMITTED BY THE BIDDER

3.1 COLLECTOR WELL PUMPING STATION:-

Collector well, footway bridge, 750 mm dia. of required length (minimum 250 meter) Infiltration gallery with 40 Nos. 300 mm dia. spiral welded mild steel strainer of required length (minimum 18 meter), PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 450 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) on both side of footway bridge to River bank in a 100 mm dia 16 mm thick spiral mild welded manifold line and discharge to GLR 1 by 800 / 700 / 600 mm dia pipe line (D.I. pipe will supplied from AMC office) approx length 300 meter up to Ground level (civil & electro-mechanical part). The Collector well pumping station slab including foot Way Bridge should be supported on RCC piers / piles at least 1.0 M above the HFL and piers / piles should rest in suitable RCC cap. The grade of the concrete should be of M 30 for structure coming in contact with water or susceptible to come in contact of water. The construction of loading on the deck slab to be made such

that it includes 2 (two) Nos. of M.S pipe line with other live loading of 250 kg/ m² finished load 150 kg/ m² and normally trolley loading 2T for transportation of electro-mechanical loading. The pump delivery line should be placed on the Collector well, footway bridge, PDB Panel, soft starter and collector well pumping station with Supplying, laying and fabricating of 12 mm thick 450 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) on both side of footway bridge up to Ground level Reservoir and butterfly valve of 450 mm dia., a full bore flow meter and discharge meter in a temper proof double throat required dia. air release valve are to be used for interconnecting the 2 Nos. 450 mm dia. rising main at the bank of the river Damodar. The floor of the pump house should be Kota stone flooring and approach deck slab / walkway should be finished chequered tiles (rough) with necessary cement backing.

The roof slab of the pump house shall have proper roof treatment together with water proofing treatment on it. The standard lime roof treatment is not acceptable. Pre-cast R. C. C. roof will also not be acceptable. The external and internal faces of the wall of pump house shall be rendered smooth. The exposed face will not be allowed to have any shutter mark and be rendered smooth by rubbing with carborandum stone.

The inside faces shall be provided with 3 (Three) coats cement wash after brushing off and finishing the shutter mark. External exposed faces shall have 2 (two) coats of weather coat (exterior) or equivalent paint of approved colour as directed by E.I.C.

There will be one entry points to the pump house both fitted with rolling shutters and the arrangement window to be made properly. All the widows of the pump house shall be sliding type made of anodized aluminium section and protection with grill to be provided on outer surface of pump house should be made from M.S grill.

One electrically operated crane of 10 MT Capacity is also included for loading / unloading pumps & motors and other equipment as specified in technical details. The control valve chamber shall be of adequate dimensions as would conveniently accommodate the inlet control system comprising S.W. M. S (spiral welded mild steel) mains and one butterfly valves of required diameter should be placed on river bank for interconnecting the rising main. There shall remain minimum 350 mm clearance all rounds inside the valve chamber. The chamber will be in brickwork. All other provision shall be made as per direction of Engineer-in-Charge.

The Bidder shall make in his design all the provisions of safety of the structures and foundations thereof. Any deviation in quantities from the design and drawings approved by

the Authority during actual execution compared with those provided in the Bid shall not entitle the Contractor to any extra payment.

3.2. Supplying, laying and fabricating of 12 mm thick 450 mm dia. M.S. spiral welded mild steel rising main pipe line (TATA / SAIL make) on both side of footway bridge to River bank in a 100 mm dia 16 mm thick spiral mild welded manifold line and discharge to GLR 1 by 800 / 700 / 600 mm dia pipe line (D.I. pipe will supplied from AMC office) approx length 300 meter up to Ground level (civil & electro-mechanical part) including fixing of all necessary valves and specials which are under the bidder scope.

1. EXCAVATION AND PREPARATION OF TRENCHES- The trenches shall be so dug that the pipe may be laid to the required alignment and at a required depth. When the pipe lines is under / site the road way, a minimum cover of 1.0 M is recommended for adaptation but it may be modified to suit local condition.

2. WIDTH OF THE TRENCH- The width of the trench at the bottom shall be such as to provide not less than 20 cm clearance on the either side of the pipe. Additional width shall be provided at positions of sockets and flanges for jointing to be made properly. Depth of pits at such places shall also be sufficient to permit finishing of joints. Boulder and large stones shall be removed to provide a clearance at least 15 cm bellow and on each side of pipe, valves and fittings for pipes 600 mm in dia. or less and 20 cm for pipes larger than 600 mm in dia.

3. TRIMMING OF TRENCH BOTTOM – Before laying the pipes, bottom of pipe trench shall be cleaned of to present a plain surface and all irregularities shall be levelled.

4. LAYING OF PIPES- Where unloading, pipes shall not be thrown off on the hard roads. In order to avoid damage to the pipes and especially to the spigot ends, pipe should not be dragged along concrete and similar pavements with hard surfaces. All department Supply pipes , fittings, valves shall be carefully lowered into trench, piece by piece by means of derrick , or ropes or other suitable tools or equipment so as to prevent damage to pipes , fittings protective coatings and linings. Any negligence during unloading and handling of pipes results damage to the pipes and development of hair cracks, which

if not detected at the time laying results in bursts during hydraulics testing will be serious offence and all liabilities goes to the concern.

4.0 TOOL BOX AND TOOLS

Bidders shall supply two toolbox (overall dimensions 1200 mm x 900 mm x 750 mm) made of best quality wood / NUWUD and polished or painted as per direction of the Engineer. The box shall be compartmentalized suitable to hold different types of tools separately. The edges of the box shall be protected by aluminium angles and the box shall be fitted with lock and key arrangement.

In addition, Bidders shall quote separately on their own letter heads for supply of one set special tools and tackles that they feel shall be necessary for maintenance, overhaul or replacement of the equipment under this contract. The quotation shall be attached with the Schedule of Prices.

5.0 LEVELLING OF THE SITE

After completion of the work, the entire site all round the intake jetty pumping station and other allied structures within the scope of this contract shall be cleared and all construction equipment shall be removed within a period not exceeding 3 (three) months from the date the plant is put into trial run. The site shall be graded and levelled to the required High Flood Level with boundary or retaining wall as required and as per instruction of E.I.C.

6.0 PROCUREMENT OF EQUIPMENT ETC.

Whenever is this Section or elsewhere, equipment, contrivance, special or this like are specified to be of 'reputed', 'approved' or similarly worded make, the List of Vendors should be consulted first and the scope of procurement limited to the same. In cases where the name of such equipment etc. do not figure in this list of vendors, written approval of the Employer about the make should invariably be obtained, failing which the equipment etc. even if procured may be subject to rejection.

7.0 Bank protection- River bank will protected by retaining wall or bolder soling by filling with M-20 concrete.

SECRETARY
ASANSOL MUNICIPAL CORPORATION

SECTION – H

GENERAL TECHNICAL SPECIFICATION FOR R.C.C. PILE FOUNDATION

1.0 GENERAL

The Design of the bidder should be based mainly on cast-in situ Bored reinforced concrete piles on driver piles on Damodar River as per site situation so arises subject to the approval of EIC. Sub-sand or soil investigation was carried out by the Department and the summary report is placed in Annexure-I (Section – N). Interested bidders may have a look at the full report which will be available in the office of the Superintending Engineer, Western Circle Municipal Engineering Directorate. Beside this the bidder himself is to be carrying Soil investigation report and safer data has to be taken for Sub-structure design.

This information is given as a guidance and is indicative only, and for any variation in strata at any location at site during actual execution of work, the employer shall not be held responsible for shall the contract be null and void on this count. In case of any variation in cut off level, necessary adjustment of safe working load will be made as per IS stipulation. The specialist firm may quote any proprietary system of piling subject to approval of the Engineer-in-Charge consistent with the load, moment and forces to be encountered by each pile.

The Bidders shall submit with his bid drawings, calculations explaining his scheme draw up specification and submit the schedules of prices following the format of the schedules of prices accompanying this bid documents.

2.0 DESIGN AND CONCRETE QUALITY

2.1 The safe working loads of the RCC cast in site bored piles should be that as computed as per IS: 2911 on the basis of sub soil parameter of site with a minimum factor of safety 2.5 (compression) and 3.00 (up lift) applied there on. For boring / driving pile under water IS stipulation as well as SWID & Municipal Engineering Directorate suggestions will be strictly honoured. The grade of concrete of all types of R. C. C. pile shall be minimum M-25 / IS stipulation unless otherwise specified elsewhere. The cement content in concrete to piling work shall be minimum 400 kg/M³ with ordinary Portland cement. Water cement ratio and slump shall be as per I. S. Specification for relevant piling work. Maximum size of coarse aggregate shall not exceed 20 mm.

2.2 Grading and other requirement of coarse and fine aggregates, water and concrete shall be as specified for reinforced cement concrete work under this Contract.

2.3 The average basis length of the piles is to be assumed from cut off level to the tip of the pile (however for piles with muff the basic length shall be from tip of the pile up to underside of muff). The final length will be decided by the contractor with approval of the Engineer on the basis of driving / boring resistance actually observed at site. It will be the responsibility of the contractor to prove by subsequent load test / pullout tests that the adopted length of pile shall carry the specified safe load, tension and the resulting deflections being within the permissible limits. In no case extra claim over the originally quoted price will be entertained for any increase in number / length / cross sectional area / reinforcement of piles and in the site of other foundation structures if required at the time of execution after the load tests of piles. Similarly no deduction in payment will be made from the lump sum price quoted for decrease in number / length / cross-section of area / reinforcement and in the size of other foundation structures at the time of execution or after the load tests of piles provided that the complete safety of the Structures is fully assured.

2.4 For Collector well, Foot Way Bridge, pumping station pile foundation should have permanent steel casing / approved alternative methodology. Scour depth below bed level will be a major guiding factor. All relevant provision of I.S. code for R.C.C. Structure on river bed (under water) will have to be strictly followed. However bidders may suggest other methodology without deviating from major objectives & cost keeping the working well within I.S. standards. In any case he has to be ensured the stability of the structure.

2.5 Bidders/ contractor will be given full liberty to opt for design mix as per satisfaction of E.I.C. with minimum cement content as mentioned.

3.0 SPECIFICATION FOR BOREDCAST-IN-CITU PILES

3.1 Unless specified otherwise in the following paragraphs, stipulations of relevant section of I. S. 2911 (latest edition) shall be followed. However in case of any conflict of stipulations laid here in and IS code of practice occurs, IS stipulations will stand as final subject to satisfaction of EIC.

The bidder shall submit within his bid the layout and number of piles based on allowable load carrying capacity, tension on the pile section design by him.

3.2 Boring equipment and accessories shall generally conform to IS: 2911 relevant section. Boring may be done by either rotary or percussion equipment or grouting

equipment using reverse or direct non circulation method. In case of unstable soils the boring tools used shall be such that suction effects are minimized.

Stabilization of the sides of bore hole shall be done by the use of betonies slurry or casing. The size of cutting tool shall not be less than the diameter of the pile by more than 75 mm.

In case of boring with casing, the casting shall be used from the ground level. The casing shall be kept ahead of boring in cases where there is danger of carrying in due to subsoil entering into the borehole or where soil is loose.

While boring below sub-soil water, precaution shall be taken so that no boiling of the bottom of the hole occurs due to difference in hydrostatic head.

3.3 Concreting of bore holes shall start soon as possible after its completion. Should a borehole, be left without concreting for more than two hours it shall be cleaned thoroughly as directed by the Engineer-in-Charge before placing concrete. Concrete under water shall be placed by means of a termite pipe. It shall, however, be ensured that concrete entering the termite pipe does not get mixed up with the slurry and $\frac{1}{4}$ kg of granulated vermiculite shall be poured in the termite pipe before pouring concrete as directed by the Engineer.

3.4 The termite pipes and funnel shall be filled and lifted just 15 cm above bottom before releasing the concrete column to facilitate flushing out of the bottom. The concrete levels in the termite shall be checked every meter in order to judge the difference, if any, between the theoretical quantity that should have been placed and the actual quantity that has gone in. This is to locate the position of cut off during boring. In addition to the normal precautions to be taken in termite concreting as per relevant Section of IS: 2911 the following specifications shall be particularly applicable for the use of termite concrete in pipes.

- i) The concrete shall be coherent, such in cement (not less than 400 kg/m^3) and of slump not less than 150 mm I S stipulations
- ii) The hopper and termite shall be closed system.
- iii) The termite shall be large enough with due regard to the size of the aggregate. For 20 mm aggregate the termite pipe shall be of diameter not less than 200 mm.

- iv) The first charge of concrete shall be placed with a sliding plug pushed down the tube of it or with a steel plate of adequate charge to prevent mixing of concrete and water. However, the plug shall not be left in the concrete as a lump.
- v) The termite pipe shall always penetrate into the concrete with an adequate margin of safety against withdraw of the pipe surged to discharge the concrete.
- vi) The pile shall be concreted wholly by termite and the method of deposition shall not be charged way up the pile to prevent into laitance from being trapped within the pile.
- vii) All termite tubes shall be scrupulously cleaned after use. Normally concreting of the piles shall be carried out without any interruption. In the exceptional case of interruption in concreting, but which can be resumed within 1 or 2 hours, the termite shall not be taken out of the concrete. Instead, it shall be raised and lowered slowly, from time to time to prevent the concrete around the termite from setting. Concreting shall be resumed by introducing a little richer (5% additional amount) concrete with a higher slump for easy displacement of the partly set concrete.

If the concreting cannot be resumed before final set of concrete already placed, the pile so cast may be rejected or accepted with modifications at the sole discretion of the Engineer-in-Charge or his representative.

In case of withdrawing of termite out of the concrete, either accidentally or to removed a blockage in the termite, the termite may be reintroduced in the following manner to prevent impregnation of laitance or sewer laying on top of the concrete already deposited in the bore.

The termite shall be gently lowered on the old concrete with very little penetration initially. A vermiculite plug shall be introduced in the termite. Fresh concrete of slump between 150 mm and 180 mm. shall be filled in the termite which will push the plug forward and will emerge out of the termite displacing laitance / sewer. The termite will be pushed further in steps, watering fresh concrete sweeping away laitance / scum in its way. When termite is buried by about 60 to 100 cm. concreting may be resumed.

3.5 The top of concrete in a pile shall be brought above the cut off level to permit removal of all laitance and weak concrete before capping to ensure good concrete at the cut off level for proper embedment into the pile cap. Where cut off level is less than 1.5 M. below the working level concrete shall be cast to a minimum of 500 mm above cut off

level. For each additional 0.3 m. increase in cut-off level below the working level additional coverage of 50 mm. minimum shall be allowed. Higher allowance may be necessary depending on the length of the pile as directed by the Engineer-in-charge. When concrete is placed by using termite material, concrete shall be cast to the piling platform level to permit overflow of concrete for visual inspection or to a minimum of one meter above cut-off level. In the circumstances where cut off level is below ground water level the need to maintain pressure on the freshly laid concrete equal to or greater than water pressure shall be formed out and accordingly the length of extra concrete above cut-off level shall be determined and provided in works.

3.6 During piling, the sequence of construction and installation of piles shall as per direction of the Engineering-in-Charge.

3.7 In case defective piles are formed during construction, they shall be removed or left in place whichever is found convenient without adversely affecting the performance of the adjacent piles or the pile cap as a whole. Additional piles shall be provided at Contractor's cost to replace them as per direction of the Engineer-in-Charge and in this respect the Engineer-in-Charges' decision shall be final and binding upon the contractor. Any deviation from the designed location, alignment or local capacity of any pile shall be noted and adequate measures shall be taken well before concreting of the pile cap, etc. if the deviations are beyond the permissible limit. All such alternations shall be done at Contractor's own cost and expenses and to the entire satisfaction of the Engineer-in-Charge.

3.8 Piles shall be installed accurately as per approved design and drawings. For vertical piles a deviation of 1.5 percent from vertical line shall not be exceeded. Piles shall not deviate more than 75 mm. or one tenth of diameter whichever is more (in case of piles having diameter more than 600 mm) from their designed positions at working level of the piling rig.

In case of piles deviating beyond the above mentioned limits and such an extent that the resulting eccentricity cannot be taken care of by a redesign of the pile cap & pile trees, the piles shall be replaced or supplemented by one or more additional piles by the contractor at his own cost and expenses along with any additional cost for pile cap, etc. being borne by him.

3.9 While manual chipping may be permitted after casting of pile, pneumatic chipping, if permitted by the Engineer-in-Charge, shall not be started before 7 days under any circumstances.

3.10 Main longitudinal reinforcement in the length of the piles and links or spiral welded mild steels shall be provided as per the approved drawing. Longitudinal bars where possible shall preferably be in one length. Every care shall be taken in handling of the reinforcing cage so that its shape is not damaged.

3.11 When working adjacent to existing structure every care shall be taken to avoid any damage to such structures, in the case of bored piles care shall be taken to avoid effect due to loss of ground. In the case of deep excavations adjacent to piles proper protection shall be provided to safeguard against the lateral movement of soil stratum or releasing the confining soil stress.

3.12 During piling work the following data shall be recorded along with any other data as may be directed by the Engineer-in-Charge. These data shall be submitted to the Engineer-in-Charge in triplicate copies on completion of installation of each pile.

- i) Sequence of installation of piles in a group.
- ii) Dimensions of the pile including reinforcement details and mark of the pile
- iii) Details of mild steel liners where provided along with the details of stiffeners
- iv) Depth bored and founding level along with a bore log depicting the nature of strata encountered during boring.
- v) Time taken for penetration of every 15 cm during last 2 m depth before founding level.
- vi) Method of cleaning bottom of hole at founding level before concreting.
- vii) Time taken for concreting.
- viii) Cement consumption and slump of concrete.
- ix) Cut off level / working level / R. L. of top concrete, any other relevant / important observation.

3.13 During execution at any stage if any variation is required to be made to suit the site on EIC to be technically satisfied and His decision will be regarded as final.

3.14 Any of data / information given if not found reasonable (this will also include data of

parameters) will be given during detail engineering. Bidders / contractor therefore revised to consult with manufacturer/ experts at his own cost, if so felt, to reach more in figure for Biding purpose. The same is also advised for any other data supplied. But in no case it will be treated as a Fault of Biding Authorities. If any found in Variance in same chapter / section or anywhere of bid document, is to be into the notice of the biding Authority & his interpretation/ decision will be consider as final.

4.0 LOAD TEST ON PILES

4.1 The load tests shall be carried out as per IS: 2911 unless specified otherwise in the following paragraphs. The tests shall be carried out on test pile and a selected representative pile as approved by the Engineer-in-Charge. Sufficient time shall be allowed before tests to permit adjustment on the soil conditions following disturbance from the method of installation. The period between installation of the test pile or any other pile in the vicinity and the test loading of the pile shall be least 28 days.

4.2 The test load shall be applied by jacking against Kent ledge or any other structure approved by the Engineer-in-Charge. No working pile shall be permitted to be used for any loading for load test on pile. The design of the Kent ledge shall be such as to prevent instability, particularly in the event of a sudden change in the load reaction from the pile. The reaction from Kent ledge to be made available for the test shall be at least 25 percent more than the final test load to be applied. The test shall be carried out at cut off level or at maximum 1.5 m below G. L. as directed by the Engineer-in-Charge. Anchors, if provided, for load test shall be at specified distance away from test pile as per relevant I. S. Code of Practice and there shall be minimum two anchors at two ends of the pile. Details regarding the testing arrangement shall be submitted well in advance to the Engineer-in-Charge for his approval. Load tests shall only be undertaken after obtaining the approval.

4.3 The jack is to be hydraulically operated. The load applied to the pile shall be recorded either by a gauge in the hydraulic system or a proving ring duly calibrated from an approved laboratory before load tests. The sensitivity of the full load and in any event, the accuracy and sensitivity of the system is to be checked against an approved instrument.

A test certificate and fresh calibration chart as obtained from an approved laboratory for jack as well as pump supplying hydraulic power shall be produced before the Engineer-in-Charge well in advance before use for any load testing pile.

4.4 The settlement of the pile shall be recorded by three dial gauges recording to 0.02 mm and placed at equal distance around the test pile. The dial gauges shall be fixed on datum bars whose ends rest upon non-movable supports. The supports for datum bars with reference to which the settlement of the pile would be measured shall be at least 5d (d being the diameter of the circular pile or the side of the square pile) away and clear from the test piles, subject to a minimum of 1.5 meters.

4.5 The testing equipment employed shall be capable of loading a pile to failure or to three times the design loading.

4.6 Before testing the top of the pile shall be clipped off carefully till sound concrete is encountered. The projecting reinforcement shall be cut or bent suitably and the top finished smooth and level with plaster of Paris, when required or as directed by the Engineer-in-Charge. A series 25 mm thick bearing plates shall be placed on the head of the pile for jack to rest as directed by the Engineer-in-Charge.

4.7 The Contractor shall have to perform rotating load test on working piles on load as decided and selected by the Engineer-in-Charge and the results must satisfy the requirements of the test. At least one working pile of each diameter shall be tested. The test shall be carried out at cut-off level or at such level as per direction of the Engineer-in-Charge. The Contractor shall also have to carry out initial test on a non-working test pile as described below:

A. INITIAL TEST ON A NON-WORKING PILE:

i) The test load shall be applied in equal increments of amount one-fifth of the estimated safe load as directed by the Engineer-in-Charge. Each state of loading or unloading shall be maintained till the rate of movement of the pile top is not more than 0.02 cm per hour in the case of clayey soils and 0.1 mm per hour in 2 hours whichever is greater.

ii) The estimated safe load shall be maintained for 24 hours and settlements shall be observed and recorded every hour during the period.

iii) Time-settlement observation shall be made at the commencement and completion of each increment. The rebound observation shall be made with suitable unloading as per direction of the Engineer-in-Charge.

iv) The loading shall be continued till the settlement of the pile top equals one tenth of the diameter of the pile stem (one tenth of the side in case of square piles) or the load is two times the estimated safe load on the pile, whichever is earlier.

v) The safe load on pile shall be the minimum of the following:

a) Two thirds of the final load at which the total settlement attains value of 12 mm unless it is specified that a total settlement different from 12 mm is permissible or required in given case on the basis of nature and type of structure in which case the safe load shall correspond to actual total settlement permissible or required.

b) Fifty (50) percent of the final load at which the total settlement equal one tenth of the pile diameter of the size of the pile.

B. ROUTINE TEST ON WORKING PILE:

Load on the pile in routine test shall be applied upto and a half times the estimated safe load carrying capacity of the pile. The loading procedure and settlement observations shall be the same in initial test described hereinabove. The safe load on the pile shall be the minimum of the following:

a) Two third of the final load at which the total settlement attains a value of 12 mm unless it is specified that a total settlement different from 12 mm is permissible in a given case on the basis of nature and type of structure.

b) Fifty percent of the final load at which the total settlement equals one tenth of the pile diameter of size of the pile.

C. LATERAL LOAD ON WORKING PILE:

i) The Contractor shall have to carry out lateral load test on one vertical working pile. Reaction may be obtained from suitable set up as approved by the Engineer-in-Charge and hydraulic jack shall be inserted in between the loading set up and pile in order to apply the lateral load. Thrust pieces need be inserted on either end of the jack to fill up the gap. Lateral deflections shall be measured at cut-off level or at maximum 1.5 M below G. L. as directed by the Engineer-in-Charge by means of dial gauges fixed to immovable supports.

ii) Loading shall be applied in increments of about 20% of the estimated safe load till the rate of deflection reduces to 0.02 mm per hour in the case of clayey soil and 0.05 mm per hour in the case of sandy soils or 2 hours whichever is earlier.

iii) Displacements shall be measured by issuing at least two dial gauges spaced at 30 cm

and kept horizontally one above the other on test pile. Where it may not be possible to place one of the dial gauges on the line of jack axis, then the two dial gauges shall be kept at a distance of 30 cm at a suitable height and the displacement interpolated at load point from similar triangles To fix dial gauges on the pile surface, uneven surfaces shall be chipped of and 25 to 30 mm square glass piece shall be fixed to provide a smooth surface. The dial gauge tips shall rest on the East portion of the glass plate.

iv) The safe lateral load shall be the least of the following:

- a) Fifty (50) percent of the final load at which the total displacement increases to 12 mm.
- b) Final load at which total displacement corresponds to 5 mm.
- d) Load corresponding to any other specified displacement due to performance requirements.

4.8 All pile test data i.e., load, displacement and time shall be recorded in a suitable chart along with other information about the pile in a manner as directed by the Engineer-in-Charge.

From the data, curves shall be drawn showing load displacements and displacement time and safe load shall be indicated on the graphs.

All data and curves shall be submitted to the Engineer-in-Charge in triplicate copies along with the originals.

If on load testing, it is found that the capacity of the pile is more than the designed capacity nothing shall be paid extra for such extra capacities.

SECRETARY

ASANSOL MUNICIPAL CORPORATION

SECTION- I

TECHNICAL SPECIFICATION OF PUMPS

1.0. GENERAL

The specification covers the design, manufacture, testing, supply erection and commissioning of the Vertical Turbine pumping unit for the Collector well pumping station of Kulti within A.M.C. at Paschim Bardhaman district. The equipment shall be designed and manufacture and tested in accordance with latest I.S specification and code of practice published by the Bureau of I.S whenever available.

CLEAR WATER PUMP

System particulars:

- | | |
|-----------------------|-----------------------------------------------|
| • Water | Clear water of River Damodar |
| • Temperature | 5 ⁰ C to 30 ⁰ C |
| • Sp Gravity | 1.1 |
| • Maximum water level | High Flood Level for river as per SWID Report |
| • Minimum water level | Low Flood Level for river as per SWID Report |
| • Elevation | Within 500M MSL |

2.0 VERTICAL TURBINE (VT) PUMP

The Collector well pumping station is to be designed for four (4) pumps normally 2 (two) (2) pumps will be working in parallel while the remaining 2 (two) pumps will serve as standby. Delivery of all pumps of Chinakuri pumping station at Kulti is to be fed to the ground level reservoir or a common delivery manifold from where water feed to ground level reservoir by 700 mm dia. M.S. Pipe (the decision will be taken after receive of final design and drawing from bidder. Pipelines would be taken from the common delivery manifold of collector well for supply to the ground level reservoir 1 at Chinakuri High lift pump house through the rising main of 2 X 450 mm dia. 12 mm thick spiral mild welded M.S. Pipe of length about (2 x 400 meter) to ground level reservoir 1. The capacity of the each pumping units will be 755 M³ / hour and head (approx 25.00 meter) finally head will be designed by the Bidder.

DESIGN

The design, investigation, manufacturing, performance of the vertical execution pumps as specified hereinafter shall comply with the requirements of applicable codes, the latest applicable Indian / British / American / DIN standards, in particular and in that order of application, the following IS1520 Vertical turbine for filter, cold water.

3.1. The materials of the various components shall be as per data sheet or equivalent material conforming to applicable IS/ BS/ ASTM/ DIN Standards in that order of application.

3.2. In case of any contradiction between the aforesaid standards and the stipulations as per the technical specification as specified hereinafter, the stipulations of the technical specification shall prevail.

3.3. In case of contradiction between this specification and the pump data specification sheets enclosed, stipulations of the data specification sheets shall prevail.

4.0 PERFORMANCE REQUIREMENTS

4.1 The pump shall be designed to have best efficiency at the specified duty point. The Pump set shall be suitable for continuous operation at any point within the 'Range of Operation', so as to match with the system resistance curve.

4.2 Pumps shall have continuously rising head capacity characteristics from the specified duty point towards shut off point, the maximum being at shut off.

4.3 Pumps of each category shall be suitable for parallel operation. The head vs. capacity, the B.H.P vs. Capacity characteristics, etc., shall match to ensure equal load sharing and trouble free operation throughout the range. In the event of tripping of one of the operation pumps, the operated pumps shall be capable of passing the maximum flow through it as dictated by the system resistance corresponding to both maximum and minimum water level of River Damodar.

4.4 The pump motor set shall be designed in such a way that there is no damage on account of any reverse flow through the pump which may occur due to any mal operation of the system.

4.5 Where reverse flow through the pump is specified in data specification sheets, the drive motor shall be capable of bringing the pump to its rated speed in the normal direction from the point of maximum possible reverse speed without injurious heating, when power to the motor is restored with a minimum voltage of 90% at the motor terminal.

4.6 External head that may be imposed on the pump under reverse flow condition is to be decided by the Bidder after analysing the complete system and the particular abnormal condition of run. However, any specific requirement as mentioned in the Pump Data Sheet shall be adhered to Torque-speed curve for pump and motor for such reverse flow condition shall have to be submitted along with the offer.

5.0 PUMP (SELF LUBRICATED):- THE PUMP MAKE WILL BE KRILOSKAR / WPIL PREFERABLY.

BOWL ASSEMBLY: The Bronze bowl shall be flanged type construction of closed grained materials conform to latest I.S.S. They shall be free from sand holes, blowholes, or other fault and must be accurately machined and fitted to the close tolerance. The shall be capable of withstanding a hydrostatic pressure equal to twice the pressure at rated flow or 1.5 times shut of head which will be greater. The intermediate bowls shall have enamel or epoxy lined waterways for maximum efficacy and wear protection. All intermediate bowls shall be of identical design for interchange ability. A discharge bowl shall be used to connect the bowl assembly to the discharge column. All the bowls (include the discharge bowl) shall be fitted with sleeve type bearings of bronze alloy.

IMPELLER: The impeller shall be constructed from ASTM B584 silicon bronze and shall be the enclosed (or semi open) type. They shall be free from defects and must accurately cast, machined and filed for optimum performance and minimum vibration. Impeller shall be balanced to grade G6.3 of ISO 1940 as minimum. They shall be securely fastened to the bowl shaft with taper locks of C1018 steel.

SUCTION: The suction bowl shall be provided with non-soluble grease packed bronze metal packed bronze bearing from abrasives in the pumping fluids. The bearing housing shall have sufficient opening at the bottom for easy removal of the bearing.

SHAFT: The bowl shaft shall be constructed from ASTM 582 type 416 SS. It shall be precision ground and polished with surface finish better than 40 RMS.

6.0. COLUMN ASSEMBLY-WATER LUBRICATED FOR VT PUMP

COLUMN PIPE: The column pipe shall be furnished in section not exceeding a normal length 3.00 Meter (10 Ft) each and shall be connected by threaded-sleeve couplings. Pump speeds between 1450 rpm shall have intermediate column length and bearing spacing no greater than 1.5 Meter (5 Ft). The pipe shall be constructed from stainless steel ASTM 582 type 416 SS. and weight shall be not less than schedule 30. The end of the pipe shall be with 8 threads per inch with 3/16" taper per foot thread and faced parallel to butt centring spiders. The inside of the such that minimum head loss occur as per IS Specification.

LINE SHAFT: The line shaft shall be of stain less steel, ground and polished with surface finish as per standard specification. They shall be furnished in interchange ability facility and shall be coupled with threaded steel couplings machined from solid steel bar. It shall have left hand thread to tighten during pump operation condition. The shaft shall be provided with stainless steel sleeve to act as journal at each bearing location. The sleeve shall be placed on a full size shaft without under cutting and secured in position by a suitable adhesive.

BEARING: Bearing shall be fluted rubber retained in the cantering spider by a shoulder on each end on the bearing.

7.0. DISCHARGE HEAD ASSEMBLY – WATER LUBRICATED (SELF)

Discharge Head: It shall be of the high profile type to allow shaft coupled above stuffing box and provide for mounting the driver and support the column pipe and bowl assembly. It shall be of high grade D.I. / cast iron or fabricated M.S. Pipe 16 mm thick. It shall have a NTP (1/2") connection for a pressure gauge.

STUFFING BOX: The stuffing box shall be cast iron and shall contain a minimum of five rings packing. It shall have pressure relief connection. The packing gland shall be a split

type secured in place with non-corrosive studs and nuts. Rubber slingers shall be secured to the shaft above the packing gland.

HEAD SHAFT: The head shaft goes through the stuffing box shall be stainless steel. It shall be precision ground and polished with surface finish as per standard practice.

SUCTION BELL MOUTH & STRAINER: The suction bell mouth shall be sufficient length and shall have a minimum inside diameter and weight larger than the discharge column pipe. A suitable cone strainer of galvanised steel shall be provided having a free area at least four times of the flow area of the suction pipe.

8.0. TEST

8.1. GENERAL

- a) All pressure parts shall be subject to hydraulic testing at a pressure of 150% of shut off head or 200% of rated head (effective head) whichever is higher, for a period not less than 30 minutes.

- b) Performance-test is to be conducted to cover the entire range of operation of the pumps. These shall be carried out to a span of at least 125% of rated capacity up to pump shut off condition. A minimum of five combinations of head and capacity are to be achieved during testing to establish the performance curves including the design capacity points and the two extremities of the Range of operation specified. For range of operation, stipulation relevant in Clause is applicable.

- c) Tests shall preferably be conducted with actual drive motors furnished.
- d) Reports and test certificates of the above tests shall be submitted to the Engineer-in-charge for approval of the employer.
- e) All rotating components of the pumps shall be subjected to dynamic balancing tests, if specified, in Data Sheets.

9.0. TEST AT SHOP FLOOR

9.1. Each pump shall have to be tested to determine the performance curves of the pumps. These tests are to be conducted, in presence of Employer or his representative, as per the requirements of the Hydraulic Institute Standard / ASME Power Test Code PTE 8, 2/BS-599/I.S.S., latest edition.

9.2. The Contractor shall conduct necessary sump model test for establishing optimum sump dimensions / flow correcting devices and establish the suitability of suction conditions.

9.3. The Employer or his authorized representative shall be given full access to all tests, Prior to performance tests, the Contractor shall intimate the owner allowing adequate time so that if the Employer so desires, his representatives can witness the test.

9.4. The Bidder shall guarantee the effective head at the specified designed capacity and also the corresponding pump efficiency, pump input power, unless otherwise mentioned, the Bidder shall specify the allowable tolerance considered by him on the guaranteed performance.

9.5. The Bidder shall indicate the guaranteed efficiency of the pumps offered by him. While carrying out shop performance tests, the permissible limits of errors in measurement shall be in conformity with Class-B of BS: 599 without any penalty whatsoever. Apart from that a negative tolerance of maximum (-) 3% on quoted efficiency shall be acceptable only with penalty. Variation more than (-) 3% will render the pump liable to rejection, If the shop performance tests indicate any failure of the pump to achieve the guaranteed efficiency, the Contractor will be given a time, to be decided by the Owner, to make up the deficiency at his cost by incorporating necessary modification, alteration and replacement.

9.6. The manufacturers shall conduct all tests required to ensure that the equipment furnished shall conform the requirements of this specification and in compliance with requirements of applicable Codes and Standards. The particulars of the proposed tests and the procedures for the tests shall be submitted to the Employer for approval before conducting the tests. The pump is to be tested on the test bed at contractor's workshop in presence of the technical representatives of Municipal Engineering Directorate.

9.7. Where stage inspection is to be witnessed by Employer in addition to above, the bidder shall submit to the Employer at the initiation of the contract, the deadline of PERT-CHART showing the manufacturing progress and indicating the periods where inspection of the Employer or his authorized inspection agency is required at the manufacturer's premises.

9.8. Since stage inspection is to be witnessed by Employer, the various stages of inspection, together with the Program shall be submitted to the Employer. The inspection and test procedures shall also be submitted for Employer's approval.

10.0. PAINTING

10.1. Surface of all parts shall be cleaned to remove scale, dirt, oil, water, grease and other foreign objects prior to final assembly of the equipment. All openings shall be covered to guard against damage and entry of foreign objects.

10.2. All surfaces shall thoroughly be cleaned in a manner approved by the manufacturer for necessary paint coating to be applied on the surface. In case of any prevalent Standard / Codes on selection and application of painting / coating, the same shall be strictly adhered to. The colour code for finished painting on the external surface shall be subject to Employer's approval. Necessary finish paintings including touch up paints, if not applied at shop, shall be done by the Contractor from sealed containers for site application.

10.3. All parts shall be properly boxed, crated or otherwise protected for transportation to suit the mode of transportation. Exposed finished surfaces shall be thoroughly greased before transportation.

11.0. TOOLS AND TACKLE

11.1. The Bidder shall quote separately for a complete and unused set of all special tools, wrenches, etc. including toolboxes, specifying the quantum of requirement, for erection, maintenance, overhaul or complete replacement of equipment under this specification. A complete list of tools necessary shall be enclosed with the Proposal.

11.2. The Price quoted for tools shall not be considered for evaluation of Bid.

12.0. SPARE PARTS

12.1. The Bidder is to supply spare parts as per list enclosed vide list of spare parts.

12.2. The spare parts as mentioned are to be supplied within the completion period of the contract.

12.3. Cost of spare parts as above are to be mentioned separately.

12.4 Replacement of spare parts during contract period would be borne by the Bidder at their own cost. The Bidder is required to provide a list of spare parts for a period of two years for further maintenance.

13.0. DELIVERY

13.1. The schedule of the project demands early delivery of the equipment's.

13.2 The delivery date shall be indicated by the Bidder in the Progress Schedule showing the time required for different phases of the work under the scope of this specification taking the date of issue of Letter of Intent as datum.

13.3. The Bidder shall guarantee the delivery date subject to penalty.

14.0. DRAWINGS, CURVES & INFORMATION

14.1 Characteristic curves of pumps showing effective head pump input power, efficiency, and submergence/NPSH, against capacity ranging from shut off condition to at least 125% of rated capacity.

14.2 Speed vs. torque curve of the pump corresponding to recommended mode of pump starting, superimposed on speed Vs. torque curves of the motor, corresponding to 85%, 90%, 100% rated voltage and also extending over quadrant I & Quadrant II covering reverse flow conditions, if applicable.

14.3. Diagram showing the type of lubrication system, etc.

14.4 Complete descriptive and illustrated literature on the equipment and accessories being offered.

14.5 Experience list for the similar type of equipment supplied, which should indicate name of customer, date of ordering, and value of order date of commissioning, pump parameters and number.

14.6 A comprehensive write up or brochure on the details of manufacturing and test rig facilities in the shop of the manufacturer.

14.7 The successful bidder shall furnish the following drawings/data for Employer's approval after award of the contract.

14.8 All data furnished during bidding stage including details furnished above shall be treated as final and binding on the Contractor if, however, any, minor change is essential during detail design stage for any improvement of the system, such changes shall be carried out only after obtaining approval of the Employer.

14.9 The G.D² valves of the impeller of the pump and Rotor of the motor not less than 750 R.P.M. (syn.) are to be supplied.

15.0. INSTRUCTION MANUALS

15.1 The instruction manual shall present the following basic categories of information in a comprehensive manner prepared for use by operating and/or maintenance personnel:

15.2. Instruction of Erection

15.3. Instruction for pre-commissioning check-up, operation, abnormal conditions, maintenance and repair.

15.4. Write up on Controls and interlocks provided.

15.5. Recommended inspection points and periods of inspections.

15.6. Schedule of preventive maintenance.

15.7. Ordering information for all replacement parts.

15.8. Recommendation for type of lubricants, lubricating points, frequency of lubrication and lubricant changing schedule.

15.9. The information shall be organized in a logical and orderly sequence. A general description of the equipment including significant technical characteristics shall be included to familiarize operating and maintenance personnel with the equipment.

15.10. Necessary drawings and/or other illustrations shall be included or copies of appropriate final drawings shall be bound in the manual. Test, adjustment and calibration information as appropriate shall be included and shall be identified to the specific equipment. Safety and other warning notices and installations, maintenance and operating cautions shall be emphasized.

15.11. A parts list shall be included showing part nomenclature, manufacture's part number and/ or other information necessary for accurate identification and ordering of replacement parts.

15.12. Instruction manual shall be securely bound in durable folder.

15.13. If a standard manual is furnished covering more than the specific equipment purchased, the applicable model (or other identification) number, parts number and other information for the specific equipment purchased shall be clearly identified and highlighted. Sectional drawing to suitable scale and characteristic curves for the particular equipment supplied must be included in the Instruction manual.

15.14. The Instruction Manual shall include the list of spare parts that are required for 2 years normal operation and maintenance for equipment. It shall also include list of all special tools and tackle furnished with complete drawings and instructions for use of such tools and tackles.

15.15. The instruction manual shall need approval of Employer in the same fashion as that for drawings.

16.0. DEVIATIONS

The Bidder is required to submit with his proposal a detailed list of any and all exceptions taken to this specification by filling up the Deviations Sheet. In absence of such a list it will be understood and agreed that Bidder's proposal is based on strict conformance to the specification in all respects. These requirements, however, are not intended to prohibit Bidders from offering alternate quotation for equipment which they consider to be equal or superior to that specified for the intended service and for which he believes he can show

economic and/or technical advantages, provided that he is not allowed to add to the Vendors list and is confined to items not appearing therein.

17.0. DATA SHEET/ CHECK LIST OF THE PUMPS BEING OFFERED: -

(Submitted by the lowest Bidder after issuing the work order)

Sl. No.	Data sheet of Pump-Motor	Check List of the pumps motor being offered
	A) GENERAL:-	
01.	Manufacturer of Pump	WPIL / Kriloskar / Mather & Plate or equivalent
02.	Model Number	
03.	Type of Pump	Vertical Turbine pump
04.	Non Pullout	Yes / No
05.	Impeller Type	Closed / semi open
06.	No. of Pumps offered	4 Nos. (2 working and 2 standby)
07.	Efficiency of Pump at peak flow condition	
08.	Efficiency of Pump at medium flow condition	
09.	Efficiency of Pump at lean flow condition	
	B) PERFORMANCES:-	
01.	Guaranteed capacity - M3/hr. in peak flow Without tolerance in single operation & parallel operation	755 cum. per hour
02.	Guaranteed head (total bowl head) - MWC at Peak flow discharge, without tolerance in single operation & parallel operation.	
03.	Guaranteed pump efficiency, without in single operation & parallel operation tolerance in peak head / flow.	
04.	Input to the pump (KW) in peak head/flow In single operation & parallel operation without tolerance.	
05.	Pump input power at worst operating condition on the range of operation (without positive tolerance).	
06.	Pump input power at shut off	
07.	Range of operation of Pump	

08.	Recommended Motor KW	
09.	Pump rated speed (RPM)	
10.	Pump specific speed of particular trim at D.P.	
11.	Pump shut off head	
12.	Minimum submergence required in MWC at worst flow condition.	
13.	Are the pumps suitable for parallel operation	
14.	Whether non-Reserve Ratchet is provided in pump or not.	
15.	Type of lubrication for pump	
16.	Whether pre lubrication arrangement provided.	
	C) PUMP NPSHR	
01.	-do- at highest water level condition	
02.	-do- at lowest water level condition	
03.	-do- in the operating range, without positive tolerance.	
04.	Pump duty: continuous intermittent	
05.	Pump shut off head	
	D) FLEXIBLE JOINTS AND SHAFT	
01.	Flexible Coupling	
02.	Type	
03.	Make	
04.	Factor of Safety adopted	
05.	Degree of Flexibility	
06.	Extent of Play allowed	
07.	Shaft diameter (Extension if required)	
08.	Material	
09.	Factor of Safety adopted	
	E) THRUST BEARING	
01.	Type	
02.	Whether separate thrust bearing for pump	

	motor provided or not.	
03.	Method of lubrication	
04.	Whether the thrust bearing is capable for worst loading of both phases.	
05.	Axial thrust at duty point (kg) approx.	
06.	Whether thrust bearing temperature detector provided.	
	F) MATERIAL OF CONSTRUCTION	
01.	Impeller	
02.	Casing	
03.	Casing Ring	
04.	Pump shaft	
05.	Coupling for pump Motor	
06.	Shaft Sleeve	
07.	Sole Plate	
08.	Impeller Ring	
09.	Seal Ring	
	G) EXPECTED LIVES UNDER NORMAL OPERATION AND MAINTENANCE	
01.	Impellers	
02.	Pump Bowl Casing	
03.	Shaft (If Required)	
04.	Thrust Bearing	

19.0. INSTALLATION OF PUMP MOTOR SET

19.1. Pumps and motors are normally despatched to the site in dismantled condition, sole plate, rotating element and all other equipment like shaft couplings and housing, stool etc. are packed separately. After receiving the materials at site all boxes should be opened and materials checked against respective packing. The protective coatings and wrappings should be removed before erection-if necessary.

19.2. Checking / preparation of foundation block if necessary should be done.

19.3. The pump assembly, including the solo plate should be level up by using Engineer's spirit level about 0-05 mm type in 254 mm and "I" beam type straight edge placed on the mechanical surface of the solo plate and adjust the thickness of the packing by shimming until the assembly is levelled.

19.4. When the solo plate is levelled and positioned with find datum, levels foundation bolts may be grouted.

19.5. Once the solo plate is levelled the pump half casing may be lowered on solo plate accurately in holding bolts and tighten the nuts.

19.6. Fix another pump half of flexible coupling on driving end side. Recheck the level on pump half coupling .Any adjustment, if necessary, can be made by shimming between solo plate and packer plate.

19.7. The motor unit are placed and coupled with pumping unit and check the alignment by precision type dial gauge.

19.8. Following variation which can be tolerated. Angular alignment 1- 0.07 and Spiral welded mild steel alignment not to exceed-0.1 mm.

20.0 TECHNICAL REQUIREMENTS AND CALCULATIONS

a) Tenderer are required to furnish the following technical particulars by the lowest tender without fail after issuing the work order.

b) Detailed system head calculations including H-Q, P-Q, Efficiency-Q, NPSH-Q etc. curves at various level conditions in solo and parallel condition superimposed on the system resistance curve, the printed family curve of the pump model offered shall be furnished along with offer.

c) Detailed calculations showing adequacy of NPSHA having at least 0.5m margin over NPSHR even at lowest water level condition as has been asked for in the technical specifications of the pumps elsewhere.

Note : To work out the system head on Hazen-William's formula to arrive out the pipe frictional losses taking 'C' value as 90 for all CI Piping shall be considered (This is

completely arbitrary – it must be fixed after testing the pipe lines) and for C value of DI as 140.

The following 'K' values for valves, specials shall be considered as follows. Sluice Valve: 0.4 Non Return Valves: 2.5 Butterfly Valve: 0.35.

OTHER SPECIALS: GUIDELINE AS PER CPHEEO MANUAL:-

Note: Units used for the curves/data shall be as follows (Language shall be in English)

Flow Rate : 755 M³ / hour each (collector well) for clear water pumping station.

Head, NPSH : 25.00 Meter (approx) MWC

Power : -----KW

Efficiency : -----%

- a. The following flow velocities shall be maintained for the pump suction and delivery branches:

Pipe diameter	Suction Side	Delivery Side
Up to D N 150 mm.	0.6 to 1.0 m/s	1.0 to 1.7 m/s
D N 200 mm. to D N 450 mm.	0.8 to 1.2 m/s	1.7 to 1.9 m/s
D N 500 mm. to D N 1000 mm.	1.0 to 1.5 m/s	1.7 to 2.2 m/s

- b) The following pipe specification shall be followed to determine frictional losses in pipelines:

- i) For sizes up to DN150, ERW black pipes / Stainless steel ASTM 582 type 416 SS for suction pipe to IS: 1239 Part-I (Hvy) and IS: 1239 Part-II (Hvy) fittings to be followed.

- ii) For sizes DN200 to DN350, ERW black pipes / Stainless steel ASTM 582 type 416 SS for suction pipe to IS: 3589 having wall thickness 7.1 mm. and 7.9 mm. for sizes DN400 to DN500. Fittings shall be fabricated from parent pipes.

- c) Obligatory Data & Information to the tenderer to work out the system head for feeding the OHRs. For the purpose of working out the detailed engineering on various system requirements, the following data and information shall be applied.

For the purpose of working out the detailed engineering on various system requirements, the following data and information shall be applied.

Sl. No.	Description of item	Data to be Considered for Design Purpose
1	Average ground level of site above MSL	±50.00 M
2	Liquid to be handled for pumping	Filter Water
3	Turbidity	Up to as per test report NTU
4	Temperature	12 °C to 37 °C
5	Specific Gravity	1.01
6	No. of Pump Motor set to be installed	(2 W + 2 SB) 755 M ³ /hr for each pump.
7	Likely supply voltage at plant premises	11KV & 415V ± 10%, 50Hz. ± 3%, 3 phase
8	Discharge station flow at duty point	(2 W + 2 SB) 755 M ³ /hr for each pump.
9.	Suction and delivery common manifold	Separate as per site requirement
10	After awarding the job the mechanical drawings shall have to be submitted with details hydraulics calculation	For approval

d) While calculating the pump TDH the tenderer must explicitly specify the length and diameter of pipes and specials they have selected while taking into account the velocity considerations given earlier in this NIT. The rates quoted by the tenderer in the BOQ / Price Schedule shall be assumed to be for that particular diameter of pipes, specials & valves etc. This calculation sheet along with table of pipes and specials should be given after issuing the work order.

SECRETARY
ASANSOL MUNICIPAL CORPORATION

SECTION – J

MECHANICAL WORK

1.0 MECHANICAL WORKS

The specification covers the design, manufacture, testing, supply erection and commissioning of the vertical pumping unit at intake jetty pumping station for Asansol Municipal Corporation. The equipment shall be designed and manufacture and tested in accordance with latest I.S specification and code of practice published by the Bureau of I.S whenever available.

1.1 SLUICE VALVES

The sluice valves shall be manufactured from closed grain Gray cast iron conforming to IS: 14846 of the year 2000 of Kriloskar / Kalpana / Upadhyay make and PN 1.6. Flange ends as per IS: 1538 or as per other standards to match with other flanges. The Body shall be of CI I.S. 210 FG 200. The delivery side sluice valves shall have by-pass arrangement but suction side slice vale the by-pass arrangement not acceptable. The seat pressure shall be 10 kg/cm² and body pressure shall be 15 kg/cm². The valves should pass through hydrostatics test for duration of 10 minutes. Materials of construction test certificate & ultrasonic test report shall be provided during supplies. The sluice valves shall be non-rising/rising-spindle type with gearing arrangement for easy manual operation and electrical actuator as specified.

1.2 BUTTERFLY VALVES

The butterfly valves shall be CIDF, long wiper type, PN 1.6, conforming to IS 13095 of 1996 of Kriloskar / Kalpana / Upadhyay make. The seat pressure shall be 10 kg/cm² and body pressure shall be 15 kg/cm². The valve shall operate smoothly & steadily in both directions, free from flow-induced vibrations. It should provide tight shut off closures & shall be suitable for frequent operation as well as from throttled duty conditions. The valve disk should rotate 90 from full open to full close. The valve disk shall be solid streamlined slab design, and to have minimum headless. The scat ring shall be replaceable type and to be bolted on the body. The rubber seal on the disk must be of easy replaceable type with the facility to be replaced at site. The valve shall have suitable and adequate capacity of gearbox for electrical actuator control with hand wheel and indicating pointer.

1.3 NON RETURN VALVE

The non-return valves is Kinetic Zero velocity type and shall be manufactured from closed grain Gray cast iron conforming to IS5312 part I & BSEN 12334 of Kriloskar / Kalpana / Upadhyay make and PN 1.6. Flange ends as per IS 1538 or as per other standards to match with other flanges. The body seat shall be of CI / DI. The non-return valves shall have by-pass arrangement with single door type with quick closing type as required for trip of the pumping unit. The seat pressure shall be 10 kg/cm² and body pressure shall be 15 kg/cm². The valves should pass through hydrostatics test for duration of 30 minutes. Materials of construction test certificates & ultrasonic test report shall be provided during supplies. The suction side sluice valves shall be rising-spindle type with gearing arrangement for easy manual operation.

1.4 DISMANTLING JOINT / RUBBER EXPANSION JOINT

One dismantling joints of diameter equal to diameter of the delivery line of each individual pumping unit shall be incorporated for easy removal of the valves etc.

1.5 PUMP DELIVERY PIPING AND COMMON DELIVERY MANIFOLD

The pump individual delivery / Suction side piping shall be of suitable designed diameter made from Stainless steel ASTM 582 type 416 SS not less than 8 mm thick plates painted both inside and outside by anticorrosive epoxy paints. The pipes shall be of welded joints and shall consist of necessary companion flanges so as to connect the piping with the DL Valves/Special of the individual pump delivery branch. The pump individual delivery side piping shall be connected to the common delivery manifold as per the layout. Necessary gaskets of suitable thickness shall have to be provided to all flange Joints complete with all necessary nuts, bolts, washers etc. The length shall be ascertained from the layout and the exact dimensions of the valves/specials. The Bidder should also provide the necessary arrangements to encounter the horizontal back thrust and the details as per the pump manufacture's recommendation shall be clearly indicated in the layout drawing.

The common delivery manifold shall be of requisite diameter and shall be of S. W. M.S. of not less than 16 mm thick. The common manifold shall have blank flange on both sides / one side with adequate stiffening. The length of the manifold must be extended at least one meter on both sides after the interconnections with the delivery pipe lines from the pumps at the two extreme ends to provide DJ, B/F valve & blank flange. The

maximum distance of the manifold from the outer wall of the pump house would be within 3m.

The common delivery manifold shall be provided with one no. temper proof air release valve (double throat) suitably placed. The pipe shall be laid underground and shall be painted with anticorrosive paints at the inside and outside shall be wrapped and coated with corporate of not less than 4mm thick so as to prevent the pipes from corrosion.

(Necessary surface finish for proper painting and wrapping coating shall be made by the contractor and careful laying shall be done so as to prevent damages during laying).

1.6 ELECTRICALLY OPERATED OVERHEAD CRANE AT COLLECTOR WELL PUMPING STATION AND MANUALLY OPERATED CRANE AT STARTING POINT OF FOOT WAY BRIDGE FOR LOADING AND UNLOADING OF PUMP- MOTOR INTO TRUCK:-

Provisions have to be made for 1) one No. 10.0 M.T. capacity electrically operated travelling Crane suitable for winching operation with a lift up to motor floor level and longitudinal travel of 12 M for handing pump, motor and other accessories and 2) one No 10.0 M.T. capacity hand operated crane Chain pulley type at starting point of foot way bridge for loading and unloading of Pump-motor into truck. They shall be of reputed make as per vendor list and as approved by Engineer-in-Charge. Suitable type of crane rails, girders and all other accessories as necessary for installation and operation of the crane are to be designed and provided by the contractor within the lump sum pipe quoted. The two travels and two hoists i.e. long cross & main Auxiliary etc. must be mechanical operation. The buffers must be spring-loaded operation. Suitable vertical clearance is to be provided over the rail level to the bottom of the roof beam (approx 1.5 M)

1.7 STEEL STRUCTURE

All steel structure shall conform to IS: 226-1962 except for M.S steel plate over 20 mm thickness which shall conform to IS: 2062-1962. Rails will be carbon or medium manganese steel, conforming to latest IRS-T-12 or IRS-T-18 specification. For detailing and construction of welded connections all provisions of IS: 816 (latest) shall apply. All rivets and bolts are to be generally of 20 mm or 22 mm dia. except where otherwise

required or noted. Where no load is shown in the trusses, bracing or latticed members, minimum 2 nos. 20 mm dia. rivets or equivalent welding to be provided. Bolted connections shall be provided at temporary sides and ends where extensions are indicated. All connections are to be riveted, welded or fitted with high strength friction grip bolts except for hand rails and cat walkways which may be bolted (Black bolts). Unless otherwise stated, all bolts under different tension are to be provided with one spring washer.

1.9 BOLTS AND NUTS

M.S bolts and nuts shall conform to IS: 1363, 1364 and 1367(latest). All nuts and bolts and washers coming in contact with shall be galvanized by a process which does not make the threaded uneven. All bolts, nuts and washer coming in contact with liquid or in corrosive atmosphere shall be made of S.S 316 or nylon depending upon the nature of the service.

1.10 OPEN THREAD MESH PLANTING

The contractor shall supply and install galvanized (hot dipped after fabrications) mild steel open thread mesh flooring at pipe trenches and of the rotating bridge decking including all kerbing. The planting shall be designed to withstand a maximum uniformity distributed shall be designed to withstand a maximum uniformity distributed load 1000 kg/sq m. The plating shall be divided into panels weighing not more than 50 kg and each complete with nosing all round. Cut outs shall be provided and trimmed so that the plating.

1.11 COUPLING

The bidder shall be provided the coupling for motors and pumps together with a suitable guard complying with BS: 1943 and BSC: 3004. The materials of the guard shall be of anti-spark types. Couplings shall incorporate all necessary flexibility for axial, lateral and torsion movements to deal with shock vibrator and driving equipment of the transmitted load.

1.12 JOINING

The joining shall be made with compressible rubber IS: 638 of thickness 3 mm, bolts and nuts. The bolts and nuts shall be of mild steel and these shall conform to IS: 1362 and 1363 unless otherwise specified.

1.13 GROUTING

The bidder shall include in his price all cost of labour and materials for grouting in all fixing ,piping and etc. at the time of construction. The contractor shall make arrangement for delivery of such items which will be grouted in the building work in time so that construction work can process smoothly without hampering of the construction work.

1.14 SUPPORT AND FIXING

All supports, fixing bolt, screws, and other fixings shall be provided by the contractor and its price be inclusive of such items.

1.15 DRIVING UNIT AND SUPPORT

Each driving unit shall be supported on a cast iron or fabricated steel frame on guide rails as appropriate. The fabricated frame shall be constructed to afford adequate access to the coupling between the driving motor and driving unit.

1.16 DISIMILAR METALS

Where metals of dissimilar character will required to be used in the construction, precautions should be taken to prevent deteriorations of the structure due to electrolytic action.

1.17 UNLOADING, HANDLING & STORAGE

The contractor shall be responsible for the delivery at site of all equipment, material and supplies required for the fulfilment of the contract up to handing over the plant to the ULB. The contractor shall at his own cost and responsibility transport or shift to plant site, all materials, equipment and other component furnished for the purpose of this contact. All movement of materials and equipment to and from storage shall be at the expense of the contractor. Space for storage facilities will be provided by the ULB at the site as workable. If contractor does not promptly shift and place for use in the premises, where is the work to be done, any materials, equipment or supplies delivered, the ULB may be do so, and charge all the cost thereof to the cost thereof the contractor and in any event the ULB shall not be responsible for any damages, arising out of, or in any connected with each shifting, or placing of the same. The bidder shall after further shifting or placing of the same. The contractor further after shifting, unpack the materials, verify the contents against invoice and notify storage or breakage to the engineer within one week of the

receipt of materials and equipment at site, failing which the contractor held responsible for any consequence. If required by the engineer, the plan method of transportation of equipment shall be submitted to the Engineer for approval. This approval shall be submitted to the Engineer for approval. This approval shall not relieve the Bidder of any responsibilities for the safety of the Equipment and personnel.

1.18 BIDDER OBLIGATIONS

Over and above the responsibilities of the contractor stipulated in the documents, following obligation fulfilled by the bidder.

The contractor shall satisfy the Engineer that adequate provision has been made

- b) To carry out his instruction fully and with prompt attitude.
- c) To ensure that parts required to be inspected before use are not use before inspection and to ensure that adequate supervision is provide at all stages of the work and each portion of the work and each portion of the work is checked before erection.

The contractor shall make necessary arrangement including provision of suitable space and facilities for testing, for inspection at any stage of manufacture of plant and equipment by the Engineer or his authorize representative as and when deemed necessary by the Engineer; the time schedule for any inspection will, however, follow the inspection scheduled suggested by the contractor and agreed upon by the Engineer during scrutiny of the delivery plain. Irrespective of any inspection and tests made by the Engineer the contractor shall be entirely responsible for the execution of the testing or inspection. At least 21 days' notice shall be required for the inspection to be carried out.

1.19 SHOP TEST

Shop test shall include all tests to be carried out at Bidder's work, works of his agent at manufactures works and at works where raw materials supplied for manufacture of equipment

The test to be carried out shall not be limited to the tests mentioned bellow:

- 2 Composition of all materials, casting, forgings etc.
- 3 Hydraulics test for pressure vessels, tanks, pumps casting etc.
- 4 Hydraulics test for valves, specials etc.
- 5 Test to check in faults in rubber lining as per IS: 4682 or its equivalent and painting.

- 6 Static and dynamic balancing of the impellers.
- 7 Performance test of (Head, Capacity, and BHP) pump (all type) and air blower.
- 8 Test on motors as per IS: 4029, IS: 325.
- 9 Other test that may be provided in different I.S.S
- 10 Other test provided elsewhere in the Bid.
- 11 Any other tests considered necessary by the Engineer.

31.0 All test certificate and reports shall be submitted to the S.E for approval. All tests are normally carried out in presence of the Engineer or his Authorized Representative. However, waiver may be allowed in specific by the Engineer at his discretion.

32.0 The engineer or his Representative shall be given to full access to witness the test. The contractor shall inform the S.E allowing adequate time so that E.I.C or his Representative can witness the test. The manufacturer / Bidder have to bear relevant costs of such inspection by two Representatives of MED/ULB to the manufacturer's factory and arrange accommodation & to and fro return ticket (as per eligibility).

33.0 No component or equipment shall be despatched unless accompanied by approval & test certificate and report. The approval shall be given provided the corresponding drawings/ technical particulars are already approved and the Engineer or his Representative agents have witnessed the test or a letter of inspection waiver is issued by the E.I.C

1.20 SITE TEST

After erection at site, all components / equipment as described below shall be tested to prove satisfactorily performance and / or fulfilment of functional requirement without showing of defect as individual equipment and as well as a system. The bidder makes all arrangement for testing and informs the Engineer for witnessing the following tests, which again, are not exhaustive.

a) All pipes and fittings and valves, after installation will be tested hydraulically at a pressure (as per relevant IS), at least 1.5 times the maximum attainable pressure in the system, to check against leakage & tightness.

b) All manual operated valves / gates shall be operated throughout 100 %, of the travel and these should be function without any trouble.

c) All pump motor shall be run with the specified fluid from shut off conditions to valve wide open. During the test condition the pump motor set shall run without any production of undue vibration, leakage through gland, temperature rising in bearing part, noise, flow pulsation etc.

i) Visual check on all structural components , welding , riveting rubber lining, FRP lining etc. and if doubt rise will be tested again.

ii) All hoist and its components shall be subjected to double the full working load during all motions without showing any distress.

iii) All test instrument and equipment duly calibrated shall be furnished by the bidder to the satisfaction of E.I.C

1.21 COMMISSIONING AND PERFORMANCE TESTS

The contractor shall undertake the complete responsibility for successful erection and commissioning of the plant and demonstrate successful performance test.

The commissioning of the plant shall be involve the following steps of operation

a) Testing of each unit on no load, to make complete to check complete check of its mechanical operation, alignment, clearance and rigidity and making necessary adjustment or alteration required to make such unit properly mechanically with tolerable vibration and sound levels, tolerance being reduced for no load operation.

b) After the mechanical check has been made, as stated above the equipment shall be energized and run progressively from no load to full load within limits of vibration and sound etc.

c) Therefore trial run of the plant under completion shall be taken at normal load operating condition for which the respective plant is designed for.

d) The initial performance test shall be carried out at least 24 hour continuous operation.

1.22 ELECTRICAL ACTUATOR

The delivery side sluice valves and the butterfly valves shall be electrically operated auto / manual syncope / syncroset type actuator with local remote control system and each shall be completed with suitable head stock, motor, starter with reversing control gear, limit switch, torque switch shall be fitted on an indicator board showing the exact amount of valve opening. They will also automatically cut off at the extreme end of valve gate travel. The valve shall also be provided with necessary arrangement for operating the valve manually in case of emergency. The safety interlock switch will automatically cut off the current in case the valve is operated manually. Self-powered local and remote digital display of percentage opening of the valves is to be incorporated.

DATA

- a. Make
- b. Type
- c. Capacity with rating of Motors
- d. Whether provided with limit & Torque Switches, if so, torque limit
- e. Protection Group (IP)
- f. Whether suitable for outdoor & temporary submergence duty/indoor type
- g. Whether equipped with suitable component & termination arrangement for transmitting signals for displaying valve opening % indicating in the valve opening indication meters. I.S Standard to which it conforms

1.23 TEMPER PROOF KINETIC AIR RELEASE VALVE

The temper proof kinetic air release valve valves shall be manufactured from cast iron conforming to IS: 14845 of the year 2000. The Body shall be of C I I .S. 210 FG 200. The valves shall have small orifice with bronze ball and larger ball will be made of SS and seal ring will be natural rubber arrangement. The body pressure shall be 15 kg/cm². The valves should pass through hydrostatics test for duration of 30 minutes. Materials of construction test certificate & ultrasonic test report shall be provided during supplies. No leakages of water takes place at the time of running and have to be maintenance free longer life.

1.24 FLOW METER & DISCHARGER METER

To measure the flow and discharge from the pumping station and recording arrangement (Digital meter) shall have to be placed in the delivery main and also transmit the sense to the recording arrangement. This will be placed over the ground or the underground.

SECRETARY

ASANSOL MUNICIPAL CORPORATION

SECTION-K

MOTOR CONTROL PANEL

MOTOR CONTROL PANEL AND POWER DISTRIBUTION PANEL

1.0. GENERAL

The motor control panel cum power distribution board is intended to receive electrical power through suitable size Air Circuit Breaker, effectively control the motor operation having facility both local manual operations of the motors at suitable places located nearer to the individual motors and remote operation of the motor from the composite remote control panel, providing against mal functioning of the motor as well as to protect downstream load from the system fault and to distribute power to the other areas of activities.

The design manufacture and testing commissioning of MCC cum PDB with various components / equipment thereof covered by this specification shall comply with the latest issue of I S Specification and I.E Rules.

2.0. TECHNICAL SPECIFICATION OF MEDIUM VOLTAGE PANEL AT INTAKE PUMPING STATION

Medium voltage Panel is required to provide power to motor feeder, valve actuators, internal & external illumination purpose etc. The panel shall be suitable for $415 \pm 10\%$, $50\text{Hz} \pm 3\%$, 3 phase, 4-wire supply system and Degree of Protection IP-45 & 50 KA breaking capacity. The MV panel shall be 2 mm. CRCA sheet steel enclosed, floor mounted type, self-supporting, fully compartmentalized, dust proof, cubicle pattern draw out / non draw out type and all the compartments would be interlocked in such a way ,the door could not be opened unless the switch is in OFF position. It shall be finished painted with powder-coated paint after necessary chemical treatment for rust free surfaces and application of anti-rust chemical coating. The base frame of the panel shall be made of ISMC-75 channel. The panel shall be dead-front type with concealed type hinged doors at front and bolted covers at the rear. It shall have rear access and the cable termination arrangement shall be provided at the rear of the respective feeder modules where type undrilled cable gland plates would be provided for this purpose. The vertical dropper bus bars shall be placed in between two vertical aligned feeder modules. The bus for the panel shall be made of E91E graded Aluminium alloy insulated with 1.1 KV grade heat shrink

type PVC colour coded sleeve. The rating of the bus bar shall be below the 1000A then traditional System R Y B shall be adopted. Interleaved bus bar (R-Y-B-R-Y-B instead of RR-YY-BB) shall have to be provided for each phase and neutral at the top of the chamber continuous to avoid skin effect and proximity effect and also avoid unnecessary heat development, this system shall be adopted when the connected load 1000 amp onwards.

The current density of the bus bars shall not exceed 1 Amp / Sq.mm The bus bars shall be supported on non-hygroscopic type resin modulated insulators and the distance between insulators shall be so designed to make the bus bar system capable of withstanding a short circuit fault current of 50 KA (r.m.s.) for 1 Sec two cut out should be provided at the top bus chamber and covered with plate for future extension purpose. The front bus bar chamber shall be fully shrouded to avoid accidental contact with the live bus bars. The minimum clearance between bus bars and bus bar to earth shall be as per I.S specifications. Incoming breaker termination shall be done with extended bus bar arrangement.

The cable termination chamber shall be provided with cable supporting clamps. Each incoming breaker shall receive 4 nos. 1.1 KV 3 core / 3.5 cores not less than 400 sq. mm armoured Al Cable. For outgoing feeder the cable tray shall have to be provided in such a fashion that the cable will be taken out easily. The control wiring of the panel shall be done with 1.1 KV made PVC insulated, 2.5 sq.mm flexible copper wires with finned copper lugs and ferule marking at each end. Wire bunches routed through horizontal and vertical wire ways which provide support and order. All hinged door shall be earthed with flexible copper wire. Lifting arrangement should be provided for lifting the panel at the top of the panel 2 nos. space heaters with rotary switch shall be provided in bottom of the panel board.

All sheet metal shall be thoroughly diluted for de-rusting, resealing and shall be painted with two coats of red oxide primer prior to final painting. Final painting would be done by synthetic enamel paint.

THE INCOMING SIDE COMPRISING WITH THE FOLLOWINGS FOR EACH AIR CIRCUIT BREAKER (ACB) (WHEN ACCUMULATED LOAD ABOVE 50 KW)

Incomer from transformers electrically synchronised by phase sequence and connected at the two end of PDB panel providing by bus-coupler with 1250 Amp ACB will

be electrically operated draw out type 4 pole ACB breaking capacity 50KA and quick make break with trip free mechanism with the followings for intake jetty pumping station feeder.

- 1 No -96 sq. mm flushes mounted type (higher than breaker amp) Ammeter with selector switch and CTs. (Breaker Amp / 5 Amp)
- 1 No -96 sq. mm flushes mounted type 0-500 V Voltmeter with selector switch and protection fuses.
- 1 No -96 sq. mm flush mounted type Power factor Meter.
- 1 No -digital feeder protective relay with the function 3 phase over current & earth fault relay with high set
- 3 Nos. - Universal Voltage LEDs indicator for breaker on.
- 1 No- Circuit identification label
- 1 No.- Universal voltage LEDs indicator for breaker trip & trip set reset button

THE OUTGOING SIDE COMPRISING WITH THE FOLLOWINGS FOR EACH WITH SUITABLE RATING OF AIR CIRCUIT BREAKER (ACB) (WHEN ACCUMULATED LOAD ABOVE 50 KW)

Minimum 400 Amps / 2 to 2.5 times of rated current of the motor, Hand operated draw-out type 4 poles ACB breaking capacity 50KA and quick make break with trip free mechanism for motor control purpose with the followings for each breaker unit.

- 1 No -digital motor protection relay with voltage input with the function IDMT feature
- 3 Nos.- Universal voltage LEDs indicator for breaker on.
- 1 No.- Universal voltage LEDs indicator for breaker trip & trip set reset button.
- 1 No- Circuit identification label
- 1 No. 96 sq. mm flushes mounted type (higher than breaker Amp) Ammeter with selector switch and CTs. (Breaker Amp/5Amp)

MOULDED CASE CIRCUIT BREAKER (MCCB) (WHEN ACCUMULATED LOAD BELOW 50 KW)

One (1) no 2 to 2.5 times of rated current of the motor Amps, rotary handle Hand operated non draw-out type 4 pole MCCB breaking capacity 50KA and quick make break with trip free mechanism with thermal & under voltage release with the followings for each feeder.

- 1 No -96 sq. mm flushes mounted type (higher than breaker amp) Ammeter with selector switch and CTs. (Breaker Amp/5 Amp)

- 1 No. - Universal voltage LEDs indicator for breaker trip & trip set reset button.
- 1 No- Circuit identification label
- 3 Nos.- Universal voltage LEDs indicator for breaker on.

SOFT STARTER HEAVY DUTY WITH BYPASSES ARRANGEMENT FOR EACH VERTICAL TURBINE PUMP-MOTORS:-

A heavy duty soft starter shall have to be placed to ensure the absolute best possible stop of pumps without water hammer and to control the pressure surges and thereby avoiding unnecessary downtime. The following features shall have to be required to smooth control the pump motor units,

- a. Three phase controlled
- b. Operational voltage 208 - 690 V
- c. Wide rated control supply voltage 100 – 250 V , 50/ 60 Hz
- d. Bypass arrangement
- e. Anti corrosive protection arrangement.

AUTO TRANSFORMER STARTER (ATS) FOR EACH MOTOR (WHEN MOTOR KW EXCEEDING 50 KW)

Air break fully auto transformer starter shall be equipped with automatic contractor (rating of the contractor selection utilization category AC-4 and rating shall be 2 to 3 times of the motor full load current with necessary potential free auxiliary contractor and hold on coil voltage 220 / 240 volt.) suitable for starting and running of the motor. Natural / oil cooled autotransformer, suitable for motor starting duty, 6 start per hour with 65%, 75% and 85% tapping with first filling of oil. 3-12 second time delay timer for automatic change over from reduced voltage to full voltage by adopting “watch dog circuit” theory. 3-20 second time delay timer for the protection if the changeover not occurred. Start stop push button will be interlocked in such a fashion that the start push button shall not be functioned at running condition of the motor until unless motor stop. Suitable rated control fuses. CT operated thermal over load relay. Relay for single phase, under and over voltage, phase reversal protection. Universal voltage LEDs indicating lamp for start stop and trip. Set reset push button. Suitable rating Ammeter with selector switch, Temperature scanner/recorder connection with BTD & RTD motor 10+2 + spare channel with tripping device which trip the motor.

Another set of contractor (rating of the contractor selection – utilization category- AC-4 and rating shall be withstand heavy duty capacitor surge current with necessary potential free auxiliary contractor and hold on coil voltage 220/240 volt.) shall be provided for inter connecting the capacitor bank. The hold on coil of the contactor shall be connected with the timer circuit in such a manner that the capacitor will be on covering the accelerating time of the motor.

The heavy duty capacitor bank shall be in house / outside with the panel board after considering site condition and as per direction of EIC.

MOTOR PROTECTION CIRCUIT BREAKER (MPCB)/ MOULDED CASE CIRCUIT BREAKER (MCCB) FOR EACH MOTOR FEEDER (BELLOW 40 KW)

2 to 2.5 times of motor full load Amp 3 pole N-linked MPCB with short circuit & over load protection (Rotary Knob Type) of breaking capacity 50KA with trip indicating auxiliary contact with universal voltage LED indicating lamp with under voltage release 230V AC and door coupling handle including shaft with front mounting type auxiliary contact 1NO+1NC.for motor control purpose with the followings for each breaker unit. The capacitor bank shall be in house / outside with the panel board after considering site condition and as per direction of EIC.

- 3 Nos. - Universal voltage LEDs indicator lamp for on of the motor protection breaker (MPCB).
- 1 No.- 96 sq. mm flushes mounted type (higher than the breaker rating) Ammeter with selector switch and CTs.(breaker Amp/5 amp)
- 1 No. - Universal voltage LEDs indicator for breaker trip& trip set reset button.
- 1 No- Circuit identification label

FULLY AUTOMATIC STAR-DELTA STARTER (FASD) (WHEN MOTOR KW BELLOW 30 KW) FOR EACH MOTOR

Three (3) nos. air break contactor (rating of the contractor selection – utilization category AC-4 and rating shall be 2 to 3 times of the motor full load current with necessary potential free auxiliary contractor and hold on coil voltage 220/240 volt.) shall have to be connected with the 6 nos. lead of the motor terminals for forming the star-delta starter suitable for motor starting duty, 6 start per hour. 3-12 second time delay timer for automatic change over from star connection to delta connection. Start stop push button

will be interlocked in such a fashion that the start push button shall not be functioned at running condition of the motor until unless motor stop. Suitable rated control fuses. Suitable thermal over load relay range with 1 OFF and reset type, Relay for single phase, under and over voltage, phase reversal protection shall have to be incorporated in the circuit. Universal voltage LEDs indicating lamp for start stop and trip. Set reset push button.

Another set of contractor (rating of the contractor selection utilization category-AC-4 and rating shall be withstand capacitor surge current with necessary potential free auxiliary contractor and hold on coil voltage 220/240 volt.) shall be provided for inter connecting the capacitor bank. The hold on coil of the contactor shall be connected with the timer circuit in such a manner that the capacitor will be on covering the accelerating time of the motor.

The heavy duty capacitor bank shall be in house / outside with the panel board after considering site condition and as per direction of EIC.

MOULDED CASE CIRCUIT BREAKER (MCCB)/ MOTOR PROTECTION CIRCUIT BREAKER (MPCB) FOR EACH MOTOR FEEDER MOTOR RATING BELLOW 3KW

2to 2.5 times full load current of the motor Amp.3 pole N-linked MCCB with short circuit & over load protection (Rotary Knob Type) of breaking capacity 50 KA with microprocessor based release with auxiliary NO+NC contact, under voltage release 240V AC door coupling rotary handle with extension shaft with the followings for each MCCB

- 3 Nos.- Universal voltage LEDs indicator lamp for ON (MCCB).
- 1 No. 96 sq. mm flushes mounted type (higher the breaker rating) Ammeter with selector switch
- 1 Nos.- Universal voltage LEDs indicator for breaker trip & trip set reset button.
- 1 No- Circuit identification label

DIRECT ON LINE STARTER (DOL) FOR EACH MOTOR

Direct on line starter with single phase protection feature and also thermal overload relay range of ON / OFF and reset type. The contractor rating will be such a manner that have to withstand the full load current of the motor as well as starting current 7 to 8 times of the full load current of the motor and starting duty 6 start per hour. Start- stop push

button will be interlocked in such a fashion that the start push button shall not be functioned at running condition of the motor until unless motor stop .

MCCB FOR DIFFERENT FEEDER

Number and Amp (calculated according site condition) 3 pole N-linked MCCB for illumination and spare with the followings for each unit.

- 3 Nos.- Universal voltage LEDs indicator lamp for on .
- 1 No. 96 sq. mm flushes mounted type 50 Ammeter with selector switch
- 1 No- Circuit identification label

3.0. CHECKLIST OF MEDIUM VOLTAGE PANEL BEING OFFERED (SUBMITTED BY THE SUCCESSFUL BIDDER AFTER ISSUING THE WORK ORDER)

Sl. No.	Name of the items	Cheque List
A.	Make	
B.	Rated voltage / Rated current	415 Volt
C.	Short circuit current withstand capacity In KA	50 KA
D.	Sheet Steel Thickness	
E.	Degree of Protection.	IP-54
F.	Busbar Rating & Breaking Capacity 50 KA in Amp.	
G.	Busbar type	
	INCOMER	
H.	Incomer Type	ACB / MCCB
I.	Rating of the incomer in Volt and Amp.	
J.	Number of Incomer	Two
	INCOMER	
K.	Protective relay Type	Draw out type
L.	Relay Voltage	
M.	Relay feature (O.C & E.F)	Yes / No
N.	Used in feeder Incomer/ motor	Yes / No
	BUS COUPLER	
O.	Rating of the bus coupler in Amp.	

	OUTGOING FEEDER	
P.	Outgoing Type	ACB / MCCB /MPCB
Q.	Nos. of <i>outgoing</i>	
R.	Starting device in built or not in Volt and amp.	
S.	Starting device in built or not	No / Yes (if yes)
T.	Protective relay Type (Motor)	
U.	Capacitor reactor bank (Motor)	Individual / Bank
V.	Type of starter	Star-Delta / ATS / DOL
W.	Switch fuse unit Number &rating	
X.	Cable alley Number & Position	
Y.	Size Length Breadth Width in mm	

4.0. TESTING (IN PRESENCE OF DEPT. ENG,)

- Visual inspection for checking the panel components its voltage, current rating breaking capacity etc. as per approved drawing.
- The insulation test as Indian Electricity Rule
- The Relay tripping test as per specification
- The contractor shall supply 6 copies of certified copies of test report (factory)

5.0. INSTALLATION

5.1. Transport of materials from store to erection site

5.2. After opening the packing case, inspection of materials is required, if any damaged is occurred during transportation necessary rectification is to be done, if require touch up paint should be done where necessary.

5.3. All alignment levelling grouting anchoring and adjustment including inter panel locking as necessary in accordance with manufactures Any chipping / levelling insertion of packing plates minor attendance of board internals etc, as necessary for the above is in bidder scope.

5.4. Retightening the busbar and rechecking of the control panel wiring are in the bidder scope.

6.0. NUMBER OF PANEL

The MCC shall be provided with spare outgoing feeder as detailed below of followed the above technical specification and feed from the PDB.

- | | |
|------------------------------|------|
| 1. Collector well pump House | 1 No |
| 2. Substation LTPDB panel | 1 No |

The above mentioned MCC panel feed from a PDB panel shall be placed in a convenient position of the Collector well pumping station. The cabling / earthing of the individual panel are in the bidder scope. The receiving of the power through cabling from LT substation in the area of Collector Well pumping station is in the bidder scope.

7.0 CABLING

7.1. GENERAL

At the time of designing the HT cable the short circuit Current of the 350 MVA system fault level shall have to be considered. The voltage grade of the cable will be 11 KV grade stranded aluminium conductor PVC insulated armoured. All LT Cable power cable shall be 1.1 KV grade stranded aluminium conductor PVC insulated armoured and the control cable shall be of copper conductor, PVC insulated, armoured/XLPE insulated armoured. All power cable and control cable shall be laid neatly in covered masonry trench, fabricated cable trays. While selecting the cable size suitable de-rating factor shall be considered. Tenderer shall furnish a cable lamination plan giving type, size and length of the cable proposed to be used.

Cables used for clarifier power supply shall have at least one spare cable shall have to be draw. Both the free end of the cable shall be properly sealed protection against damaged. All cables within buildings shall be laid neatly on wall or on trays as the case may be and shall be readily accessible for inspection or replacement.

The LT control cable shall be of 660 volt grade, PVC 1.5/2.5 sq.mm multi stranded, multi-core screened cable of electrolytic copper conductor. Two spare cores shall have to left for future provision

7.2. CABLES AND LAYING

The cables shall be 1.1 KV grade for LT 3.5/3, 2/1 core XLPE aluminium conductor cable 4 Nos. of 400 sq mm size and length as per requirement for electrical loading. The

selection of the size of the cable will be considering voltage drop, 1.5-2 times of the normal current drawl by the load and de-rate factor of the cable when laid in ground, cable spacing and temperature of the ambient. All cable should as per relevant ISS specification. The cable will be ,if, necessary laid in underground trenches dimension for trench must be 450 mm width x 760 mm average depth, with brick protection on the top of the cable with 16 nos. bricks per meter and filling up the trenches with shifted soil, levelling up and restoring the surface to the satisfaction of the Engineer-in-Charge. Where cable is laid in masonry trench/metal trays, the cable trenches (when applicable) shall be filled up with sand or covered with chequered plate/RCC slab according to the direction of Engineer-in-Charge. Where necessary cables shall be supported on clamps of approved type and shall be properly protected with G.I. conduit or other protective covering as per direction of Engineer-in-Charge. Length of each type of cable should be assessed from G.A. drawing as well as physical verification from site.

7.3. GLAND & SOCKETS

7.3.1. For weather proof entry of armoured power & control cable through plain holes on equipment gland plate (Minimum threaded length 12 mm) threaded (ET) holes on equipment body / casing heavy duty brass machine finished & tined , double compression (as per BS 6121) thickness of plating not less than 10 mm. All washers and hardware will be on tin plated brass. Rubber components shall be of neoprene tested quality.

7.3.2. The socket shall be Dowell (Mumbai) make solder less crimping type tubular / sockets ring / fork ring / pin type tinned copper for power cable termination . Nylon straps, aluminium cable tags, plastic ferrules (Yellow with black engraving) coloured insulation sleeves and tapes and all other necessary termination accessories, hardware's and consumable will have to be provided.

7.3.3 The socketing can be done by hydraulic punching machine and gland plate hole shall have to be made by drilling machine.

8.0. WIRE MATERIALS OF ELECTRIFICATION:-

The wire for electrification indoor & outdoor should be PVC aluminium fire proof & weather proof sheathed wire. PVC conduit wiring should be done for electrification the pump house, LT substation room in such a manner that illumination level will be suitable for night maintenance work i.e. 120-200 lux. The ceiling fan (48 inch, 52 inch) with electronic

regulator, exhaust fan of 450mm size, man cooler fan for each motor and other luminary should be provided as per direction of E.I.C. The wiring should be done by using distribution box and loading of one circuit never greater than 8 points as per I.E rules. Necessary power plug point shall have to be provided as per direction of E.I.C. All luminaries' fittings shall be industrial corrosion proof.

9.0. EARTHING:-

The total electrical installation shall be effectively earthed by providing earthing arrangement. Each earthing station shall consists of 2 (two) G.I pipe of 50 mm dia. and 3.50 meter length sufficiently deep from the ground level and 2 meter away from the any civil structure and shall be acceptable any front side of the buildings and minimum distance between two the earthing station shall be maintained 3 meter. The Nos. of earthing station shall have to be done until unless the earth resistance value bellow 1 ohms.

Preparation of earth pit with necessary excavation and ground compaction/ foundation work with required masonry / bricks works including precast removable pit cover& necessary supply of coke breeze or charcoal, salt bricks, cement aggregates, gravels& sand. Making required hole in pit and wall for conductor with necessary hardware non corrosive type clamp nuts bolts etc. shall be provided.

After preparations of the pit underground horizontal counter poise (40mm MS rod) to be laid of a depth generally 1500 mm bellow the ground level or a greater depth as may be encounter to suit the site condition. Necessary drilling / digging for installation of UG vertical electrode and connection with horizontal counter poise to be done at four sides of the pump house. The riser pig tail from ground grid shall consists of one no 40 mm dia. rod / GI flat and shall be projected 300 mm above the ground level for location . All ground conductor connection below ground level shall be made of electric arc welding of 25 mm X 6 mm copper flat (necessary equivalent G.I flat as use of copper is restricted by G.O.I) All UG welded joints shall be treated with red led paint and afterwards should be coated with bituminous paint to prevent corrosion.

After installation of UG earthing network, back filling with suitable soil up to required level and compaction to be done. Back filling soil may be required to carry from nearby place / excavated soil.

Chipping / Floor finishing as necessary to ensure that over ground earthing conductor is bellow finished floor already exists.

All the electrical equipment shall have to be two separate earthing connection from the Ring main by 25 mm X 3 mm copper flat (necessary equivalent G.I flat as use of copper is restricted by G.O.I). No welding shall be allowed in the earth G.I flat. A separate neutral earthing of transformer arrangement shall have to be provided by the bidder.

10.0 TUBE LIGHT FITTINGS (LED)

The tube light fittings should be industrial corrosion proof with lamp and their fittings and fixing wiring should be done as per direction of EIC .Tube light fittings shall be Philips make LED light 22 Watts each single tube light. Each room shall be illuminated minimum 4 nos. LED tube light fittings but 12 nos. of twin LED tube light fittings shall be provided for illuminating the pump room.

11.0 YARD LIGHTING FOR INTAKE:-

For yard lighting arrangement 160 Watts / 144 Watts / 22 Watts Bollard type Philips make LED street light fittings and 210 Watts Philips make LED flood lights 9 M swan neck MS pole placing 9 M along the 5 M width road and post top lantern type light fittings shall be use where road width below the 5 meter Post top lantern type LED fittings shall be of Philips make post top lantern / decorative light fitting. All post top lantern shall be mounted on 76 NB GI medium pipe poles 7 M which shall be installed all along the roads at an average interval of 30 M. Pipe poles shall be buried in the ground with proper solid PCC foundation. Each pole shall be securely earthed with one 40 mm dia. GI pipe earth electrode and 6 SWG GI wire. Junction box with rewire able fuse for pipe pole shall be mounted above HFL.

12.0 TESTING COMMISSIONING:-

After completion of erection work test shall be conducted as per relevant applicable rules and regulations and as per instruction of EIC. Temporary arrangement of electrical connection if necessary for the test shall be provided by the contractor including required

instruments, tools & tackles, supervisory personnel and labour, the contractor shall record and furnish the test result in agreed format as per direction of EIC.

- a) Meggar Test
- b) HV Test
- c) Primary & secondary current injection test

13.0 CEILING FAN

Minimum 2 Nos. 1200 mm sweep ceiling fans are to be provided with electronic regulator and necessary wirings and clamps and down rod etc. In each room of the substation.

14.0 EXHAUST FAN

The exhaust fan should be of 450 mm with the louvers with necessary wiring etc as per direction of EIC. Necessary holes are required to be done. Minimum 2 Nos. Exhaust fan are to be provided in each room minimum 6 Nos. fan for intake pumping station.

15.0 FIRE EXTINGUISHER

Fire extinguisher (Dry type) of 4 numbers with same sand bucket shall be provided in each panel room for fire management purpose, shock treatment chart and rubber mat.

SECRETARY

ASANSOL MUNICIPAL CORPORATION

SECTION – L

ELECTRICAL MOTOR WORKS

1.0 GENERAL:

The specification covers the design, manufacture, testing, supply erection and commissioning of the electrical motor for the intake jetty pumping station at Chinakuri, Kulti, Asansol Municipal Corporation. The equipment shall be designed and manufacture and tested in accordance with latest I.S specification and code of practice published by the Bureau of I.S whenever available. The electrical equipment shall also conform to latest I.E Rules as regard safety, earthing etc.

System particulars:

- Voltage 415 Volt $\pm 10\%$
- Frequency 50 Hz $\pm 3\%$
- Climatic condition Tropical zed, Humid & Dusty
- Max Ambient Temp. 45 degree centigrade
- Annual Rainfall 100 mm (approx.)
- Elevation within 500 M MSL

2.0 MOTORS

2.1 This specification covers the general requirements of the drive motors.

2.2 Motor shall be furnished in accordance with both this general specification and the accompanying driven equipment specification.

2.3 In case of any discrepancy, the driven equipment specification shall be given.

3.0 STANDARDS

3.1 All motors shall conform to the latest applicable IS/BS/DIN publications. All the motors should be of ESF-1 category with an efficiency range of 96% and above.

3.2 The Motor shall be suitable for operation in hot humid, tropical atmosphere in polluted area.

3.3 Motors shall be deemed to be installed outdoor and exposed to 100% humidity constantly. The effect therefore shall be considered in the determination of the design.

3.4 The drive electrical motors shall be of squirrel cage induction type Vertical axis to suit the size of the pump and shall be able to drive the pumps. The rating of the motor shall

not be less than (for vertical pumping unit 20 – 30 % Of the pump BHP or suggested by the Pump manufacturer) of 415 V \pm 10%, 3 phase, 50 Hz \pm 3 %, designed RPM (Synchronised) and also suitable for drive the pumping units.

3.5 All the motors shall be rated for continuous duty operation (duty:S1 as specified in IS 325 1978).However, due to the operational schedule of the pumping station , the pump motor unit may demand for 8/10 start and stop in a day with minimum time gap of 20 minutes for one stop after prolong operation and restart the same. The motor shall also be capable of one immediate hot restart and three equiv.-space starts per hour. The motor shall also be suitable for long period of inactivity.

3.6 The motor characteristic shall match the requirements of the driven equipment so that adequate starting torque, accelerating, pull up, break down and full load torques are available for the intended service. It shall be drip and splash proof protected and well ventilated/ totally enclosed fan cooled

3.7 The motors shall be capable of working satisfactorily at full load for 5 minutes without injurious heating at 75% rated voltage at motor terminals.

3.8 Motor shall be designed for Autotransformer/Star-Delta/Direct on line starting device of 60% or 85% of full voltage. Starting current shall not exceed 2 to 3 times full load current for all auxiliaries subject to tolerance (IS)

3.9 Motor shall be designed for Star-Delta starting device of 57.7% of full voltage. Starting current shall not exceed 3 to 4 times full load current for all auxiliaries subject to I S tolerance.

3.10 Motor shall start with rated load and accelerate to full speed with rated voltage and accelerating time of the motor should not be more than 2 to 3 second.

3.11 The locked motor withstand time under hot condition at 110% rated voltage shall be more than motor starting time by at least 2.5 sec .

3.12 All motor enclosures shall be screen protected (SPDP) / totally enclosed fan cooled (TEFC) and conform to the degree of protection IP55

3.13 The stator windings shall be of class F insulation to ensure trouble free operation in an atmosphere where the relative humidity shall consistently be near to at 100%.The stator windings should have uniform machine wound single/ double layer formed coils with electrolytic grade copper conductors (99.9%)

3.14 The stator core is to be built up on low loss cold rolled dynamic grade laminated steel sheet insulated from one another by a thin layers of high heat resistant varnish-ventilated are to be provided to increase the cooling efficiency in the core protection.

3.15 Two numbers of axial fans are used and proper gap at the top and bottom of the motors for easy air exist. The motors are to be dynamically balanced with all the fans and with full key in the shaft extension, if required.

3.16 Motors shall be provided with antifriction bearings grease lubricated at both ends. Bearings shall be provided with seal to prevent leakage of lubricants or entrance of foreign matters like dirt water etc. in to the bearings area.

3.17 Grease lubricated bearings shall be pre-lubricated and shall have provisions for in service positive lubrication with drain to guard against over lubrication. Lubrication shall not detoriate under all service conditions. The lubricants shall be limited to normally available type IOC or equivalent.

3.18 The motors (above than 75 KW) are to be provided with 10 nos. +2 nos. platinum type resistance temperature detector PT100 type (recommendation by the motor manufacturer). The leads of this RTD's and BTD's are to be brought out in a separate terminal box. Over voltage fuses are to be provided for each RTD' & BTD terminals for connecting the alarm & trip connection.

3.19 The noise level shall not exceed 5 micron at 1.5 M away from the motor in full load condition. The peak amplitude of the vibration shall be within IS specification (IS: 11724) limit.

3.20 Motor terminals box shall be detachable type and located in accordance with IS. It should be suitable for terminating 2 nos. 1.1 KV grade PVC (AL) conductor armoured cable along with the lead cable for P.F improving capacitor may be connected, if required. No compound should be used in terminals box for easy handling. The terminals box shall

be capable of withstanding maximum system fault current for duration of $\frac{1}{4}$ th Cycle. The terminal box shall be clearly identified by phase markings with corresponding direction of rotation marked on the non-driving end of the motor.

3.21 The motor should have provided with ratchet mechanism to prevent reverse direction of rotation.

3.22 The frame of (higher rating as per IS motor) Motor shall be provided with space heater suitably located for easy removal or replacement. The space heater shall be rated 240 Volt single phase 50 Hz and size to maintain the motor internal temperature above dew point when the motor is idle.

3.23 The frame of each motor shall be provided with separate and distinct grounding pads complete with tapped hole, GI bolts & washer. The grounding connection shall be suitable for accommodation of ground conductor 50 X 6 or 25X 3 mm GI flat.

3.24 Motor shall have drain plug so located that they will drain the water, resulting from the condensation or other cause from all pockets of the motor casing.

3.25 Motor shall be provided with eye bolts or other adequate provision of lifting.

3.26 The motor frame shall be designed to permit easy access for drilling holes through motor feet or mounting flange for installation of dowels pin after final alignment of the motor and driven equipment.

3.27 The rating plate of the motor should be containing clearly output in KW, stator voltage, stator connection, stator current, frequency, RPM, at full load temperature rise, type of motor name & year of manufacturing, name of manufacture, numbers of pole, slip, and weight of the motor etc.

3.28 Motor including fan shall be painted with corrosion proof paint.

4.0 CHECK LIST OF THE MOTORS BEEING OFFERED

(Submitted by the successful bidder before issuing the work order)

Sl. No.	Description of Motor accessories	Check List
A	GENERAL	
01.	Manufacture	Crompton Greaves/ Kriloskar / BHEL/ ABB
02	Rated output in KW /HP	
03	Numbers of pole	
04.	Speed	
05.	Numbers offered	4 Nos. (2 Nos. Working and 2 Nos. standby)
06.	Approx. weight of the motor	
07.	Painting	
08.	Earth terminal lifting lug provided	Yes / No
09.	Type of enclosure	
10.	Installation	Vertical
11.	Shaft orientation and mounting	
12.	Degree of Protection	
13.	Technical leaflet / literature provide	Yes / No
14.	Type of duty & duty designation	
15.	Whether the motor is capable for operation after one hot restart and/ or equivalent space hourly restart.	
B	SUPPLY CONDITION	
16.	Rated Voltage (Volts)	
17.	Allowable Variation of voltage (%)	
18.	Frequency (Hz)	
19.	Allowable Variation of frequency (%)	
20.	Number of phases	
21.	Stator connection	
C	CURRENTS	
22.	Full load current	
23.	No load current	
24.	Starting current (%) of full load current	

D	Efficiency	
25.	Full Load Efficiency	
26.	Efficiency at 75 % of load	
27.	Efficiency at 50 % of load	
E	Power Factor	
28.	Full load power factor	
29.	No load power factor	
30.	Power factor at 75 % load	
31.	Power factor at 50 % load	
F	METHOD OF STARTING	
32.	Direct on line start	
33.	Star-Delta start	
34.	Auto-transformer start	
G	TORQUE	
35.	Starting Torque (% of full load Torque)	
36.	Maximum Torque (% of full load Torque)	
H	ACCELERATION TIME (SECOND) FROM DEAD STOP	
37.	with 100% Terminal voltage	
38.	with 85% Terminal voltage	
39.	Safe stall time	
I	CLASS OF INSULATION	
40.	Reference temperature (ambient) Degree centigrade	
41.	Temperature rise in degree centigrade by resistance method & class in which limited	
42.	Safe stall time	
J	SPACE HEATERS (PRESENT OR NOT)	
43.	Number	
44.	Rating (watt)	
45.	Voltage, phase & frequency	
46.	Whether separate terminal box provided for	
K	BEARINGS	
47.	Driving end	

48.	Non Driving end	
49.	Anticipated life (hours)	
50.	Recommended lubricants & Qty.	
51.	Whether separate lubricant nipple provided	
52.	Interval of lubricant hours	
L	WINDING & BEARING TEMPERATURE DECODER	
53.	Whether separate Terminals box provided or not	

5.0 DRAWINGS, DATA & MANULS

After award of the contact for approval:-

- Dimensional general arrangement drawings.
- Foundation plan and loading
- Cable end box details
- Space requirement for rotor removal.
- Thermal withstand curve hot & cold.
- Starting and speed characteristics curve at 80% & 100% voltage.
- Complete motor data.
- Erection and maintenance manual.

6.0 TESTS

Testing at factory: Upon completion, each motor shall be subjected to standard routine tests as per IS .In addition, type test of at least 50% of order number and as per choice of the consumer, shall be performed. Further any special tests called for in the driven equipment specification shall be performed. The manufacture/Tenderer has to bear all expense for such testing to witness the test for maximum two representatives (not bellow the rank of SAE) of the dept. to the manufacturer premises within shortest possible time Six (6) copies of routine and type test certificate shall be submitted for approval prior to despatch of the motors from the manufacturer factory.

CHECKING BEFORE INSTALLATION

- Check clean and dry
- Air gap check
- Tightness of fastener (nuts, bolts, locking clips)
- All safety guard
- Earth connection lead
- Lubrication points

Paint finish

Ventilation path fitters etc. are to be checked.

Correctness of name plate and diagram plate

Motor terminal box

Coupling and driving unit.

BTD and RTD Terminal box check.

SECRETARY

ASANSOL MUNICIPAL CORPORATION

MAIN POWER DISTRIBUTION BOARD FOR INFILTRATION GALLERY 1

7.0 MAIN POWER DISTRIBUTION BOARD (PDB)

Medium voltage Power Distribution board is required to receive power by bidder from the pre construction substation room and VCB Panel. From VCB Panel to 315 KVA transformer (including supply & Fixing) and transformer to L.T. PDB Panel through suitable Rating Air Circuit Breaker at high lift pump house and provide ACB as incomer feeders to feed motor control centre at utility loads at collector well LT substation is under bidder scope. The PDB shall be suitable for 415V \pm 10%, 50Hz \pm 3%, 3 phase, 4 wire supply system and Degree of Protection IP-54. The PDB shall be 2mm CRCA sheet steel enclosed, floor mounted type, self- supporting, fully compartmentalized , cubicle pattern and all the compartment door would be interlocked in such a way, the door cannot be open unless the switch is in off position. It shall be finish painted with powder coated paint after necessary chemical treatment for rust free surfaces and application of anti rust chemical coating.

The base frame of the panel shall be made of ISMC – 75 channels. The panel shall be dead front type with concealed hinged doors at front and bolted covers at the rear. It shall have rear access and the cable termination arrangement shall be provided at the rear of respective feeder modules where detachable type undrilled cable gland plates shall be provided for this purpose. The vertical dropper bus bars through bus- coupler shall be placed in between two vertical aligned feeder modules. The bus of the panel shall be made of E91E grade of Aluminium alloy insulated with 1.1 KV grade heat shrink type PVC colour coded sleeve. The rating of the bus bar shall be 2 to 2.5 times of the full load current of low voltage side of the transformer.

The current density of the bus bars shall not exceed 1 Amp / Sq. mm. The bus bars shall be supported on non-hygroscopic resin moulded fibre glass supports / insulators and the distance between supports / insulators shall be so designed to make the bus bar system capable of withstanding a short circuit fault current of 50 KA (r.m.s.) for 1 Sec. Two cut outs shall be provided at the top bus chamber and covered with plate for future extension purpose. The front bus bar chamber shall be fully shrouded to avoid accidental contact with the live bus bars. The minimum clearance between bus bars and bus bars to earth shall be as per I.S. Specification. Air Circuit Breaker termination shall be done with extended bus bar arrangement. The cable termination chamber shall be provided with cable supporting clamps. Each Breaker shall receive 4 nos. 1.1 KV 3.5 core not less than

required 400 Sq. mm. armoured Al. Cable. For other outgoing feeders the cable alley shall have to be provided in such a fashion that the cable will be taken out easily. The control wiring of the panel shall be done with 1.1 KV grades PVC insulated flexible copper wires with tinned copper lugs and ferrule marking at each end.

Wire bunches routed through horizontal and vertical wire ways which provide support and order. All hinged doors shall be earthed with flexible copper wires. Lifting arrangement shall be provided for lifting at the top of the panel. 2 Nos. space heaters with rotary switch shall be provided in bottom of the panel board.

THE RATING OF THE INCOMER WILL BE FULL LOAD CURRENT OF LT SIDE OF THE TRANSFORMER:- Incoming Feeders each consists of followings devices:

- a) 1250 amps electrically draw out type microprocessor based 4 poles Air Circuit Breaker from transformer with the following feature such as breaking capacity 50 KA, rated operational voltage – 690 V AC, rated insulation voltage – 1000 V AC and impulse withstand voltage- 12 KV with quick make break trip free mechanism and provided with over load and short circuit trip release, shunt trip coil, safety shutters, castle lock.
- b. 1 No. flush mounted type Voltmeter (0-500V) with selector switch for each ACB.
- c. 1 No. flush mounted type Ammeter 0-(breaker rating) A with selector switch and CT for each ACB.
- d. 3 nos. Universal Voltage LED for indication of Breaker on / off/ trip for each ACB.
- e. Current Transformer of ratio 1500 / 5A, Class: 1.0, 15 VA 3 Nos for each ACB.
- f. Current Transformer of ratio 1500 / 5A, Class: 5P10, 15 VA 3 Nos for each ACB.
- g. Red, Yellow, Blue phase indicating lamp 3 Nos for each ACB.
- h. CB ON / OFF / TRIP / Spring Charged / Trip Circuit Health DC Fail Indicating Lamp 6 Nos.
- i. TNC Breaker Control Switch 1 No.
- j. 1 No. Non Directional IDMT Relay with high instantaneous element for over current & earth fault protection type.
- k. 1 No. flush mounted Multifunction meter with Power factor indication.

OUTGOING FEEDERS

- A. For feeding main panel of the pumping station
- a) 1 no 1250 A for feeding the main pumping station panel electrically draw out type microprocessor based 4 pole Air Circuit Breaker with the following feature such as breaking capacity 50 KA, rated operational voltage – 690 V AC, rated insulation voltage 1000 V AC and impulse withstand voltage- 12 KV with quick make quick break trip free mechanism and provided with over load and short circuit trip release, shunt trip coil, safety shutters, castle lock with Digital feeder protection relay with 3 phase over current & earth fault element each with high set unit for feeding the IGLR pumping station panel.
 - b. 1 No. 96 Sq. mm. flush mounted type Ammeter 0-1200 A with selector switch and CT
 - c. 3 Nos. Universal Voltage LED for indication of Breaker On/Off/Trip.
 - d. 2 Nos. 63A TPN outgoing Feeders MCCB (for Yard Lighting + miscellaneous use)
 - e. 1 no 25 A TPN outgoing Feeders MCCB for house wiring purpose
 - f. 1250 A for feeding the APFC panel placed in the substation electrically draw out type microprocessor based 3 pole Air Circuit Breaker with the following feature such as breaking capacity 50 KA, rated operational voltage – 690 V AC, rated insulation voltage 1000 V AC and impulse withstand voltage- 12 KV with quick make quick break trip free mechanism and provided with over load and short circuit trip release, shunt trip coil, safety shutters, castle lock with Digital feeder protection relay with 3 phase over current & earth fault element.
 - g. 96 sq mm 0 – 400 A MISC. Ammeter with Selector Switch 1 No.
 - h. Current Transformer of ratio 400 / 5A, Class: 1.0, 15 VA 3 Nos.
 - i. TNC Breaker Control Switch 1 No.
 - j. CB ON / OFF / TRIP / Earth Fault Trip Indicating Lamp 4 Nos.
 - k. Spare 63 A MCCB -2 nos.
 - l. Spare for internal illumination & External illumination

**CHECKLIST FOR MEDIUM VOLTAGE PANEL (PCC) (SUBMITTED BY THE SUCCESSFUL
BIDDER BEFORE ISSUING THE WORK ORDER)**

- A. Make : **ABB/ SEIMANCE/L&T/ RNR**
- B. Rated Voltage / Rated Current :
- C. Short Circuit Withstand Capacity 50 KA : Yes / No.
- D. Sheet Steel Thickness :
- E. Degree of Protection IP – 54 : Yes / No.
- F. Bus Bar Rating & Short time capacity : Amp /KA
- G. Bus bar material / grade :

Incomer:

- H. Incomer Type : **ACB / MCCB / MPCB / RNR**
- I. Rating of the Incomer : -----VoltAmp...KA
Breaking CapacityNo. of Pole

Relay:

- J. Protective Relay Type : Draw out / Non draw out
- K. Relay Voltage : Self /Separate.....Voltage
- L. Relay feature (O.C. & E.F.) : Yes / No.
- M. Used in Incomer feeder : Yes / No.

Outgoing Feeder:

- P. Outgoing Type : **ACB / MCCB / MPCB / RNR**
- Q. Nos. of outgoing :
- R. Rating of the outgoing breaking capacity : -----VoltAmpKA
.....No. of Pole
- S. Protective relay Type (ACB Feeder) :
- T. Switch Fuse Unit Number & Rating :
- U. Size: Length x Breadth x Height in mm. :
- V. Approximate weight in Kg. :

Testing

- A. Visual inspection for checking the panel components, its voltage, current rating, breaking capacity etc. as per approved drawings.
- B. The insulation Test as Indian Electricity Rules.
- C. Operation test at site with load.

D. Relay Tripping Test as per specification at site.

Installation

- A. Transport of materials from store to erection site
- B. After opening the packing case, inspection of materials is required, if any damage is occurred during transportation necessary rectification is to be done, if require touch up paint should be done where necessary.
- C. All alignment, levelling, grouting, anchoring and adjustment including Inter Panel locking as necessary in accordance with manufacturers. Any chipping/ levelling insertion of packing plate's minor attendance of board internals etc. as necessary for the above is in bidder scope.
- D. Retightening of the bus bar and rechecking of the control panel wiring are in the bidder scope.

6.0 APFC PANEL (AUTOMATIC POWER FACTOR CORRECTION PANEL)

The Medium voltage APFC panel is required to develop the power factor from 0.8 lag to 0.98 lag after providing 400 A TPN (four poles) ACB. The APFC panel shall be suitable for indoor type 415V \pm 10%, 50Hz \pm 3%, 3 phase, 4 wire supply system and Degree of Protection IP-40. The APFC panel shall be 2mm CRCA sheet steel enclosed, floor mounted type, self- supporting, fully compartmentalized, dust proof, cubicle pattern. It shall be finish painted with powder coated paint after necessary chemical treatment for rust free surfaces and application of anti rust chemical coating. The base frame of the panel shall be made of ISMC – 75 channels. The panel shall be dead front type with concealed hinged doors at front and bolted covers at the rear. It shall have rear access at respective feeder modules where Capacitor bank shall be provided. The bus of the panel shall be made of E91E grade of Aluminium alloy insulated with 1.1KV grade heat shrink type PVC colour coded sleeve.

The rating of the bus bar shall be 2 to 2.5 times of the full load current of the capacitor draw current. The current density of the bus bars shall not exceed 1Amp / Sq. mm. The bus bars shall be supported on non-hygroscopic resin moulded fibre glass supports / insulators and the distance between supports/insulators shall be so designed to make the bus bar system capable of withstanding a short circuit fault current of 50KA (r.m.s.) for 1 Sec. The front bus bar chamber shall be fully shrouded to avoid accidental contact with the live bus bars. The minimum clearance between bus bars and bus bars to earth shall be as per I.S. Specification.

The capacitors shall be of APP type. The capacitors shall conform to IS 2834 of latest amendments. The panel shall be suitable for minimum 250 KVAR rating (Exact KVAR rating should be calculated and submitted at the time of detail engineering) and complete in all respect with 4/6 (four/Six) stages of each 30 KVAR, 4/6 (four/six) stages of each 25 KVAR, 2 stages of each 10 KVAR, 2 stages of each 5 KVAR capacitor bank to generate 250 KVAR at 440 V as per requirement to improve P.F. as far as possible 0.95(in no condition the PF will be go to leading stage).

The capacitors should come into line automatically with certain time delay for which contactors / relays / timers should be used. Suitable current transformer and potential transformer is to be used. There shall be also provision for manual push button operation in addition to the auto mode. Switches with HRC fuses should be provided for each current. P.F. meters in incoming & outgoing are to be placed along with one ammeter for displaying the improvement in P.F. achieved. The panel should be with all interconnection complete. The control wiring should be with 2.5 sq mm 'Cu' single core conductor of 1.1 KV grade cable.

The following components are to be incorporated with the panel.

- a) All power contactor shall be Capacitor duty (with dumping resistance) for capacitor switching.
- b) All individual feeders will be backed by suitable rated Power fuse base with link.
- c) All individual banks should be suitable for Manual / Auto operation.
- d) APFC relay will be 16 channels with microprocessor base system along with display.

7.0 Testing

- A. Visual inspection for checking the panel components, its voltage, current rating, breaking capacity etc. as per approved drawings.
- B. The insulation Test as Indian Electricity Rules.
- C. Operation test at site with load.
- D. Relay Tripping Test as per specification at site.

8.0 Installation

- A. Transport of materials from store to erection site.

- B. After opening the packing case, inspection of materials is required, if any damage is occurred during transportation necessary rectification is to be done, if require touch up paint should be done where necessary.
- C. All alignment, levelling, grouting, anchoring and adjustment including Inter Panel locking as necessary in accordance with manufacturers. Any chipping/ levelling insertion of packing plate's minor attendance of board internals etc. as necessary for the above is in bidder scope.
- D. Retightening of the bus bar and rechecking of the control panel wiring are in the bidder scope

SECTION - N

SCOPE OF WORK

1.0 LAYING OF RISING MAIN

Supplying, Laying and fabricating of spiral welded mild steel 12 mm thick Spiral mild welded M.S. Pipe line (TATA / SAIL make) on both sides of foot way bridge 450 mm dia. from Collector well to MS manifold pipe line at the starting point of foot way bridge (approx length 2 X 400 meter) and Laying D.I. pipes (800 mm / 700 mm dia. K9 will be supplied from AMC office) approx length 300.00 meter including earth work in excavation in trenches, shoring (if necessary) of adequate width having minimum depth to keep the top surface of pipe 1.00 M below of the existing ground level in any kind of soil mixed with boulder, metal crust, concrete pavement, any road sub-grade and its flank etc., dewatering the trenches, preparing the bottom surface of the trenches for continuous bedding including sand filling (if necessary) or over ground installation to cross ditches etc. supported with RCC pillars as & when necessary.

And fitting, fixing, jointing (all types of joints) valves, specials etc. as per requirement, in position, cutting, chamfering of pipes as required, carriage of materials from departmental store to work site, constructing sluice valve chambers including supply and fitting in position sluice valve of different dia. as per requirement , filling of the trenches with excavated materials, consolidating the same in layers, temporary road restoration, guarding trenches with temporary bamboo railing for safety where necessary, emergency horizontal auger boring (for roads other than NH & SH) where necessary, removing the surplus materials from site including all labour charges, tools and plants, hydraulic pressure testing, cleaning and disinfection of pipes etc. complete in all respect as per IS 12288-1987 (latest edition) and instruction of E.I.C. (only the pipes, rubber rings, Mechanical joints and specials of different dia. will be supplied departmentally. Only sluice valve where necessary will be supplied by agency. The surplus and unused materials are to be returned to store at his own cost.)

2.0 LOCATION

The site of the pumping station at Chinakuri, R.S. Plot No 278, Asansol Municipal Corporation near the river of Damodar, P.S. – Asansol, Dist. –Paschim Bardhaman.

3.0 DETAIL SCOPE OF WORKS

- I.** The agency has to quote the rate on the basis of quantity of laying as per drawing attached as Annexure I and existing condition of the site as unit rate diameter wise. The participating agency has to carefully inspect the site with the attached drawing and collect all data for preparation of justified estimate and thereafter evaluation of unit rate against each item of BOQ. The participating agency also includes the cost of all such items in estimating the total cost which is required to complete the work complete in all respect.
- II.** The work is to be executed as per related IS Specification, Municipal Form K7 and other specification laid down in the bid. The DI Pipes of different diameter, specials and mechanical joints etc. except Sluice valve will be supplied by Municipality.
- III.** The contract comprises of laying of the distribution system and laying, fitting, fixing, jointing, distribution pipes and all other works incidental thereto as desired and set-forth in the specification, Bidders are advised to inspect the site before tendering, extra claims on the ground of insufficient data and absence of knowledge about conditions prevailing at site shall not be entertained.
- IV.** A network drawing is attached with the quotation in .pdf format. The agency has to collect the drawing format (AutoCAD format) from the concerned division and planned everything on the drawing i.e., where additional work of shoring, BFS,RCC column, sand filling Sluice valve and chambers etc. are required. The whole planning thereof will be upload in .pdf format in a folder under Technical bid. This will be one of criteria to judge the Technical ability of the participating agency. This will be the basis on which the successful bidder have to submit the details of estimate if asked for before acceptance of bid. The final drawing(6 copies) prepare on the basis of the above will be prepared after issuance of work order and will be approved by competent authority if found correct.
- V.** The work has to be carrying out on the basis of the approved drawing and part drawing has to submit along with each R.A bill submitted by the Contractor.
- VI.** After completion of the work a completion drawing (6 copies) in suitable scale with position of pipes(diameter wise and its length), specials/fittings, valves issued to him by Department or supplied by them have to be submit along with final bill. The final bill shall not be paid unless the said stipulation is complied with.

VII. Care has been taken to make the uploaded drawing as correct as possible; nevertheless these drawings must be checked thoroughly by the tenderers' who will be held responsible for satisfactory work of the pipe connection with all its details. Any discrepancy noticed should be pointed out before the work is commenced. Under all circumstances, the contractor will be held responsible for the satisfactory completion. In case of any discrepancy between the drawing and the schedule of tender, the decision of the Superintending Engineer will be final and binding.

VIII. The works are to be carried out strictly in accordance with approved drawing and specification supplemented by other detailed working drawings as the Engineer-in-Charge may sign, if necessary, from time to time. For any change, no extra claim will be entertained

IX. The pipes are to be laid as far as practicable along road flanks with least hindrances to the vehicular traffic. The contractors are to obtain the information regarding the layout and precise position of the underground Electric Main, Telephone or other Cables. No responsibilities in this respect will be taken by the Directorate. The contractor will have to cut metal road where suitable Road flank is not available and its cost is included in the relevant items of the work. The information regarding the layout and precise position of the underground Electric Main, Telephone or other Cables. No responsibilities in this respect will be taken by the Directorate. The contractor will have to cut metal road or bituminous road of any thickness where suitable Road flank is not available and its cost is included in the relevant items of the work.

X. The trenches will have to be adequately protected against accidents continuously throughout day and night. Demonstrations of danger signals, red lamps and other signs as may be required at the vintage point and imperative upon the contractors in the interest of public safety.

XI. The contractors' will further shore up and support to the satisfaction of the Engineer-in-Charge, all Building Works, Electric Mains, Telephone or Other Cables, Surface Storm Water, Drains, Ditches, Culverts, Water Sources, Water Mains and Other Pipes which may be or likely to be affected or endangered or disturbed by the works, being in the line thereof and continuous thereto.

XII. The contractors' will be liable for and make good at their own expenses within a reasonable period of time to be fixed by the Engineer-in-Charge, all damages which may be occasioned to one or combination of items in building, walls, water mains and other pipes by or in consequence of the execution of the works or accident whatsoever, in the event of default (in lapse with respect to the time limit) it shall be lawful for the undersigned to employ other agency to make good the damages at the risk at cost of the contractors' after a 24 hours written notice period has elapsed. The expenditure amount in above situation will be deducted from the bills of agency.

XIII. In case of trenches in front of any holding so as to block its passage of communication, the contractors' will have to make for temporary arrangements to remove the difficulties by provision of wooden planks or otherwise and removing the same after the trenches are filled up.

XIV. The tenderers will consider the conditions and adjust the extent of liabilities involved and quote their rate accordingly. Since no extra claims will be entertained separately on that account, inspection of sites prior to tendering, therefore, should be done by the tenderer.

Further "Laying of Pipes" shall also include. Excavation of trenches a depth ensuring a minimum cover of one metre over the top of the pipe.

XV. Decision of the Engineer-in-Charge in this respect is final. The excavation shall have to be done through any materials (e.g. soil, premixed road surface, concrete to roads etc.) with shuttering and dewatering as may be required to protect the trenches and facilities the works during execution. This also includes cutting and removing trunks and roots of trees upto 20mm dia.

XVI. Cutting the pipes to sizes (except for damaged ends supplied by the Department, where necessary), lowering and placing them along trenches including laying, fitting and jointing with rubber gasket and / or solvent cement joint and/or D.T. joint as the case may be. Filling the trenches in layers of 15 cm. each layer being adequately watered and consolidated. The filling has to be done after completion of the joints and after affecting the hydraulic test as per specification.

XVII. After removal of the surplus excavated materials (except road metal) after the trenches have been rammed to the satisfaction of the Engineer-in-charge, if any, serviceable materials such as bricks and stones ballast and chips, stone-setting, asphalt etc. are available from roads and other road flanks along which the pipes have been laid for restoration of the same, contractor will arrange for stacking these materials properly and separately as per direction of Engineer-in-Charge for which, no extra payment will be entertained in this situation.

XVIII. The contractors' rates for laying pipes will also include the cost of all the items of works mentioned with this Clause excepting that for which, a separate item has been provided in the schedule.

XIX. In general, the pipes have to be laid below 1 metre from the existing ground level but if 1 metre cushion cannot be maintained anywhere to maintain the hydraulic gradient in the undulating terrain, (+/-) 10 % deviation in respect of such situation will be acceptable.

XX. The contractor will provide his own arrangement for every cost, charges or expenses which may be claimed or any person public or private or Government concerned, occurred to the property of life of any such concern or person (as the case may be) by or in consequence of the execution of the said work or in respect of any labour of work, entitled upon said work for which, no extra payment will be allowed.

XI. TEMPORARY ROAD RESORATION (KUTCCHA ROAD / COCRETE ROAD):

The kutcha roads and other road flanks along which the pipes have been laid, have to be restored fully by filling, watering and consolidating in accordance with specification. Filling up the trenches with loose excavation materials followed by a loose layer at the top is not permitted. For any lapse on part of the contractor in this respect, a deduction as decided by the Engineer-in-Charge shall be made from bill which becomes payable under this contract.

No separate payment will be made for filling up of trenches to original level and proper consolidation thereto. Contractor will also have to dress the damaged alignment time to time as and when necessary during the tenure of the contract. All such costs must be included while quoting the rate.

The contractors' must see that the finished tops of the filled up trenches do not give rise to any significant difference of level (i.e., in form of hump or depression so as to cause hindrances to vehicular traffic). In case of Concrete road restoration will be done by minimum 100 mm thick M15 grade of concrete.

XXII. EXISTING TAR MACADAM ROAD :- Cutting of existing bituminous / concrete road and restoration of road by laying brick flat soling of picked jhama bricks, including dressing in proper level and filling gaps of jhama bricks with local sand and supplying, laying, spreading and consolidation over the soling of picked jhama bricks including dressing in proper level and filling gaps of jhama bricks with local sand and morrum as per direction of Engineer-in- Charge.

XXIII. WATER BOUND MACADAM ROAD :- Restoration of ordinary water bound macadam road as per West Bengal P.W.D. (Roads) Code of practice, bricks flat soling of picked jhama bricks including dressing bed on proper level and filling gaps with local sand supplying, spreading and consolidating over the soling jhama metal of 5cm. size by road roller to a thickness of 15cm. including earth, old serviceable materials to be used along with new materials as per direction of Engineer-in-Charge.

XXIV. EXCAVATION OF FOUNDATION, FILLING UP TRENCHES:

Foundation to be excavated as per drawing. The depth and width of trenches to be properly maintained. The bed of trench is to be properly levelled and rammed. Any water accumulated in the trenches due to sewage or rain water to be dewatered at the cost of contractor. The laying rate includes for excavation in whatever soil and stone hard or soft that may be found and breaking through any underground structure surface metal ling, pegging and trimming and pumping, if necessary, for removal of water or muddy water, taking out mud keeping the top soil separately or unavailing of surplus materials, tapping and shoring excavated materials, matching temporary instalment and maintenance of surface and every other expense in strict conformity with the specification.

The excavated areas around the foundation structure are to be filled up properly to the required levels with the earth obtained from excavation. The filling should be done properly consolidated with Iron Rammer and sprinkling water. The cost of filling up the trenches includes relevant items of work for which, no extra payment will be made.

XXV. DEPARTMENTAL SUPPLY OF PIPES AND CARRIAGE:

The departmental supply of D.I Pipes of different dia, will be made from the local departmental store. List of pipe will be prepared on the basis of the actual requirement duly once set by Engineer-in-Charge so that, least possible materials are left surplus which are to be returned back to local departmental store by the contractor for which no extra payment will be made.

The carriage cost from store to work site has been provided in the respective item of the schedule, for which, no extra payment will be made. The contractor shall check the quality of materials before taking delivery of the same, any subsequent complaint in this respect shall not be entertained.

The contractors' are solely responsible for the safe custody of those supplied materials onwards from the date of issue till the same are used in the work according to the contract and the surplus items are finally handed-over to this directorate / department. For any loss or damage occurring during this period, the contractors' will remain responsible and recovery will be made from them as per Rule.

The contractors' at their own cost will supply labours for loading, unloading and stacking the materials as and when required by the Engineer-in-Charge.

No carriage charges will be paid for any carriage within the campus of the work site, for any advance carriage (to relieve cage of the store), double carrying if it becomes necessary and return the surplus materials to the departmental stores, no extra payment shall be made. The cost of all such carriage has been included and distributed in the relevant items of the bill of quantities.

No claims for extra payment due to any delay of detention, dispute of non-procurement of materials to be supplied departmentally or for any other reason will be entertained.

XXVI. RECOVERY OF MATERIALS:

For loss of damage of the materials supplied by Government or non-returning of surplus materials, recovery will be made from the contractor at the highest of the following rates :-

Fifty percent in excess of departmental stock rate or the rate at which Municipality buy the material from agency at the time of recovery of value. Ten per cent in excess of market rate at the time of recovery of value. Decision of the Executive Engineer / E.I.C. concerned in respect of market price is final and bindings.

The contractors' should carefully examine the materials supplied from Govt. Store regarding its quality and suitability. No complaint in this regard will be entertained once the materials have been supplied to and received by the Contractors.

XXVII. DEPARTMENTAL MATERIALS AND COST:

All the materials except D.I. Pipes, and DT / Mechanical Joints, D.I. / C.I. Specials and Rubber Gaskets have to be supplied by the contractor. Only the D.I. Pipe will be supplied by the Department free of cost as non-recoverable items. Other items will be supplied by agency at his own cost.

XXVIII. TIME OF COMPLETION:

The works for pipe line shall be completed in all respect by the contractors' within 180 (One hundred and eighty) days. In the event of work being not completed within this stipulated period, the contractors' will be liable to pay a penalty as Clauses of Asansol Municipal Corporation tender Form through which the tender will be accepted.

The contractor will show satisfactory cause for delay in starting work if the works are not started within 10 (ten) days from the date work order. Otherwise, the contract will be terminated. The contractor will accordingly, prepare a time bound programmes of execution with regard to all the items of work set-forth in a schedule and submit the same to the undersigned within 7(seven) days' from the date of work order.

For unsatisfactory progress of work, it will be the option of the undersigned / E.I.C. to withdraw the works out of the contractors' and to get the balance works done through any other agency at the risk and cost of the contractors'.

In case of recurrence of unsatisfactory progress, the undersigned/E.I.C. shall have the power to rescind the contract and to impose such penalties as have been specified in

the Asansol Municipal Corporation tender Form. The contractor may further be debarred from tendering for works under this Directorate.

Before starting the work, the contractor shall submit a target of progress schedule showing the different portions of work, he expects to complete against stages of time.

XXIX. SITE ORDER BOOK:

The contractor will produce Site order book at site before commencement of the work duly numbering the page herein shall be recorded the orders, instructing comments, sketches etc. as may be issued at site by the undersigned / Engineer-in-Charge or his authorized representative from time to time. The contractor also will comply with such order, instruction, sketches etc. and will maintain the site order book till the contract is fulfilled and will be required to produce the same on demand by the Engineer-in-Charge.

The site order book shall be a bound register full shape size of fifty pages in triplicate duly marked two pages in each unit of three should have perforation beside, so as to be easily detachable.

The contractors' or authorized representative (to be categorical named by the contractors') must sign any such orders, instructions, comments and sketches issued as a token acceptance in all three pages of the Site Order Book.

XXX. ACCIDENT OR INJURY TO WORKMEN:

The Employer shall not liable for or in respect of any damages or compensation payable at law in respect or in consequence of any accident or injury to any workman or other; person in the employment of the Contractor or any sub-contractor, have and except any accident or injury resulting from any act or default of the employer, his agents, or servants. The Contractor shall indemnify and keep indemnified the Employer against all such damages and compensation, save and except as aforesaid and against all claims, proceedings, costs, charges and expenses whatsoever in respect thereof or in relation thereto.

4.0 SPECIFICATION OF DIFFERENT ITEM OF WORKS TO BE EXECUTED

a) Supplying, laying and fabrication of MS pipe all types valve, specials & Laying D.I. pipes (All types & Class of different diameters) with specials including earth work in excavation in of adequate width as per relevant IS Code having minimum depth to keep

the top surface of pipe 1.00 M below of the existing ground level in any kind of soil mixed with boulder, metal crust, concrete pavement, road sub-grade and its flank etc., in position and carriage of materials from departmental store to work site, filling of the trenches with excavated materials, consolidating the same in layers, removing the surplus materials from site including all labour, tools and plants etc. (Only the pipes, will be issued departmentally. The surplus and unused pipe are to be returned to store at contractor's own cost.)

b) Laying of M.S. / C.I. / D.I pipes & specials over brick or concrete pillar or wall unto height of 2 m above ground level aligning assembling etc. all complete including cost of all salbullah staging, bamboo scaffolding tools & plants specials for hoisting and positioning etc. all complete as per specification and direction of E.I.C.

c) Cutting M.S. / cast iron / D.I. (all types) by gas welding / chisel / Hacksaw including rendering the surface smooth to make it suitable for flange joint / rubber gasket / rubber ring etc. complete as per direction of E.I.C.

d) Chamfering the spigot end of the C.I / D.I pipes for using in tyton joints line or otherwise by means of electric grinder set at site as per direction of E.I.C

e) Cleaning thoroughly the inner surface of pipe line including special & valves by flushing with water & subsequently disinfection of the same pipe line by flushing again with water containing bleaching powder resulting in residual chlorine not less than 10 mg / Hr. after 24 hours of such filling including laboratory testing of water sample obtained from disinfected pipe line & disposal of water from the pipe line after completion of the work. The rate is including of cost of requisite water to be arranged by the Contractor.

f) Supplying & delivery at working site CIDF sluice valve, Non return valve, Air release valve, Pressure Release Valve, water discharge digital Flow meter conforming to IS 14846-2000 (ISI marked), with latest amendment, Specials, accessories including stacking and inclusive of departmental inspection, packing charges, all taxes and duties as applicable and payable, Flanged drilled as per IS 1538/1993 with latest amendment all complete along with installation of the same as per direction of EIC. (Approved make: Kirlosker / Kalpana / Upadhyay) Class PN 1.6 with cap. (All materials except D.I. Pipe to be supplied by agency)

- g)** Making flange joint to M.S. / D.I pipes and specials and valves including dewatering of trenches, tools & plants, labour etc as per specification and instruction of E.I.C .
- h)** Hydraulically testing of different types of pipes in sections for a head of water not less than 1/2 (Half) the that pressure recommended by I.S or corresponding pipe materials whether the gauge pressure will remain static for 30 minutes by filling water including supply of necessary equipment's such as generator sets, pumps gauges etc. All complete as per specification and instruction of E.I.C. [Water have to be arranged by the bidder himself and whole testing procedure will be accordance with as per IS : 3114 - 1965]
- i)** Hire and labour charges for 75 mm dia bamboo railing on Jhau / Eucalyptus or other approved timber / bamboo posts 1.4 m above GL and 0.6 m below GL including tying strongly with coir ropes and boring holes for posts in any soil/ concrete surface / Bituminous surface packing the sides etc. including cost of restoration to the damages of the ground to its original condition as per direction of EIC after removing barricade. 75 mm dia bamboo railing and 100 mm dia bamboo posts @1.4 mtr apart railing with 3 rows.
- j)** Dismantling all type of masonry including cement concrete stacking serviceable materials at site and removing rubbish as directed within a lead of 75m in ground floor including roof.
- k)** Cutting sub -grade of road (concrete bituminous carpeting & consolidated Ballast / brick soling & other sub-grade materials by means of chisels/Hammer other equipments (for trenches & laying of pipe line) are in the bidder scope.
- l)** Emergency horizontal road crossing by Augor-boring including boring charge, pipe laying and jointing, making barricades, lighting arrangement etc. all complete as per direction of E.I.C For 100 mm dia to 500 mm dia pipes.
- m)** Construction of sluice valve chamber as per drawing supplied by concerned division or standard drawing given by contractor and approved by E.I.C with brick work in cement mortar (6:1) over 15 cm. of WCC (6:3:1) with supply of approved quality (Heavy type) C.I surface box embedded in 100mm thick removable slab in (4:2:1) including fitting, fixing and overhauling and instruction of E.I.C (Valves will be supplied by Agency).

- n)** Installation of CI Bolted collar as per IS 13382-1992 with latest amendment or end cap up to date including all taxes & other incidental charges what so ever, carriage, loading unloading & stacking at working site.
- o)** Hire and labour charges for shuttering with cantering and necessary staging upto 4 mtr. using approved stout props for and thick hardwood planks of approved thickness with required bracing for concrete slabs, beams and columns, lintels curved or straight including fitting , fixing and striking out after completion of works (up to roof of ground floor), as per drawing, specification & direction of E.I.C.
- p)** Ordinary cement concrete (mix 1:2:4)) with graded stone chips (20 mm nominal size) excluding shuttering and reinforcement if any in ground floor as per relevant IS Codes. a) Pakur variety. In ground floor
- q)** Reinforcement for all reinforced concrete work in all sorts of structures including distribution bars, stirrups, binders etc. including supplying of rods, initial straightening and removal of rust (if necessary), cutting to requisite length, hooking & bending to correct shape (if necessary) placing in proper position & binding with 16 gauge black annealed wire at every intersection etc. complete as per drawing & specification including cost of wire.
- r)** Ordinary cement concrete (mix 1:1.5:3) with graded stone chips (20 mm nominal size) excluding shuttering and reinforcement if any in ground floor as per relevant IS Codes. a) Pakur variety. In ground floor
- s)** Single Brick Flat Soling of Picket Jhama bricks including ramming & dressing bed to proper level & filling joints with powder earth or local sand.
- t)** Restoration of late rite / morrum / bituminous road to its original condition with old and new materials and by supplying edging etc. over a layer of B.F.S. complete as per direction of and satisfaction of E.I.C.

Secretary

Asansol Municipal Corporation

ANNEXURE – I

SOIL / SAND INVESTIGATION REPORT FOR COLLECTOR WELL STRUCTURE

Soil / sand investigation SWID report has been attached as Annexure I. Bidder may take his own survey at the site. The safer values between these two have to be taken while designing the foundation.

SECRETARY
ASANSOL MUNICIPAL CORPORATION

ANNEXURE - II

LIST OF DOCUMENTS TO BE FURNISHED

List of instruments supplied by bidders have to be furnish by bidders and will be uploaded in Technical Document 2 folder with digital signature.

1. Pump thrust bearing housing details.
2. Pump non-reverse ratchet details.
3. Finally approved pump house layout with load data.
4. Finally approved single line diagram of the electrical system and earthing.
5. Cable schedule and termination chart.
6. GA details of L.T. Board at pumping and substation.
7. Schematic power wiring drawings (M.V), panel wise.
8. Schematic Control Wiring drawings panel wise.
9. List of authorized service centres of individual equipment.
10. List of special tools & tackles required for effective installation & maintenance.
11. Installation, operation, maintenance manuals for all equipment.
12. Completion drawings for all electrical circuit diagrams, layout Terms & Conditions.
(The drawings etc. shall be furnished on transparency along with the copies mentioned).

SECRETARY

ASANSOL MUNICIPAL CORPORATION

ANNEXURE – III

LIST OF TOOLS OF ELECTRICAL EQUIPMENT

Supplied by the bidder

Sl. No.	Description of Item	Quantity & Make
A	Mechanical instrument	
01.	Double Ended Spanner (6 mm to 25 mm)	3 Sets
02.	Screw Driver (6 mm to 25 mm)	3 Sets
B	Sliding Pipe Wrench	
03.	150 mm	3 Nos.
04.	250 mm	3 Nos.
05.	350 mm	3 Nos.
06.	Hand Drill (6 mm to 19 mm)	3 Nos.
07.	H.S. Drills (1.5 mm to 10 mm)	3 Nos.
08.	Round Rough File 350 mm	3 Nos.
09.	Flat Rough File 350 mm	3 Nos.
10.	Steel Tape 2 Meter	3 Nos.
11.	Hacksaw 300 mm	3 Nos.
C	Hammer with handle	
12.	1 kg	3 Nos.
13	2.5 kg	3 Nos.
14.	Cold Chisel 200 mm x 20 mm	3 Nos.
15.	Centre Punch	3 Nos.
16.	Engineering Square 200 mm	3 Nos.
17.	Spirit Level	3 Nos.
D	Electrical Equipment	
18	Multi Range Tong Tester	1 No.
19	500V Meggar	1 No.
20	Multi Meter	1 No.

ANNEXURE - IV

LIST OF VENDORS

Sl. No.	Equipment / Instrument	Make
01.	Pumps	KIRLOSKAR/WPIL/ KSB/ MATHER & PLANT
02.	Motors	SIEMENS/KBL/ABB/CG/MATHARON
03.	MCC	LARSEN & TOUBRO/SIEMENS/RNR/ABB/SALWIN
04.	Electrical component	LARSEN & TOUBRO/SIEMENS/RNR/ABB
05.	Power distribution board	L & T/SIEMENS/RNR/ABB/SALWIN
06.	Hoist	INDEF/ROPEMASTER/SUREKHA
07.	Valves (Sluice/Butterfly/NRV)	KIRLOSKAR/IVC/KSB/AUDCO
08.	Isolation Penstocks	Nil
09.	Pressure Gauge	H.GURU/BELLS
10.	Ammeter, Voltmeter	AE / IMP/ L&T
11.	Control Switchs.	SIEMENS / L&T / ABB
12.	Push buttons, Selector Switches, Indicating Lamps	SIEMENS / L&T / ABB
13.	Air Circuit Breakers	ABB/GE/LARSEN & TOUBRO/ABB
14.	Power Cable (Aluminium)	UNIVERSAL/HEAVELS/GLOSTER/NICCO/FINOLEX
15.	Control Cable (Copper)	UNIVERSAL/HEAVELS/ NICCO/ FINOLEX
16.	HRC Fuse	LARSEN & TOUBRO/SIEMENS/GE
17.	Contractors	LARSEN & TOUBRO/SIEMENS/GE
18.	Overload Relays	SIEMENS/GE/LARSEN & TOUBRO/AVK-SEG & CONTROLS (I) LTD/CUTLER HAMMER
19.	Local start / stop Push button switch	SWITCHGEAR AND ACCESSORIES/ SIEMENS/L&T
20.	Current Transformers	CROMPTON/BHARAT BIJLEE/EMCO/KAPPA
21.	OC/EF & Under voltage	EE/LARSEN & TOUBRO/ABB
22.	Capacitor	CROMPTON/KHATAUJUNDER/NCEF/UNISTAR
23.	Light Fitting including Lamps & Tubes.	PHILIPS/HEAVELS/CROMPTON (all should be LED lights)

24.	Ceiling Fans & Cabin Fans	GEC/ CROMPON/HEAVELS
25.	Exhaust Fans	GEC/ CROMPON/HEAVELS
26.	15-A Industrial Plug Socket outlets.	HEAVELSA/ANCHOR
27.	Multi-range Tongue Tester	MOTWANE
28.	Avo-meter	MOTWANE/HITACHI
29.	500 Volt Meggar	HITACHI/MOTWANE
30.	Paints	ASIAN PAINTS/ ICICI/ JONSON & NICHOLSON/ SHALIMER/ BERGER
31.	Epoxy Resin	CIBA - GEIGY
32.	Fibre Glass	MAT FIBRE GLASS PILKINGTON
33.	Flow meter	ABB/SEIMANCE/MARSHALL
34.	Temper proof air release valve	KBL/IVC
35.	Power Transformer	ANDRIWEL/ SCHINIDER/ KEC/ CG/ BHEL/ELECTROMECH
36.	HT VCB	ABB/SEIMANCE/SCHINIDER/KEC/CG/BHEL /BICCO-LAWRIEE / ANDRIWEL

SECRETARY
ASANSOL MUNICIPAL CORPORATION

ANNEXURE - V

LIST OF DEVIATIONS

The Bidders are advised to fill up the list of deviations, they indicate/sought for in their offer, showing the specifications & the deviations wanted backed by all clarifications & justifications.

If there is no deviation sought, the Bidder must indicate NIL in the list.

Sl. No.	Items	Details as per Bid specification	Details of the offer	Reason for which such deviation sought for with technical backup

Signature of Bidder

SECRETARY
ASANSOL MUNICIPAL CORPORATION

ANNEXURE – VI

HYDRAULIC SURVEY REPORT BY SWID

Photocopy of Hydraulic Investigation Report is enclosed and uploaded for general guidance.

SECRETARY
ASANSOL MUNICIPAL CORPORATION

ANNEXURE – VIII

TENTATIVE SITE PLAN AND LAY-OUT PLAN OF COLLECTOR WELL

One copy of 'Tentative Drawing' of proposed Collector well, foot way bridge, Pumping station & L.T. Sub Station located at Plot No- 278, Mouza : Chinakuri, within Asansol Municipal Corporation, Paschim Bardhaman District, is enclosed herewith for Bidders ready reference. They are requested to visit the Site physically and to verify the dimensions of the proposed Plot and to judge all other conditions if any, which may affect their Design and proposal.

SECRETARY
ASANSOL MUNICIPAL CORPORATION